

QF-LDC-08
Page -1

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 834 MW (20:00) of load shed was imposed over the whole areas of the national grid .
b) Due to low gas pressure Raozan (210 MW),RPCL (210 MW) and Baghabari (100 MW) were limited to 80 MW , 106 MW and 90 MW respectively.	
c) After maintenance Raozan #2 was synchronized at 14:01.	
d) Sikalbaha GT was shut down at 16:23 due to gas shortage .	
e) Ashuganj - Kishoreganj 132 KV line-1 tripped at 11:26 showing dist-C . At the same time Mymensingh RPCL GT-3 & St also tripped due to low voltage . Line was switched on at 21:35 from Kishoreganj end and machines were synchronized at 11:39, 18:12 respectively.	
f) Ashuganj - Comilla (N) 230 KV line-1 was switched on at 19:23 & taken in to service.	
g) Satkhira 132/33 KV T1 X-former was shut down at 07:30(19/10/10) due to annual maintenance.	
	Due to generation shortage, about 150 MW (09:00) of load shed has been running since morning (19/10/10) over the whole area (except Sylhet) of the national grid.

Deputy / Asstt. Manager
Network Operation Division

Manager
Network Operation Division

Deputy General Manager
Load Despatch Circle