

CENTRAL LOAD DESPATCH CENTER

DAILY REPORT

MIS=302

Page -1

Reporting Date : 27-Feb-07

Till now the maximum generation is :-

3782.1 MW at 20:00 on

30-Oct-05

The Summary of Yesterday's (26-Feb-07)		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	2768.0	MW	Hour : 8:00	Min Gen. at 4:00	2448 MW
Evening Peak Generation :	2900.6	MW	Hour : 20:00	Max Generation :	2805 MW
E.P. Demand (at gen end) :	3758.0	MW	Hour : 20:00	Max Demand :	3800 MW
Maximum Generation :	2915.6	MW	Hour : 21:00	Shortage :	995 MW
Total Gen. (MKWH) :	62.01	System L/ Factor :	88.62%	Load Shed :	876 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :- Maximum	252 MW	at 7:00	Energy	3960000 KWHR.
Import from Ishurdi to Ghorasal:- Maximum	-	MW at -	Energy	- KWHR.

Water Level of Kaptai Lake at 6:00 A M of 27-Feb-07

Actual : 79.49	Ft.(MSL)	Rule curve : 93.30	Ft.(MSL)		
Gas Consumed : PDB	403.17	MMCFt.	Oil Consumed : PDB	SKO :	56160 Liter
WMPL	20.84	MMCFt.		HSD :	243857 Liter
RPCL	34.18	MMCFt.		FO :	525706 Liter
NEPC	12.61	MMCFt.			
CDC (H+M)	62.61	MMCFt.			
Total	533.41	MMCFt.			

Cost of the Consumed Fuel (PDB) : Gas : Tk29,798,459 Oil : Tk13,911,451 Total : Tk43,709,910

Load Shedding & Other Information

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end) MW	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
	from 17:45	to 0:55			
DESA	241		1408	95	7%
Chittagong Area	123		436	176	40%
Khulna Area	81		361	145	40%
Rajshahi Area	75		307	124	40%
Comilla Area	70		282	114	40%
Mymensing Area	64		167	67	40%
Sylhet Area	61		163	66	40%
Barisal Area	17		75	30	40%
Rangpur Area	23		145	59	41%
Total	755	(20:00)	3344	876	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Sahjibazar GT-5(09/03/05)	1) Haripur SBU GT -1 (19/05/05)
2) Sahjibazar GT-6(16/11/04)	2) Haripur SBU GT-3 (25/05/05)
3) Ashuganj -5 (25/12/05),	3) Haripur SBU GT-2 (06/03/06).
	4) Sikalbaha BMPP-1(15/12/01)
	5) Ghorasal -1,2 (30/11/06),(16/01/07)
	6) Sahjibazar GT-8(29/07/06)
	7) Sahjibazar GT-9(09/02/06)
	8) Khulna 60 MW (05/07/06)
	9) Bheramara GT-2 -(29/07/06)
	10) Kaptai -5 (30/07/06)
	11) Shahjibazar GT4 -05/10/06
	12) Sikalbaha Steam(27/11/06)
	13) Baghabari-71MW(26/02/2006)
	14) Raozan unit -2 (18/02/07)
	15) CDC (H) GT & ST (02/02/07)
	16) Siddhirganj 210MW (06/02/07)
	17) Tongi GT (27/01/07)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 755 MW (20:00) of load shed was imposed over the whole area of National grid .
b) Ashuganj unit - 3 was forced shut down at 09:03 due to generator abnormal sound. It may be synchronized before evening peak hour today.	
c) Tongi - Aminbazar 230 KV ckt. -2 was under shut down from 09:56 to 17:05 for annual maintenance.	
d) Hathazari - Feni 132 KV line -2 was under shut down from 10:24 to 17:17 due to replacement of disc insulator.	
e) Bottail 132/33 KV T1 and T2 transformers were under shut down from 10:58 to 15:00 and 15:00 to 17:40 due to protection test.	
f) Siddhirganj 132/33 KV T2 transformer tripped at 15:50 due to 33 KV Khanpur -2 feeder fault showing 'Over current relay' and was switched on at 16:15.	So about 12 MW of partial power interruption occurred under Siddhirganj S/S areas from 15:50 to 16:15.
g) After installation of optical fiber, Noapara - Jessore 132 KV line -1 was switched on at 15:32.	Due to generation shortage, About 250 MW of load shed has been running since morning (27/02/07) over the whole areas of the national grid.

Deputy Manager
Load Despatch DivisionManager
Load Despatch DivisionDeputy General Manager
Load Despatch Circle