

CENTRAL LOAD DESPATCH CENTER

MIS=302
Page -1

DAILY REPORT

Till now the maximum generation is :- 3782.1 MW at 20:00 on 30-Oct-05 Reporting Date : 5-Mar-07

The Summary of Yesterday's (4-Mar-07)		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	2523.0	MW	Hour : 11:00	Min Gen. at 4:00	2320 MW
Evening Peak Generation :	2718.0	MW	Hour : 20:00	Max Generation :	2782 MW
E.P. Demand (at gen end) :	3800.0	MW	Hour : 20:00	Max Demand :	3800 MW
Maximum Generation :	2722.5	MW	Hour : 22:00	Shortage :	1018 MW
Total Gen. (MKWH) :	58.10	System L/ Factor :	88.92%	Load Shed :	896 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :- Maximum 114 MW at 6:00 Energy 1336500 KWHR.
 Import from Ishurdi to Ghorasal:- Maximum - MW at - Energy - KWHR.

Actual : 78.64		Water Level of Kaptai Lake at 6:00 A M of 5-Mar-07		Rule curve : 92.36		Ft.(MSL)	
Gas Consumed : PDB	346.59	MMCF		Oil Consumed : PDB			
WMPL	22.32	MMCF		SKO	57642	Liter	
RPCL	29.43	MMCF		HSD	215927	Liter	
NEPC	17.10	MMCF		FO	515226	Liter	
CDC (H+M)	63.93	MMCF					
Total	479.36	MMCF					
Cost of the Consumed Fuel (PDB) : Gas		Tk25,616,350		Oil		Tk13,116,554	
				Total		Tk38,732,903	

Load Shedding & Other Information

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from 17:45	to 0:18			
DESA	324		1408	95	7%
Chittagong Area	160		436	180	41%
Khulna Area	110		361	149	41%
Rajshahi Area	118		307	129	42%
Comilla Area	93		282	116	41%
Mymensing Area	56		167	69	41%
Sylhet Area	50		163	67	41%
Barisal Area	12		75	31	41%
Rangpur Area	29		145	60	41%
Total	952	(20:00)	3344	896	

Information of the Generating machines under maintenance

Planned Shut-Down	Forced Shut-Down
1) Sahjibazar GT-5 (09/03/05)	1) Haripur SBU GT -1 (19/05/05)
2) Sahjibazar GT-6 (16/11/04)	2) Haripur SBU GT-3 (25/05/05)
3) Ashuganj -5 (25/12/05),	3) Haripur SBU GT-2 (06/03/06)
	4) Sikalbaha BMPP-1(15/12/01)
	5) Ghorasal -1 (30/11/06)
	6) Sahjibazar GT-8(29/07/06)
	7) Sahjibazar GT-9(09/02/06)
	8) Khulna 60 MW (05/07/06)
	9) Bheramara GT-2 -(29/07/06)
	10) Kaptai -5 (30/07/06)
	11) Shahjibazar GT4 -05/10/06
	12) Sikalbaha Steam(27/11/06)
	13) Baghabari-71MW(26/02/2006)
	14) Raozan unit -2 (18/02/07)
	15) CDC (H) GT & ST (02/02/07)
	16) Siddhirganj 210MW (06/02/07)
	17) Siddhirganj 50MW (04/03/07)
	18) Tongi GT (27/01/07)
	19) Ashuganj CCPP GT-1&ST-02/03/07

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 952 MW (20:00) of load shed was imposed over the whole area of National grid .
b) After maintenance Ashuganj unit-2 was synchronized at 15:55. Again it tripped at 17:10 due to super heater problem and was synchronized at 20:30.	
c) Siddhirganj 50 MW tripped at 20:05 due to feed pump problem. It is now under maintenance.	
d) Hathajari - Comilla (N) 230 KV ckt-2 was shut down from 09:40 to 16:23 due to annual maintenance.	
e) Hasnanabad 132/33 KV T2 & T5 transformers tripped at 12:40 due to 33/4 KV station transformer fault and were switched on at 13:02 after isolating the station transformer.	So about 48 MW power interruption has been occurred from 12:40 to 13:02 in the respective areas.
f) After installation of optical fiber , Jessore - Jhenidaha 132 KV line -1 was switched on at 16:08. Again it is under shut down since 06:19 (05/03/07) due to the same reason.	
	Due to generation shortage , about 300MW of load shed has been running since morning (05/03/07) over the whole area of national grid.

Deputy Manager
Load Despatch DivisionManager
Load Despatch DivisionDeputy General Manager
Load Despatch Circle