

Description of the generation of various Power Stations

Date : 4-Mar-07

MIS = 302, Page -2

Name of Power Station	Machine	Present Generation Capacity	Peak Hour Generation	Energy Generated	Remarks
		MW	MW	KWHr	
Karnafuli Hydro Power Station	1	46	35		
	2	46	0	533000	Water level low.
	3	50	0		Water level low
	4	50	40	241000	
	5	50	0		Under maint. since 30/07/06
Shikalbaha Power station	Steam	42	0	0	Under maint.since 27/11/06, O/H
	barge	10	0	0	
Raozan Power Station	1	180	150	3500000	Gas pressure low
	2	210	0	0	Gas pressure low(18/02/07)
Ashugonj Power Station	1	64	64	1943238	
	2	64	0		synchronized at 20:30
	3	150	150	3568846	
	4	130	135	3225770	
	5	80	0	0	Under maint. since 25/12/05
" CCPP	GT-1	40	0	689500	Under maint. since 02/03/06
	GT-2	40	30		Over speed prob.
	ST.	20	0	0	Under maint. since 02/03/06
Ghorasal Power Station	1	40	0	644000	Under maint.since 30/05/06, O/H
	2	40	30		
	3	190	0	0	Under maint.since (02/03/07)
	4	200	180	4150509	
	5	200	190	4158000	
	6	200	190	3613050	
Tongi Power Station	1	80	0	0	Under maint. since 27/01/07.
Siddhirgonj Power Station	50MW	30	30	592000	
	210MW	210	0	0	Under maint. since 06/02/07
Meghnaghat Power Ltd	CCPP (3)	450	461	9960000	
Haripur SBU	GT-1	30	0		Under maint. since 19/05/05
	GT-2	31	0	0	Under maint. since 06/03/06
	GT-3	32	0		Under maint. since 25/05/05
NEPC, Haripur	8*15.5	80	82	2035600	Unit 3 is under maintenance
Haripur Power Ltd	GT	235	0	0	Under maint. since 02/02/07
	Steam	125	0	0	Under maint. since 02/02/07
Sahjibazar Power Station	2	10	8		
	4	10	0	189000	Under maint. since 05/10/06
	8	35	0	0	Under maint. since 29/07/06
	9	35	0		Under maint. since 09/02/06
Fenchugonj Comb. Cycle	GT-1	30	30		
	GT-2	30	30	1383000	
	Steam	30	27	638000	
(3)					
Sylhet Power Station (1)	GT	20	20	482000	
R P C L , Mymensingh	1 - 4	140	143	2354000	gas pressure low on 26/02/07
Eastern Grid Total		3819	2025.0	43900513	
Khulna Power Station	110MW	90	81	1776643	Boiler problem.(21/02/07)
	60MW	50	0	0	Under maint. since 05/07/06 O/H
	Barge 1	14	14		
	Barge 2	18	15	147800	
Khulna Power Co Ltd.	KPCL	90	90	2143800	
Barisal Power Station	GT-1	20	15	243527	
	GT-2	20	16.5		
Bheramara Power Station	GT-1	20	18		
	GT-2	20	0		Under maint. since 29/07/06 O/H
	GT-3	20	0	117800	Under maint. since 28/02/07
Bagabari Power Station	71 MW	71	0	0	Under maint. since 17/11/05 O/H
	100 MW	100	97	2184000	
West Mont (WMPL) pvt.	GT 1 & 2	88	89	1859630	
Barapukuria power station	ST 1 & 2	200	233	5600291	
Rangpur Power Station	GT	20	0	0	
Saidpur Power Station	GT	20	20.0	99000	
Combined Diesel		8	4.5	29647	
Western Grid Total		869	693	14202138	
National Grid Total		4688	2718.0	58102651	