MIS=302 Page -1

DAILY REPORT

Reporting Date : 22-Mar-07 3782.1 MW Till now the maximum generation is on 30-Oct-05 The Summary of Yesterday's (
Day Peak Generation:) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand 21-Mar-07 3130.3 MW 12:00 Min Gen. at 2994 MW 5:00 Hour Evening Peak Generation 3588.0 MW 20:00 Max Generation 3629 MW Hour E.P. Demand (at gen end) : 4050.0 MW Hour 20:00 Max Demand 4000 MW Maximum Generation 3588.0 MW Hour 20:00 Shortage 371 MW Total Gen. (MKWH) 73.05 System L/ Factor 84.83% Load Shed 326 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 336 MW at 1:00 7557000 KWHR. Export from Ghorasal to Ishurdi :- Maximum Energy Import from Ishurdi to Ghorasal:- Maximum MW at Energy KWHR. Water Level of Kaptai Lake at 6:00 A M of 22-Mar-07 76.95 Ft.(MSL) 89.64 Ft.(MSL) Actual Rule curve Gas Consumed : MMCEt : PDB 464 11 Oil Consumed WMPL 21.39 MMCFt. SKO PDB 15873 Liter MMCFt. HSD **RPCL** 25.16 421430 Liter NEPC 11.71 MMCFt. FO 103045 Liter CDC (H+M) 118.97 MMCFt. Total 641.34 MMCFt.

Load Shedding & Other Information

Area	Yesterday			Today		
	Actual Shed	lding (s	/s end), MW	Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	from 18:00	to	1:30	MW	MW	(On Estimated Demand)
DESA	90			1478	157	11%
Chittagong Area	80			453	38	8%
Khulna Area	95			378	31	8%
Rajshahi Area	50			340	27	8%
Comilla Area	32			289	24	8%
Mymensing Area	6			180	15	8%
Sylhet Area	22			167	14	8%
Barisal Area	26			81	7	9%
Rangpur Area	5			154	13	8%
Total	406	(20:00) 3520	326	

Tk34,302,519

Oil

Information of the Generating machines under maintenance

Planned Shut- Down	F	orced Shut- Down	
1) Sahjibazar GT-5(09/03/05)	1) Haripur SBU GT -1 (19/05/05)	8) Khulna 60 MW (05/07/06)	15) Ashuganj CCPP St-02/03/07
2) Sahjibazar GT-6(16/11/04)	2) Haripur SBU GT-3 (25/05/05)	9) Bheramara GT-2 -(29/07/06)	16) Ashuganj -1(13/03/07)
3) Ashuganj -5 (25/12/05),	3) Haripur SBU GT-2 (06/03/06).	10) Kaptai -5 (30/07/06)	17) Siddhirganj 50 MW (19/03/07)
	4) Sikalbaha BMPP-1(15/12/01)	11) Shahjibazar GT4 -05/10/06	18) Barisal GT-2 (20/03/07)
	5) Ghorasal -1 (30/11/06)	12) Sikalbaha Steam(27/11/06)	
	6) Sahjibazar GT-8(29/07/06	13) Baghabari-71MW(26/02/2006)	
	7) Sahiibazar GT-9(09/02/06)	14) Tongi GT (22/03/07)	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

a) There was generation shortage in the evening peak hour yesterday

- b) Ashuganj GT-1 tripped at 09:04 due to 'governor system failure' and was synchronized at 09:33.
- c) After maintenance, Khulna 110MW was synchronized at 17:45.

Cost of the Consumed Fuel (PDB) :

- d) After maintenance Tongi 80MW was synchronized at 18:26. and tripped at 04:30 (22/03/07) due to filter problem.
- e) Ashugonj GT-2 breaker opened at 19:08 due to under frequency and was synchronized
- f) Feni -Hathazari 230 KV ckt 1&2 were opened at 23:18 due to overload of Transformers.

Forced load shaded / Interrupted Areas
So about 406 MW (20:00) of load shed was imposed over the whole area

Tk12,307,386

Total

Tk46,609,904

of National grid

Due to low voltage, about 20MW of load shed has been running since morning (21/03/07) over Dhaka areas.

Deputy Manager Load Despatch Division

Load Despatch Division

Deputy General Manager Load Despatch Circle