

CENTRAL LOAD DESPATCH CENTER

DAILY REPORT

Reporting Date : 22-Apr-07
30-Oct-05

Till now the maximum generation is : -	MW at	3782.1	20:00	
The Summary of Yesterday's (21-Apr-07) Generation & Demand				
Day Peak Generation :	3234.0	MW	Ho	9:00
Evening Peak Generation :	3717.8	MW	Ho	20:00
E.P. Demand (at gen end) :	4300.0	MW	Ho	20:00
Maximum Generation :	3717.8	MW	Ho	20:00
Total Gen. (MKWH) :	75.61	System L/ Factor	84.74%	
Today's Actual Min Gen. & Probable Gen. & Demand				
Min Gen. at	7:00			2737
Max Generation :				3794
Max Demand :				4400
Shortage :				606
Load Shed :				533

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :- Maximum	354 MW	at	24:00	Energy	7276500
Import from Ishurdi to Ghorasal:- Maximum	- MW	at	-	Energy	-

Water Level of Kaptai Lake at 6:022-Apr-07

Actual :	74.16	Ft.(MSL) ,	Rule curve :	83.80	Ft.(MSL)
Gas Consumer: PDB	483.31	MMCFt.	Oil Consumed :		
WMPL	21.23	MMCFt.	PDB	SKO :	54483
RPCL	27.65	MMCFt.		HSD :	396061
NEPC	14.77	MMCFt.		FO :	353672
CDC (H+M)	112.66	MMCFt.			
Total	659.63	MMCFt.			
Cost of the Consumed Fuel (PDB) : Gas :		Tk35,721,722	Oil :	Tk15,656,611	Total : Tk51,378,332

Load Shedding & Other Information

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Sheddii (On Estimated De
from	to	18:15 6:38	MW	MW	
DESA		100	1606	269	17%
Chittagong Are		70	502	58	12%
Khulna Area		90	422	49	12%
Rajshahi Area		78	396	47	12%
Comilla Area		85	304	35	12%
Mymensing Area		20	211	25	12%
Sylhet Area		25	167	19	11%
Barisal Area		20	79	9	11%
Rangpur Area		25	185	22	12%
(
Total		513 20:00	3872	533	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Sahjibazar GT-5(09/03/05)	1) Haripur SBU GT -1 (19/05/05) 8) Khulna 60 MW (05/07/06)
2) Sahjibazar GT-6(16/11/04)	2) Haripur SBU GT-3 (25/05/05) 9) Bheramara GT-3 -(27/02/07)
3) Ashuganj -5 (25/12/05),	3) Haripur SBU GT-2 (06/03/06). 10) Kaptai -5 (30/07/06)
	4) Sikalbaha BMPP-1(15/12/01) 11) Sikalbaha Steam (27/11/06)
	5) Ghorasal -1 (23/03/07) 12) Baghabari-71MW(26/02/2006)
	6) Sahjibazar GT-8(29/07/06) 13) Barisal GT-2 (20/03/07)
	7) Sahjibazar GT-9(09/02/06) 14) Siddhirgonj -50 MW(18/04/07)

Additional Information of Machines, lines, Interruption / Forced Load shed etc

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 513 MW (20:00) of load shed was imposed over the whole of the national grid.
b) Ashuganj unit -4 tripped at 09:04 due to live steam differential flow problem. and was synchronized at 12:55.	
c) NEPC tripped at 15:27 due to earth fault. And was synchronized at 15:37.	
d) Aminbazar 230/132KV transformer T-2 shut down from 10:27 to 13:16 due to PT oil leakage.	
e) Barapukuria 230/132KV transformer T-2 tripped at 02:42 due to earth fault. And was switched on at 02:57.	
f) Saidpur - Barapukuria 132 KV ckt-1 tripped at 02:41 showing 'distance' on B-phase and was switched on at 02:58.	
g) After installation of optical fiber, 132 KV Natore - Ishurdi line -1 was switched on at 15:35. But again it is under shut down since 06:15 (22/04/07) due to the same reason.	Due to low voltage , about 87MW of load shed has been running since morning (22/04/07) over Khulna, Barisal and DESA areas of the nation
Deputy Manager Load Despatch Division	Manager Load Despatch Division
	Deputy General Manager Load Despatch Circle

MW
MW
MW
MW
MW

KWHR.
KWHR.

Liter
Liter
Liter

ng
mand)

e area

ce
onal grid.