

				Reporting Date : 11-May-07	
Till now the maximum generation is : -	MW at	3782.1	20:00	30-Oct-05	
The Summary of Yesterday's (10-May-07) Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	3160.0	MW	Ho 12:00	Min Gen. at 7:00	2794 MW
Evening Peak Generation :	3491.5	MW	Ho 20:00	Max Generation :	3481 MW
E.P. Demand (at gen end) :	4500.0	MW	Ho 20:00	Max Demand :	4200 MW
Maximum Generation :	3491.5	MW	Ho 20:00	Shortage :	719 MW
Total Gen. (MKWH) :	74.89	System L/ Factor	89.37%	Load Shed :	633 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :- Maximum	312 MW	at 22:00	Energy	6699000 KWHR.
Import from Ishurdi to Ghorasal:- Maximum	- MW	at -	Energy	- KWHR.

Water Level of Kaptai Lake at 6:0 11-May-07

Actual :	73.16	Ft.(MSL) ,	Rule curve :	80.10	Ft.(MSL)
Gas Consumer: PDB	499.43	MMCFt.	Oil Consumed :		
WMPL	11.02	MMCFt.	PDB	SKO :	49803 Liter
RPCL	25.94	MMCFt.		HSD :	259301 Liter
NEPC	15.94	MMCFt.		FO :	0 Liter
CDC (H+M)	117.92	MMCFt.			
Total	670.26	MMCFt.			
Cost of the Consumed Fuel (PDB) : Gas :		Tk36,912,680	Oil :	Tk7,831,886	Total : Tk44,744,566

Load Shedding & Other Information

Area from	Yesterday Actual Shedding (s/s end), MW		Today Estimated Demand(s/s end)		Rates of Shedding (On Estimated Demand)
	18:30	till now	MW	MW	
DESA	220		1531	203	13%
Chittagong Area	145		480	95	20%
Khulna Area	178		405	80	20%
Rajshahi Area	99		379	76	20%
Comilla Area	94		286	57	20%
Mymensing Area	38		202	40	20%
Sylhet Area	31		158	31	20%
Barisal Area	31		79	16	20%
Rangpur Area	51		176	35	20%
Total	887	20:00	3696	633	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Sahjibazar GT-5(09/03/05)	1) Haripur SBU GT -1 (19/05/05)
2) Sahjibazar GT-6(16/11/04)	2) Haripur SBU GT-3 (25/05/05)
3) Ashuganj -5 (25/12/05),	3) Haripur SBU GT-2 (06/03/06).
	4) Sikalbaha BMPP-1(15/12/01)
	5) Ghorasal -1 (23/03/07)
	6) Sahjibazar GT-8(29/07/06)
	7) Sahjibazar GT-9(09/02/06)
	8) Khulna 60 MW (05/07/06)
	9) Bheramara GT-3 -(27/02/07)
	10) Kaptai -5 (30/07/06)
	11) Sikalbaha Steam (27/11/06)
	12) Baghabari-71MW(26/02/2006)
	13) Barisal GT-2 (20/03/07)
	14) Siddhirgonj -50 MW(25/04/07)
	15) Khulna 110 MW (25/04/07)
	16) Westmont-2 (10/05/07)
	17) Ashuagnj st-1 (11/05/07)

Additional Information of Machines, lines, Interruption / Forced Load shed etc

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 887 MW (20:00) of load shed was imposed over the whole areas of the national grid.
b) Fenchugonj GT-2 was shut down at 13:16 due to second boiler running and synchronized at 15:00 .	
c) After maintenance Ashuganj CCPP steam was synchronized at 15:10 .	
d) Ashuganj unit -1 was shut down at 00:35 due to CW pump problem.	
e) Srimongal 132/33 KV T2 transformer was shut down 07:05 due to oil filtering.	
f) Halishohar - Sikalbaha 132 KV line was shut down at 08:20 due to dad line choking	
	Due to low voltage and generation shortage , about 50 MW of load shed has been running since morning (11/05/07) over Khulna areas of the National grid.
Deputy Manager Load Despatch Division	Manager Load Despatch Division
	Deputy General Manager Load Despatch Circle