DAILY REPORT

				ALL INELO	<u> </u>				. ago .
							Reporting Date:	30-Jun-07	
Till now the maximum generation	ı is : -	3782.1 MW	at	20:	00	on	30-Oct-05		
The Summary of Yesterday's (29-Jun-07) Generation	& Demand			Today's Actual Mi	n Gen. & Probable Ge	n. & Demand	
Day Peak Generation :	2900.0	MW I	Hour :	10:	00	Min Gen. at	7:00	2635.1	MW
Evening Peak Generation :	3489.5	MW I	Hour :	20:	00	Max Generation	:	3397	MW
E.P. Demand (at gen end):	4200.0	MW H	Hour :	20:	00	Max Demand	:	4300	MW
Maximum Generation :	3508.0	MW H	Hour :	21:	00	Shortage	:	904	MW
Total Gen. (MKWH) :	71.17	System L/ Factor	or :	84.5	4%	Load Shed	:	761	MW
	EXPORT / II	MPORT THROUG	H EAST-WE	ST INTERCONN	IECTO	R			
Export from Ghorasal to Ishurdi :- 1	Maximum			354 MW	at	1:00	Energy	7474500	KWHR.
Import from Ishurdi to Ghorasal:- M	laximum	-		MW	at	-	Energy	-	KWHR.
	Water Level of Kapt	ai Lake at 6:00	A M of	30-Jun	-07	•			
Actual: 90.90	Ft.(MSL),		Rule	curve :	83.73	Ft.(MSL)			
O O	100.10	MACE		0.1.0		1			

Import from Ishurdi to Ghorasal:- Maxir	mum	-	MW	/ at -		Energy	-	KWHR.
Wa	ter Level of Kap	tai Lake at 6:00 /	A M of 30-	Jun-07				
Actual: 90.90 Ft.	(MSL),		Rule curve :	83.73 Ft	t.(MSL)			
Gas Consumed : : PDB	438.13	MMCFt.	Oil	Consumed:				
WMPL	20.57	MMCFt.		PDB	SKO	:	56823	Liter
RPCL	52.59	MMCFt.			HSD	:	190853	Liter
NEPC	8.61	MMCFt.			FO	:	0	Liter
CDC (H+M)	116.66	MMCFt.						
Total	636.55	MMCFt.						
Cost of the Consumed Fuel (PDB): G	as :		Tk32,381,905	Oil :	Tk6,278,343	Total :	Tk38,660,24	18

Load Shedding & Other Information

Area	Yesterday		Today			
	Actual Shedding (s/s end), M\	V Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding		
	from 18:30 to till now	MW	MW	(On Estimated Demand)		
Dhaka	74	1485	156	11%		
Chittagong Area	70	485	137	28%		
Khulna Area	132	395	112	28%		
Rajshahi Area	99	345	98	28%		
Comilla Area	69	295	84	28%		
Mymensing Area	11	195	55	28%		
Sylhet Area	37	170	48	28%		
Barisal Area	30	75	21	28%		
Rangpur Area	78	175	50	29%		
Total	598 (20:00) 3620	761			

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down		
1) Ashuganj -5 (25/12/05),	1) Haripur SBU GT -1 (19/05/05)	9) Kaptai -5 (30/07/06)	17) Khulna 110 (28/06/07)
	2) Haripur SBU GT-3 (25/05/05)	10) Barpukuria -2 (09/06/07)	18) Ashuganj CCPP St (28/06/07)
	3) Sikalbaha BMPP-1(15/12/01)	11) Baghabari-71MW(26/02/2006)	19) Ghorasal unit -4 (30/06/07)
	4) Ghorasal -1 (23/03/07)	12) Barisal GT-1 (27/05/07)	
	5) Sahjibazar GT-8(29/07/06	13) Bheramara GT-2 (15/06/07)	
	6) Sahjibazar GT-9(09/02/06)	14) Raozan-1 (23/06/07)	
	7) Khulna 60 MW (05/07/06)	15) Fenchuganj GT-1 (24/06/07)	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 598 MW (20:00) of load shed was imposed over the whole
	area of the national grid.

- b) Ghorasal unit -4 was forced shut down at 00:06 (30/06/07) due to rotor Earth fault .It is
- now under maintenance. c) After maintenance, Kaptai unit - 5 was synchronized at 16:37(on test) and was shut down at 21:03.
- d) Rangpur GT (20 MW) tripped at 21:03 showing 'Lub oil temperature high'. It may be synchronized before evening peak hour today.
- e) Rampura 230 KV bus- II was under shut down from 10:26 to 26:23 due to project work.

Due to low voltage, about 60 MW of load shed has been running since morning (30/06/07) over Khulna, Barisal area of the national grid.

Deputy Manager Deputy General Manager Manager Load Despatch Division Load Despatch Division Load Despatch Circle