

QF-LDC-08  
Page -1

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 1017 MW (21:00) of load shed was imposed over the whole areas of the national grid .
b) Due to low gas pressure Baghabari 100 MW and RPCL (210 MW) were limited to 65 MW and 94 MW respectively.	
d) Ashuganj CCPP ST tripped at 13:40 due to reverse power and GT-2 tripped at 02:22(15/03/11) due to lube oil filter problem. ST unit was synchronized at 14:18.	
e) After maintenance Khulna-60 MW was synchronized at 17:12.	
f) Megnaghat power limited ST & GT1 was shut down at 22:08 & 22:15 due to schedule maint.respectively	
g) Madanganj RPP (100 MW) newly install was synchronized at 09:24.( On test)	
h) Rampura-Ullon 132kV line tripped at 17:05 at Ullon end showing dist.relay.	
i) Rampura 132kV bus-2 tripped at 17:06 on bus proection and was taken back in service at 17:58.	
j) Tongi-Bashundhara 132kV line-2 was shut down at 08:05(15/03/11) for cleaning nest at Bashundhara side and was kept charged from Tongi at 08:55(15/03/11) as before.	
	Due to generation shortage, about 662 MW (09:00) of load shed has been running since morning (15/03/11) over the whole area of the national grid.

Deputy / Asstt. Manager  
Network Operation Division

Manager  
Network Operation Division

Deputy General Manager  
Load Despatch Circle