

QF-LDC-08
Page -1

Hrs on 20-Aug-10

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Water Level of Kaptai Lake at 6:00 A M of

14-Mar-11

Actual : 83.32

Water Level of Kaptai Lake at 6:00 A M of

Rule curve :

90.92 Ft.(MSL)

Oil Consumed (PDB) :

FO : 0 Liter

Total : Tk81,281,286

Load Shedding & Other Information

Area	Yesterday		Today			
			Estimated Demand (s/s end)		Estimated Shedding (s/s end)	Rates of Shedding
	MW		from	to	MW	(On Estimated Demand)
Dhaka	371	(17:50-Till Now,Gen. shortage)		1930	425	22%
Chittagong Area	176	(17:50-Till Now,Gen. shortage)		550	148	27%
Khulna Area	143	(17:50-Till Now,Gen. shortage)		500	133	27%
Rajshahi Area	134	(17:50-Till Now,Gen. shortage)		413	111	27%
Comilla Area	96	(17:50-Till Now,Gen. shortage)		325	87	27%
Mymensing Area	75	(17:50-Till Now,Gen. shortage)		212	57	27%
Sylhet Area	21	(17:50-Till Now,Gen. shortage)		210	16	8%
Barisal Area	15	(17:50-Till Now,Gen. shortage)		97	26	27%
Rangpur Area	67	(17:50-Till Now,Gen. shortage)		232	63	27%
Total	1098	20:00		4469	1066	

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	9) Meghnaghat Power Ltd GT-2(15/02/11)	1) Ghorasal 6(18/07/10)
2) Ghorasal 2(26/04/10)		2) Ashuganj-1(09/11/10)
3) Siddirganj GT-1 (18/06/10)		Siddirganj-210 MW(11/03/11)
4) Ashuganj-4(12/09/10)		Khulna-60 MW & 110 MW (11/03/11)
5) Raozan-1 (03/10/10)		
6) Raozan-2 (21/10/10)		
7) Kaptai #5 (02/11/10)		
8) Kaptai #3 (1/12/10)		

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description		Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.		So about 1098 MW (20:00) of load shed was imposed over the whole areas of the national grid .
b) Due to low gas pressure Baghabari 100 MW and RPCL (210 MW) were limited to 55 MW and 92 MW respectively.		
c) Sylhet RPP (10 MW & 50 MW) tripped at 12:10 showing bus protection.		
d) Fenchuganj RPP (55 MW) tripped at 12:10 due to differential protection.		
e) After maintenance Ashuganj CCPP ST was synchronized at 09:33.		
f) Siddirganj(peaking) GT-2 tripped at 13:35 due to turbine vibration high and was sync.at 16:46.		
g) Ashuganj #5 tripped at 04:55(14/03/11) due to C.W pump problem.		
h) Siddirganj QRPP & RPP were shut down at 13:11 & 00:56(14/03/11) due to fuel shortage respectively		
i) Uttara-Mirpur 132kV line was under shut down from 08:26 to 17:50 due to annual maint.		
		Due to generation shortage, about 555 MW (09:00) of load shed has been running since morning (14/03/11) over the whole area of the national grid.

Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division	Deputy General Manager Load Despatch Circle
-------------------------------------------------------	---------------------------------------	------------------------------------------------