

QF-LDC-08
Page -1

Hrs on 20-Aug-10

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

29-Mar-1188.51 Ft.(MSL)

FO : 201705 Liter

Total : Tk98,310,728

Load Shedding & Other Information

Area	Yesterday		Today			
			Estimated Demand(s/s end)		Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	MW		from	t&MW		
Dhaka	215	(18:05-22:28, Gen. shortage)		1963	182	9%
Chittagong Area	76	(18:05-22:30, Gen. shortage)		560	80	14%
Khulna Area	18	(18:05-22:00, Gen. shortage)		510	73	14%
Rajshahi Area	32	(18:05-22:25, Gen. shortage)		419	60	14%
Comilla Area	-	0		330	47	14%
Mymensing Area	36	(18:05-22:26, Gen. shortage)		219	31	14%
Sylhet Area	23	(18:05-22:27, Gen. shortage)		225	-	-
Barisal Area	11	(18:05-22:00, Gen. shortage)		99	14	14%
Rangpur Area	34	(18:05-22:20, Gen. shortage)		233	33	14%
Total	445	21:00		4558	520	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10)
2) Ghorasal 2(26/04/10)	2) Ashuganj-1(09/11/10)
3) Siddirganj GT-1 (18/06/10)	3) Khulina-110 MW(17/03/11)
4) Ashuganj-4(12/09/10)	4)Ashuganj CCPP GT-1 & ST(19/03/11)
5) Raozan-1 (03/10/10)	5) Raozan-2 (26/03/11)
6) Kaptai #5 (02/11/10)	
7) Kaptai #3 (1/12/10)	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 445 MW (21:00) of load shed was imposed over the whole areas of the national grid .
b) Due to low gas pressure RPCL (210 MW) and HPL (350 MW) were limited to 108 MW & 271 MW respectively.	
c) Comilla-Hathazari 230kV line-2 was under shut down from 08:50 to 17:07 due to annual maint.	Power interruption occurred (about 10 MW) under Hasnabad S/S areas from 17:50 (26/03/11) to 21:15(28/03/11).
d) Kabirpur-Tongi 132kV line-2 was under shut down at Kabirpur end from 10:43 to 16:56 due to oil leakage of breaker.	
e) Bagerhat-Bhandaria 132kV line was under shut down from 10:16 to 15:57 at Bagerhat end due to R phase conductor armouring.	
f) Hasnabad-Shympur 132kV line was under shut down from 10:55 to 16:04 at Shympur end due to Lightning Arrestor replacement.	
g) Hasnabad-Meghnaghat 230kV line-1 & 2 was under shut down from 15:27 to 16:01, 16:30 to 18:44 respectively at both end due to teleprotection work.	
h) Shyampur-Haripur 132kV was under shut down from 16:30 to 18:44 at Shympur end due to Lightning Arrestor replacement.	
i) Hasnabad 132/33 kV T6 X-former was switched on at 21:15. (It was tripped on 26.3.2011 at 17:50). After replacement of 33kV bushing of 33 kV incoming ckt breaker.	
j) Sylhet 50 MW tripped at 01:15(29/3/11) showing bus bar alarm and was synchronized at 02:20(29/03/11).	
k) Sylhet-Chatak 132kV line-1 tripped at 01:15(29/03/11) showing dist, B phase relay and was switched on at 01:27(29/03/11).	

Deputy General Manager
Load Despatch Circle