POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTEF DAILY REPORT

QF-LDC-08

Page -1 Reporting Date : 5-Apr-11 Till now the maximum generation is:-4698.5 MW at on 20-Aug-10 The Summary of Yesterday's (4-Apr-11) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 4092.0 11:00 Hour : Min Gen. at Evening Peak Generation : 3951.0 MW Hour : 19:00 Max Generation 4488 MW E.P. Demand (at gen end): 3951.0 MW 4900 MW Hour : 19:00 Max Demand MW 412 MW Maximum Generation 4212.0 Hour : 15:00 Shortage Total Gen. (MKWH) 85.41% 87.84 System L/ Factor Load Shed 384 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MW Energy 7600000 KWHR. Import from West grid to East grid :- Maximum MW KWHR. Energy at Water Level of Kaptai Lake at 6:00 A M of 5-Apr-11 79.90 Ft.(MSL), 87.20 Ft.(MSL) Actual: Rule curve : Gas Consumed : MMCFt. Oil Consumed (PDB): HSD : 956238 Liter FO : 658113 Liter Cost of the Consumed Fuel: Gas Tk50,085,851 : Tk51,411,770 Total : Tk101,497,621

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	-	0	1963	120	6%
Chittagong Area	-	0	560	62	11%
Khulna Area	-	0	510	58	11%
Rajshahi Area	-	0	420	48	11%
Comilla Area	-	0	330	37	11%
Mymensing Area	-	0	218	22	10%
Sylhet Area	-	0	232	-	-
Barisal Area	-	0	99	11	11%
Rangpur Area	-	0	233	26	11%
Total	0		4565	384	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10)
2) Ghorasal 2(26/04/10)	2) Ashuganj-1(09/11/10)
3) Siddirganj GT-1 (18/06/10)	3) Raozan-2 (26/03/11)
4) Ashuganj-4(12/09/10)	
5) Raozan-1 (03/10/10)	
6) Kaptai #5 (02/11/10)	
7) Kaptai #3 (1/12/10)	

Additional Information of Machines, lines, Inter	ruption / Forced Load shed etc.	
Description		Forced load shaded / Interrupted Areas
 a) Sikalbaha ST was shut down at 08:28 due to condenser clear b) Shahjibazar-86 MW,B.Baria RPP and Shahjibazar RPP trippe and transformer differential relay abnormal and was sync.at 21: 	ed at 20:47 due to high frequency	
respectively. c) Baghabari-100 MW was forced shut down at 07:43 due to lub		
d) Mymensing-Jamalpur 132 kV ckt-2 was shut down at 10:36 di switched on at 11:36.		
 e) Bogra-Palashbari 132 kV ckt-1 & 2 tripped at 16:22 showing of (From Bogra end) broken down due to storm. f) B.Baria-Srimongal 132 kV Ckt tripped from both end at 20:47 switched on at 21:05. 		
g) Mymensing 132/33 kV T2 transformer tripped at 17:31 showir relay and was switched on at 22:12 and again tripped at 22:46	•	
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division	Deputy General Manager Load Despatch Circle