

QF-LDC-08  
Page -1

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 596 MW (21:00) of load shed was imposed over the whole areas of the national grid.
b) Due to low gas pressure RPCL(210 MW) was limited to 129 MW.	
c) After maint.Shahjibazar #5 was sync.at 13:10.	
d) Thakurgaon RPP tripped at 12:30 due to short ckt current and was sync.at 12:40.	
e) Baghabari WMPL #1 & 2 tripped at 16:53 & 17:51 due to voltage fluctuation & auxiliary failure respectively and #2 was sync.at 20:51 and again tripped at 21:16 due to turbine vibration high. #2 was sync.at 23:01.	
f) Haripur HPL ST was shut down at 02:02(07/04/11) due to turbine vibration monitoring purpose and was sync.at 08:24(07/04/11).	
g) Khulsi-A.Khayar 132 kV line-was shut down at 09:18 due to annual maintenance and was switched on at 16:44.	
h) Jessore-Noapara 132 kV Ckt-1 tripped at 12:59 from both end showing distance relay and was switched on.at 13:05.	
i) Kallayanpur 132/33 kV T1 transformer was shut down at 10:46 due to DC system testing & control cable and relay maint.and was switched on at 18:01.	Power interruption occurred (about 10 MW) under Kallayanpur S/S areas from 10:46 to 18:01.
j) Mymensing 132/33 kV T1 transformer tripped at 07:46(7/4/11) showing E/F and was switched on at 07:58(7/4/11)	
	Due to generation shortage, about 180 MW (09:00) of load shed has been running since morning (07/04/11) over the whole area (except Sylhet) of the national grid.

Deputy / Asstt. Manager  
Network Operation Division

Manager  
Network Operation Division

Deputy General Manager  
Load Despatch Circle