

QF-LDC-08  
Page -1

Description		Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.		So about 802 MW (21:00) of load shed was imposed over the whole areas of the national grid.
b) Due to low gas pressure RPCL(210 MW), HPL(360 MW) & Tongi(105 MW) were limited to 107 MW, 301 MW & 40 MW respectively.		
c) Baghabari WMPL #1 tripped at 09:26 due to high inlet manifold vacuum problem and was synchronized at 12:49.		
d) Bogra-Polashbari 132kV ckt-2 was under shut down from 11:33 to 14:30 due to emergency maintenance work.		
e) Mymensing-Jamalpur 132kV line-1 & 2 tripped at 14:39 from Mymensing end showing OC, dist Z2 & OC A phase respectively and were switched on at 15:35, 15:31 respectively.		Power interruption occurred (about 40 MW) under Jamalpur S/S areas from 14:39 to 15:31.
f) After maintenance Ghorasal #4 was synchronized at 16:02.		
g) Savar 132/33 kV T2 transformer tripped at 18:55 operating Buchholz relay.		
h) Joydevpur 132/33 kV T2 & T4 transformer's 33kV breaker were opened at 21:05 due to fire at REB 33 kV feeder and were switched on at 21:50.		Power interruption occurred (about 40 MW) under Joydevpur S/S areas from 21:05 to 21:50.
		Due to generation shortage, about 380 MW (09:00) of load shed has been running since morning (12/04/11) over the whole area (except Sylhet) of the national grid.

Deputy / Asstt. Manager	Manager	Deputy General Manager
Network Operation Division	Network Operation Division	Load Despatch Circle