

QF-LDC-08  
Page -1

Hrs on 20-Aug-10

### EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

21-Apr-1184.00 Ft.( MSL )FO : 407255 Liter

Oil (PDB) : Tk14,017,466      Total : Tk75,528,995

### Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand (s/s end) from MW	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
	MW				
Dhaka	286	(18:25-00:10)	2075	313	15%
Chittagong Area	100	(18:25-00:32)	580	105	18%
Khulna Area	90	(18:25-23:58)	528	96	18%
Rajshahi Area	74	(18:25-23:45)	435	80	18%
Comilla Area	59	(18:25-23:56)	342	62	18%
Mymensing Area	44	(18:25-22:10)	228	42	18%
Sylhet Area	41	(18:25-23:46)	240	17	7%
Barisal Area	18	(18:25-23:58)	102	18	18%
Rangpur Area	41	(18:25-23:42)	242	44	18%
<b>Total</b>	<b>753</b>	21:00	<b>4772</b>	<b>777</b>	

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut- Down	
1) Haripur SBU GT-3 (18/06/09)	8) Bheramara GT1(1/3/11)	1) Ghorasal 6(18/07/10)	
2) Ghorasal 2(26/04/10)		2) Ashuganj-1(09/11/10)	
3) Siddirganj GT-1 (18/06/10)		3) Raozan-2 (26/03/11)	
4) Ashuganj-4(12/09/10)		4) B.Pukuria #1(11/4/11)	
5) Raozan-1 (03/10/10)		5) Khulna 60 MW (18/4/11)	
6) Kaptai #5 (02/11/10)			
7) Kaptai #3 (1/12/10)			

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas	
a) There was generation shortage in the evening peak hour yesterday.	So about 753 MW (21:00) of load shed was imposed over the whole areas of the national grid.	
b) Due to gas pressure low HPL 360 MW & RPCL 210 MW were limited to 306 MW & 116 MW respectively.		
c) Dohazari-Cox's Bazar 132 kV Ckt-2 was shut down at 08:10 due to annual maintenance and is now under shut down due to breaker fault.		
d) Fenchuganj 132/33 kV T2 tripped at 09:05 showing E/F and was switched on at 09:35.		
e) Khulna Central 132/33 kV T1 was under shut down from 10:07 to 16:26 due to oil leakage maintenance.		
f) Natore-Rajshahi 132 kV Ckt-2 was under shut down from 09:45 to 10:40 due to red hot maint at Rajshahi end.		
g) Khulshi-Halishahar 132 kV Ckt-2 was under shut down from 09:15 to 16:27 due to annual maintenance.		
h) Ashuganj CCPP GT-1 & ST tripped at 10:14 due to control oil pressure failure and GT-1 & ST were synchronized at 12:40 & 16:09 respectively.		
i) After maintenance Shahjibazar #6 was synchronized at 13:20.		
j) Ashuganj CCPP ST unit again tripped at 16:31 due to unit breaker problem and was synchronized at 22:01.		
	Due to generation shortage, about 90 MW (09:00) of load shed has been running since morning (21/4/11) over the whole area (except Sylhet) of the national grid.	
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division	Deputy General Manager Load Despatch Circle