

QF-LDC-08
Page -1

Description		Forced load shaded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Due to low gas pressure Siddirganj 105 MW and RPCL 210 MW were limited to 95 and 139 MW respectively.</p> <p>c) After maintenance Sikalbaha-60 MW was synchronized at 16:40.</p> <p>d) Siddirganj-210 MW was forced shut down at 18:02 due to boiler hot box pressure abnormal.</p> <p>e) Rajshahi-Natore 132 kV ckt-2 was shut down at 10:20 due to red hot maintenance at Rajshahi end and was switched on at 11:10.</p> <p>f) Shahjibazar RPP(45 MW) tripped at 12:44 during maintenance work and was synchronized at 14:45.</p> <p>g) Khulna-Shatkhirra 132 kV ckt was shut down at 13:12 due to crack of R-phase insulator at tower no.130 and was switched on at 15:40.</p> <p>h) After red hot maintenance of 230 kV isolator Aminbazar 230/132 kV TR3 transformer was switched on at 17:51.</p> <p>i) After maintenance Comilla(N)-Chandpur 132 kV ckt was switched on at 18:35.</p> <p>j) After maintenance Comilla(S)-Chandpur 132 kV ckt was switched on at 18:37.</p>		<p>So about 722 MW (20:00) of load shed was imposed over the whole areas of the national grid .</p> <p>Power interruption occurred (about 20 MW) under Shatkhirra S/S areas from 13:12 to 15:40.</p>
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division	Deputy General Manager Load Despatch Circle