POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTEF DAILY REPORT

QF-LDC-08 Page -1

					DAILY	REPOR	<u>ا</u>				Page -
Till now the maxim	um apporation is : -		4698.5 MW	at		21:00			ting Date : 20-Aug-10	20-Sep-10	
The Summary of Ye	0	19-Sep-10) Generation			21.00		Today's Actual N		Probable Gen &	Demand
Day Peak Generation : 3856.0		,	Hour :		12:0	0	Min Gen. at	7:00	3301	MW	
Evening Peak Gener		4356.0		lour :		20:0		Max Generation		4180	MW
E.P. Demand (at ger		5200.0		lour :		20:0		Max Demand		5200	MW
Maximum Generatio	,	4356.0		lour :		20:0		Shortage		1020	MW
Total Gen. (MKWH)	:	93.00	System L/ Fact			85.41		Load Shed		910	MW
			IMPORT THR		-WEST INTE						
Export from East grid	d to West grid :- Max			520		MW		3:00	Energy	1143700	0 KWHR.
	d to East grid :- Max					MW	at	-	Energy	-	KWHR.
<u></u>	U	Vater Level of Kaptai Lake	at 6.00 A M (of		20-Sep-					
Actual :		Ft.(MSL),			Rule curv	•	3.37	Ft.(MSL)			
Cost of the Consume	ed Fuel (PDB) : Gas	s :	Tk55,462,06	4		Oil	:	Tk68,865,546	FO : Total :	0 Tk124,327,610	Liter
Area	L Yesterday	oad Shedding & Other In	formation					Today			
Alea	resteruay		Fstin	nated Demai	d(s/s and)			Estimated Shed	dina (s/s o	Rates of Shec	
	MW		from	to/W	ia(6/6 611a)				U (110100 01 01100	dina
Dhaka	368								VIW I	(On Estimated	0
		(18:10-00:58 gen_shortage)		2015					MW 367	(On Estimated 189	Demand)
Jnittadond Area		(18:10-00:58 gen. shortage) (18:10-00:45 gen. shortage)		2015 567					367	189	Demand) %
0 0	105	(18:10-00:45 gen. shortage)		567					367 125	189 229	Demand) % %
Khulna Area	105 60	(18:10-00:45 gen. shortage) (18:10-00:45 gen. shortage)		567 515					367	189 229 229	Demand) % %
Khulna Area Rajshahi Area	105 60 75	(18:10-00:45 gen. shortage) (18:10-00:45 gen. shortage) (18:10-00:30 gen. shortage)		567 515 424					367 125 112 93	189 229 229 229	Demand) % % %
Khulna Area Rajshahi Area Comilla Area	105 60 75 38	(18:10-00:45 gen. shortage) (18:10-00:45 gen. shortage) (18:10-00:30 gen. shortage) (18:10-00:30 gen. shortage)		567 515 424 335					367 125 112 93 74	18 22 22 22 22 22 22	Demand) % % % %
Khulna Area Rajshahi Area Comilla Area Mymensing Area	105 60 75 38 42	(18:10-00:45 gen. shortage) (18:10-00:45 gen. shortage) (18:10-00:30 gen. shortage) (18:10-00:30 gen. shortage) (18:10-00:30 gen. shortage)		567 515 424 335 220					367 125 112 93 74 48	18 22 22 22 22 22 22 22 22	Demand) % % % % %
Khulna Area Rajshahi Area Comilla Area Mymensing Area Sylhet Area	105 60 75 38 42 21	(18:10-00:45 gen. shortage) (18:10-00:45 gen. shortage) (18:10-00:30 gen. shortage) (18:10-00:30 gen. shortage) (18:10-00:30 gen. shortage) (18:10-00:05 gen. shortage)		567 515 424 335 220 230					367 125 112 93 74 48 20	18 22 22 22 22 22 22 22 9	Demand) % % % % % %
Chittagong Area Khulna Area Rajshahi Area Comilla Area Mymensing Area Sylhet Area Barisal Area Rangpur Area	105 60 75 38 42	(18:10-00:45 gen. shortage) (18:10-00:45 gen. shortage) (18:10-00:30 gen. shortage) (18:10-00:30 gen. shortage) (18:10-00:30 gen. shortage)		567 515 424 335 220					367 125 112 93 74 48	18 22 22 22 22 22 22 22 22	Demand) % % % % % %

20:00 Information of the Generating machines under shut down.

753

Total

Planned Shut- Down	Forced Shut- Down				
	1) Kaptai- 3 (19/04/08)	8) Ashuganj-4(12/09/10)			
	2) Khulna 110MW (31/03/09)				
	3) Haripur SBU GT-3 (18/06/09)				
	4) Ghorasal 2(26/04/10)				
	5) Siddirganj GT-1 (18/06/10)				
	6) Ghorasal 6(18/07/10)				
	7)Ghorasal-5(12/09/10)				

4640

910

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas		
) There was generation shortage in the ever	So about 743 MW (20:00) of load shed was imposed over the		
) Due to low gas pressure Raozan (360 MW 75 MW respectively.) and Tongi GT (105 MW) were limited to 330 MW,	whole areas of the national grid .	
) Fenchuganj GT #2 was shut down at 16:1 Ghorasal #3 shut down at 23:17 due to feer) Ashuganj - Comilla 230 KV line-1 & 2, Ash Ashuganj - Serajganj 230 KV line -2 tripped switched on at 17:11,08:37(20/09/10), 08:5	7 due to combine mode and was synchronized at 15:49. 5 due to combine mode and was synchronized at 17:05. d water line leakage.		
eputy / Asstt. Manager	Manager	Deputy General Manager	
letwork Operation Division	Network Operation Division	Load Despatch Circle	