POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-I DC-08 Page -1

: Tk135,006,854 Total : Tk192,329,802

Reporting Date : 10-Jan-12 Till now the maximum generation is : 5243.5 WWW at 22:00 Hrs on 29-Aug-11 The Summary of Yesterday's (9-Jan-12) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 3677.0 MW Hour : 9:00 Min. Gen. at 5:00 2508 MW Evening Peak Generation 4914.0 MW 5023 Hour 19:30 Max Generation MW E.P. Demand (at gen end) : 4914.0 MW 19:30 Max Demand 5000 MW Maximum Generation 4914.0 MW Hour 19:30 Shortage -23 MW Total Gen. (MKWH) 83.46 System I / Factor 85.41% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 560 MW at 19:00 MKWHR. Energy 10.638 Import from West grid to East grid :- Maximum MKWHR. MW Energy Water Level of Kaptai Lake at 6:00 A M on 10-Jan-12 95.01 Ft.(MSL) Rule curve : 101.29 Ft.(MSL) Actual Gas Consumed : 660.28 MMCFD. Oil Consumed (PDB): HSD FO Liter

Tk52 725 993

Tk4,596,955

Load Shedding & Other Information

Cost of the Consumed Fuel (PDB+Pvt) :

Area	Yesterday		Today		
"			Estimated Demand(s/s end)	Estimated Shedding (s/s e	n Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	-	0	1842	-	-
Chittagong Area	-	0	486	-	-
Khulna Area	-	0	547	-	-
Rajshahi Area	-	0	493	-	-
Comilla Area	-	0	362	-	-
Mymensing Area	-	0	268	-	-
Sylhet Area	-	0	266	-	-
Barisal Area	-	0	105	-	-
Rangpur Area	-	0	275	-	-
Total	0		4644	0	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10) 9) Sylhet-20MW(16/11//1)
2) Ghorasal 2(26/04/10)	2) Ashuganj-1(09/11/10) 10) Ashuganj-3(10/11/11)
3) Kaptai #3 (1/12/10)	3) Raozan-2 (26/03/11) 11) Khulna-110 MW(7/11/11)
	4) WMPL #2(1/8/11) 12) Sikalbaha 60 MW(16/11/11)
	5) Bhola RPP (18/7/11) 13) Khulna-60 MW(28/11/11)
	6) Siddhirganj ST 210 MW (1/8/11) 14) Raozan-1 (24/11/11)
	7) Sikalbaha GT 150MW (14/11/11) 15) B.Pukuria-1(5/1/12)
	8) Shahiibazar #5 & 6(21/7/11) 16) Ashuganj-2(9/1/12)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) RPCL #3 was shut down at 09:49 due to filter change and was synchronized at 11:23.	
b) Sylhet-50 MW tripped at 10:20 due to busbar alarm and was synchronized at 10:40.	
c) Shajibazar-86 MW, Shahjibazar RPP(50 MW), Shahjibazar #8 & 9 and Sylhet-50 MW	

- tripped at 14:30 due to tripping of Sreemongal-Shahjibazar 132 kV Ckt-2 and were synchronized at 15:15,15:10,15:22 & 15:00 respectively.
- d) Sreemongal-Shahjibazar 132 kV Ckt-2 tripped at 14:30 showing distance B & C, Zone-2 and was switched on at 14:58.
- e) Tongi GT tripped at 12:58 due to thermocouple problem and was switched on at 18:19. f) Comilla(N)-Hathazari 230 kV Ckt-1 was under shut down from 08:23 to 15:54 due to A/M.
- g) Ashuganj-Serajganj 230 kV Ckt-1 was under shut down from 08:42 to 18:35 due to A/M.
- h) Shyampur 132/33 kV T3 transformer tripped at 09:56 showing instantaneous O/C & E/F relays.
- i) Hathazari 132/33 kV T2 transformer tripped at 09:25 showing O/C & E/F relays and was switched on at 09:29.
- j) Hasnabad 132/33 kV T5 transformer tripped at 09:20 due to tripping of 33 kV feeder and was switched on at 10:25.

Deputy / Asstt. Manager Deputy General Manager **Network Operation Division** Network Operation Division **Load Despatch Circle**