POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08 Page -1

Reporting Date : on 22-Mar-12 16-Apr-12 6065.5 NWW at Till now the maximum generation is: 19:30:00 PM The Summary of Yesterday's (15-Apr-12) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 3923.0 MW Hour 12:00 Min. Gen. at 1:00 3435 MW MW Evening Peak Generation 4456.0 Hour : 19:00 Max Generation 4653 MW E.P. Demand (at gen end) 5000.0 MW Hour 19:00 Max Demand 5500 Maximum Generation 4456.0 MW Hour : 19:00 Shortage 847 MW Total Gen. (MKWH) 91.72 System L/ Factor 85.41% Load Shed 768 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR MW Export from East grid to West grid :- Maximum 860 at 5:00 Energy 18.126 MKWHR. Import from West grid to East grid :- Maximum MKWHR. MW at Energy Water Level of Kaptai Lake at 6:00 A M on 16-Apr-12 76.27 Ft.(MSL) Actual Ft.(MSL) Rule curve 85.00 Gas Consumed : Total 832.30 MMCFD. Oil Consumed (PDB): HSD : Liter FO: Liter Tk66,462,476 Cost of the Consumed Fuel (PDB+Pvt) : Gas Tk4,963,584

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	176	18:20-02:51	1990	325	16%
Chittagong Area	111	18:20-03:09	530	86	16%
Khulna Area	75	18:20-03:10	538	88	16%
Rajshahi Area	48	18:20-00:54	580	90	16%
Comilla Area	52	18:20-00:58	365	60	16%
Mymensing Area	-	0	310	38	12%
Sylhet Area	-	0	267	27	10%
Barisal Area	31	18:20-03:58	107	14	13%
Rangpur Area	-	0	300	40	13%
Total	493	19:00	4987	768	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut-Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10) 09) Khulna-110 MW(7/11/11)
2) Ghorasal 2(26/04/10)	2) Ashuganj-1(09/11/10) 10) Khulna-60 MW(24/1/12)
3) Kaptai #3 (1/12/10)	3) Raozan-1 (14/4/12)
	4) WMPL #2(1/8/11)
	5) Baghabari-71 MW(6/3/12)
	6) Siddhirganj ST 210 MW (1/8/11)
	7) Ashuganj CCPP ST(9/4/12)
	8) Shahjibazar #5 & 6(21/7/11)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
There was generation shortage in the evening peak hour yesterday.	So about 493 MW (19:00) of load shed was imposed over the
) Due to low gas pressure HPL 360 MW, Siddhirganj 210 MW, Tongi 150 MW were limited to	whole areas(except Sylhet, Mymensing & Rangpur) of the national grid .

- 346 MW, 132 MW and 90 MW respectively.
- c) Tongi-Kabirpur 132kV line-1 is under shut down since 10:50 due to breaker change at Kabirpur.
 d) Siddhirganj GT-1 was synchronized at 16:46.
- e) Bogra-Naogaon 132kV Ckt-1 & 2 tripped at 19:15 showing dist.Z1,E/F relay at Ckt-1 & dist.Z2 relay at Ckt-2 and was switched on at 19:32.
- f) Aminbazar-Mirpur 132kV Ckt-2 tripped at 19:55 from both end showing RST dist. Relay and was switched on at 20:42.
- g) Due to heavy rainfall & storm the following 132kV lines & machines were tripped at 19:20: Kishoreganj-Mymensing Ckt-1 & 2, Mymensing-Jamalpur Ckt-1 & 2, Mymensing-Jamalpur Ckt-1 & 2, Mymensing-RPCL Ckt-1 & 2 and RPCL GT-1,2,3.4. The lines were switched on at 01:05,01:03,01:12,01:13,01:15,01:16,22:28 respectively & Mymensing-RPCL Ckt-2 is under shut due to breaker damage at Mymensing end. RPCL GT-1,2 were synchronized at 01:22, 01:25(16/4/12) respectively.
- h) Rampura-Ullon Ckt-1 tripped at 20:17 from Rampura end showing dist.Z2 relay and was switched on at 20:28.
- i) Haripur-Shympur 132kV line tripped at 20:22 from both end showing dist.Z1, Z2 relay and was switched on at 20:48.
- j) Sitalakhya-Madanganj & Sitalakhya-Hasnabad 132kV line tripped at 20:21 from Sitalakhya end showing dist. & E/F relay and was switched on at 20:31.
- k) Siddhirganj-Maniknagar 132kV Ckt-1 tripped at 20:17 from both end showing dist. Z1 & E/F relay and was switched on at 20:55.
- Siddhirganj-Siddhirganj GT 132kV Ckt-1 & 2 tripped at 20:17. At the same time GT-1 & 2 also tripped and lines were switched on at 20:37 & machines were synchronized at 00:01,22:03(16/4/12) respectively. GT-1 was shut down at 08:26(16/4/12).
- m) Haripur AES 360MW was forced shut down at 22:24 due to servo valve maintenance and GT was synchronized at 03:01 & ST was synchronized at 04:36.

Power interruption occurred (about 68 MW) under Sitalakhya S/S areas from 20:21 to 20:31.

Due to generation shortage, about 132 MW (09:00) of load shed has been running since morning (16/04/12) over the whole area (except Sylhet, Mymensing & Rangpur) of the national grid.

Deputy / Asstt. Manager Network Operation Division

a) b)

> Manager Network Operation Division

Deputy General Manager Load Despatch Circle