

QF-LDC-08
Page -1

Reporting Date : 24-Apr-12

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

R.

R.

24-Apr-12

Ft.(MSL)

Oil Consumed (PDB) :

Lite

Lite

Total : Tk201,730,022

Information of the Generating machines under shut down.

- 1) Haripur SBU GT-3 (18/06/09)
- 2) Ghorasal 2(26/04/10)
- 3) Kaptai #3 (1/12/10)

1) Ghorasal 6(18/07/10)	09) Khulna-110 MW(7/11/11)
2) Ashuganj-1(09/11/10)	10) Ashuganj CCPP GT2(18/4/12)
3) Khulna-60 MW(24/11/12)	
4) W MPL #2(1/8/11)	
5) Baghabari-71 MW(6/3/12)	
6) Siddhirganj ST 210 MW (1/8/11)	
7) Ashuganj CCPP ST(9/4/12)	
8) Shahjibazar #5 & 6(21/7/11)	

Description		Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.		So about 692 MW (20:00) of load shed was imposed over the whole areas(except Sylhet) of the national grid .
b) Due to low gas pressure Siddhirganj 210 MW & Tongi 105 MW were limited to 102 MW 90 MW respectively.		
c) NEPC-Haripur SBU 132kV line is under shut down since 09:36 due to renovation work carried out by EGCB at Haripur end.		
d) New Meghnaghat-Daudkandi 132kV Ckt-1 tripped at 17:05 from Daudkandi end showing dist.Z1 O/C relays and was switched on at 15:32.		
e) Rajshahi-Chapainawabganj 132kV Ckt-1 tripped at 17:05 from both end showing dist.Z1 relay at Rajshahi end & dist.ABC, Z1 relay at Chapai end and was switched on at 17:30 .		
f) Natore 132/33kV T3 tripped at 21:30 showing O/C relay and was switched on at 21:48.		Power interruption occurred (about 9 MW) under Natore S/S areas from 21:30 to 21:48.
g) Baghabari 100MW was under forced shut down from 23:01 to 00:31(24/4/12) due to lube oil leakage.		
		Due to generation shortage, about 331 MW (09:00) of load shed has been running since morning (24/04/12) over the whole area (except Sylhet & Mymensingh) of the national grid.
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division	Deputy General Manager Load Despatch Circle

Deputy General Manager
Load Despatch Circle