

QF-LDC-08
Page -1

Reporting Date : 11-Sep-12
on 4-Aug-12

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

MKWHR.

11-Sep-12

Ft.(MSL)

Oil Consumed (PDB) :

Liter

Liter

Total : Tk411.696.943

Information of the Generating machines under shut down.

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description		Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.		So about 536 MW (20:00) of load shed was imposed over the whole(except Sylhet) areas of the national grid .
b) Mymensing-Netrokona 132 kV Ckt-1 was shut down at 09:18 due to protection work and was switched on at 17:58.		
c) Natore-Rajshahi 132 kV Ckt-1 was shut down at 10:15 due to bay shifting work and was switched on at 19:12.		Power interruption occurred (about 38 MW) under Bagerhat & Mongla S/S areas from 06:46 to 08:52(11/9/12).
d) Bagerhat-Mongla 132 kV Ckt was shut down at 10:04 due to red hot maintenance B-phase at Bagerhat end and was switched on at 11:07.		
e) Bogra 132/33 kV T2 transformer was shut down at 08:52 due to maintenance and was switched on at 13:17.		
f) After maintenance Shahjibazar-Ashuganj 132 kV Ckt-3 was switched on at 03:58(11/9/12).		
g) Goalpara-Bagerhat 132 kV Ckt was shut down at 06:46(11/9/12) due to red hot maintenance at Goalpara end and was switched on at 08:52(11/9/12).		Due to economic purpose, about 150 MW (09:00) of load shed imposed by distribution zones (11/09/12) over the whole area (except Sylhet) of the national grid.
h) Madaripur-Gopalganj 132 kV Ckt was shut down at 07:40(11/9/12) due to red hot maintenance Gopalganj end and was switched on at 08:55(11/9/12).		
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division	Deputy General Manager Load Despatch Circle