POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC.DHAKA DAILY REPORT

Oil Consumed (PDB):

QF-LDC-08 Page -1

Reporting Date: 6-Jul-10 Till now the maximum generation is: 4606.0 MW at 5-Jul-10 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 3829.0 MW 9:00 Min Gen. at 3719 MW Hour 7:00 Evening Peak Generation 3871.5 MW 21:00 Max Generation 3843 MW E.P. Demand (at gen end) : 0.0 MW Hour 21:00 Max Demand 5000 MW Maximum Generation 4109 0 MW Hour : 5:00 Shortage 1157 MW Total Gen. (MKWH) 87.50 System L/ Factor 85.41% Load Shed 995 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum MW 9227000 KWHR. Energy Import from West grid to East grid :- Maximum MW KWHR

Water Level of Kaptai Lake at 6:00 A M of 6-Jul-10

95.77 84.80 Ft.(MSL) Ft.(MSL) Rule curve

MMCFt.

HSD : 907545 Liter

FO 0 Liter

Cost of the Consumed Fuel (PDB): Gas Tk60,056,310 : Tk36,301,818 Total: Tk96,358,128

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Rates of Shedding
	MW		from tonW	MW	(On Estimated Demand)
Dhaka	406	(18:30-05:20, gen. shortage)	1866	415	22%
Chittagong Area	143	(18:30-05:10, gen. shortage)	530	129	24%
Khulna Area	109	(18:30-05:00, gen. shortage)	460	108	23%
Rajshahi Area	92	(18:30-05:15, gen. shortage)	385	93	24%
Comilla Area	88	(18:30-05:56, gen. shortage)	302	73	24%
Mymensing Area	62	(18:30-04:55, gen. shortage)	225	54	24%
Sylhet Area	-	0	230	49	21%
Barisal Area	21	(18:30-05:00, gen. shortage)	93	23	25%
Rangpur Area	49	(18:30-05:15, gen. shortage)	208	51	25%
Total	970	21:00	4299	995	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut-Down	
	1) Kaptai- 3 (19/04/08)	8) Siddhirganj GT-1 (16/06/10)
	2) Khulna 110MW (31/03/09)	9) Kaptai -1 (25/06/10)
	3) Haripur SBU GT-3 (18/06/09)	10) Ashuganj -3 (02/07/10)
	4) Ashuganj CCPP ST (05/12/09)	
	5) Raozan -1 (08/05/10)	
	6) Ghorasal 2(26/04/10)	
	7) Kaptai- 4 (17/01/10)	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Forced load shaded / Interrupted Areas So about 970 MW (21:00) of load shed was imposed over the a) There was generation shortage in the evening peak hour yesterday. whole (except Sylhet) areas of the national grid .

- b) Due to gas limitation, Siddhirganj GT -2 (120 MW), Raozan (180 MW), RPCL (210 MW), Baghabari GT2 (100 MW), MPL GT (450 MW) and HPL (250 MW) were limited to 40 MW, 100 MW, 88 MW,50 MW, 415 MW and 204 MW respectively.
- c) Tongi GT was shut down at 10:14 due to gas pressure low and was synchronized at 00:08 (06/07/10).
- d) Ashuganj CCPP St was shut down at 10:21 due to problem in cooling water pump.
- e) After maintenance, Ashuganj unit -3 was synchronized at 19:40.
- f) Ashuganj unit -2 was forced shut down at 01:57 (06/07/10) due to spray water valve problem.
- g) Manikganj 132/33 KV T3 & T2 transformers were under shut down from 10:05 to 14:10 and 14:55 to 18:06 respectively due to protection test.
- h) Rampura Gulshan 132 KV line -2 was under project work from 10:48 to 01:28.

Due to generation shortage, about 150 MW (09:00) of load shed has been running since morning (06/07/10) over the whole area (except Sylhet) of the national grid.

Deputy / Asstt. Manager Load Despatch Division

Actual

Gas Consumed:

Manager Load Despatch Division Deputy General Manager Load Despatch Circle