POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC.DHAKA DAILY REPORT

Oil Consumed (PDB):

QF-LDC-08 Page -1

Reporting Date: 17-Jul-10 Till now the maximum generation is: 4606.0 MW at 16-Jul-10 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 3532.0 MW 9:00 Min Gen. at ΜW Hour 7:00 3866 Evening Peak Generation 4001.0 MW 20:00 Max Generation MW 4015 E.P. Demand (at gen end) 4850.0 MW Hour 20:00 Max Demand 5000 MW Maximum Generation 4096.0 MW Hour 23:00 Shortage 985 MW Total Gen. (MKWH) 88.20 System L/ Factor 85.41% Load Shed 601 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum MW 3:00 10335000 KWHR. Energy Import from West grid to East grid :- Maximum N/N/ **KWHR** at

Water Level of Kaptai Lake at 6:00 A M of 17-Jul-10

96.84 86.56 Ft.(MSL) Actual Ft.(MSL) Rule curve MMCFt

> HSD 1606416 Liter

FO 0 Liter

Cost of the Consumed Fuel (PDB): Gas Tk54,955,041 : Tk64,256,646 Total : ##########

Load Shedding & Other Information

743.54

| Area | Yesterday | | Today | | |
|-----------------|-----------|---------------------------------|---------------------------|---------------------------|-----------------------|
| | | | Estimated Demand(s/s end) | Estimated Shedding (s/s e | Rates of Shedding |
| | MW | | from toMW | MW | (On Estimated Demand) |
| Dhaka | 317 | (18:45-Till now, gen. shortage) | 1795 | 257 | 14% |
| Chittagong Area | 115 | (18:45-Till now, gen. shortage) | 499 | 84 | 17% |
| Khulna Area | 86 | (18:45-Till now, gen. shortage) | 436 | 73 | 17% |
| Rajshahi Area | 80 | (18:45-Till now, gen. shortage) | 359 | 60 | 17% |
| Comilla Area | 43 | (18:45-Till now, gen. shortage) | 279 | 47 | 17% |
| Mymensing Area | 25 | (18:45-Till now, gen. shortage) | 198 | 34 | 17% |
| Sylhet Area | - | 0 | 227 | - | - |
| Barisal Area | 20 | (18:45-Till now, gen. shortage) | 84 | 14 | 17% |
| Rangpur Area | 38 | (18:45-Till now, gen. shortage) | 189 | 32 | 17% |
| Total | 724 | 20:00 | 4066 | 601 | |

Information of the Generating machines under shut down.

| 1) Kaptai- 3 (19/04/08) 6) Siddhirganj GT-1 (16/06/10) 2) Khulna 110MW (31/03/09) 7) Kaptai -1 (25/06/10) 3) Haripur SBU GT-3 (18/06/09) 8) Sikalbaha St (07/07/10) 4) Raozan -1 (14/07/10) 9) Ghorasal 5(12/07/10) 5) Ghorasal 2/26/04/10) 10) Siddhirganj 210 MW(12/07/10) | Planned Shut- Down | | Forced Shut- Down | | |
|--|--------------------|--------------------------------|-----------------------------------|--|--|
| 3) Haripur SBU GT-3 (18/06/09) 8) Sikalbaha St (07/07/10) 4) Raozan -1 (14/07/10) 9) Ghorasal 5(12/07/10) | | 1) Kaptai- 3 (19/04/08) | 6) Siddhirganj GT-1 (16/06/10) | | |
| 4) Raozan -1 (14/07/10) 9) Ghorasal 5(12/07/10) | | 2) Khulna 110MW (31/03/09) | 7) Kaptai -1 (25/06/10) | | |
| | | 3) Haripur SBU GT-3 (18/06/09) | 8) Sikalbaha St (07/07/10) | | |
| 5) Ghorasal 2/26/04/10) 10) Siddhirgani 210 MW(12/07/10) | | 4) Raozan -1 (14/07/10) | 9) Ghorasal 5(12/07/10) | | |
| | | 5) Ghorasal 2(26/04/10) | 10) Siddhirganj 210 MW(12/07/10) | | |
| | | | | | |
| | | | | | |

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

| Description | Forced load shaded / Interrupted Areas |
|--|---|
| a) There was generation shortage in the evening peak hour vesterday. | So about 724 MW (20:00) of load shed was imposed over the |

- b) Due to gas limitation, Raozan -2 (180 MW), RPCL (210 MW) and HPL (360 MW) were limited to 120 MW, 89 MW and 352 MW respectively.
- c) Sikalbaha 150 MW was synchronized (on test) at 09:40.
- d) Raozan -2 was forced shut down at 18:23 due to gas pressure low and was synchronized at
- e) After maintenance, Ghorashal unit -4 was synchronized at 19:10.
- f) Baghabari WMPL GT-1 was shut down at 00:43 (17/07/10) for maintenance for four days.
- g) Kallyanpur 132/33 KV T1,T2 & T3 transformers tripped at 09:13 showing O/C relays and were switched on at 09:55, 10:45 & 09:48 respectively
- h) Naogaon 132/33 KV T1 transformer was under shut down from 09:25 to 14:31 due to maintenance of 33 KV incoming isolator.
- i) Ashuganj 132/33 KV T4 transformer was shut down at 09:22 due to installation of new transformer. It is now under down.
- j) Dohazari 33 KV bus was under shut down from 10:05 to 11:40 due to maintenance work by Distribution Division.
- k) Kalyanpur 132/33 KV T1 transformer was shut down at 19:50 due to burst of B- phase bushing It is now under inspection and maintenance
- I) Halisahar 132/33 KV T2 transformer was under shut down from 21:15 to 22:26 due to red-hot maintenance of 132 KV CT.
- m) Mymensing 132/33 KV T3 transformer was under shut down from 22:05 to 00:40 (17/07/10) showing E/F & lockout' relay.
- n) Siddhirganj Ullon 132 KV line -2 and Haripur Maniknagar 132 KV line -1 are under shut down since 04:40 (17/07/10) and 05:18 (17/07/10) respectively due to project work.

Power Interruption about 129 MW occurred under Kalyanpur S/S

whole (except Sylhet) areas of the national grid .

Power Interruption about 20 MW occurred under Dohazari S/S areas from 10:05 to 11:40.

No interruption.

areas from 09:13 to 09:48.

Due to generation shortage, about 175 MW (09:00) of load shed has been running since morning (17/07/10) over the whole area (except Sylhet) of the national grid

Deputy / Asstt. Manager Load Despatch Division

Gas Consumed:

Manager Load Despatch Division Deputy General Manager Load Despatch Circle