

DAILY REPORT

Page -1

Till now the maximum generation is :-

6350 MWV at

21:00

Hrs

Reporting Date : 27-Apr-13
on 4-Aug-12

The Summary of Yesterday's (26-Apr-13)		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	5045.0	MW	Hour :	12:00	Min. Gen. at 8:00	4713	MW
Evening Peak Generation :	6304.0	MW	Hour :	20:00	Max Generation :	6466	MW
E.P. Demand (at gen end) :	6304.0	MW	Hour :	20:00	Max Demand :	6400	MW
Maximum Generation :	6304.0	MW	Hour :	20:00	Shortage :	-66	MW
Total Gen. (MKWH) :	126.78	System L/ Factor :		92.98%	Load Shed :	0	MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum	730	MW	at 7:00	Energy	15.516	MKWHR.
Import from West grid to East grid :- Maximum	-	MW	at -	Energy	-	MKWHR.

Water Level of Kaptai Lake at 6:00 A M on

27-Apr-13

Actual :	77.35	Ft.(MSL) ,	Rule curve :	92.80	Ft. (MSL)
----------	-------	------------	--------------	-------	-------------

Gas Consumed : Total	985.60	MMCFD.	Oil Consumed (PDB) :		
			HSD :		Liter
			FO :		Liter

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk78,704,093			
	Coal :	Tk8,870,859	Oil :	Tk356,867,241	Total : Tk444,442,192

Load Shedding & Other Information

Area	Yesterday		Today		
	MW		Estimated Demand(s/s end) from to/MW	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
Dhaka	-	0.00	2349	-	-
Chittagong Area	-	0.00	602	-	-
Khulna Area	-	0.00	657	-	-
Rajshahi Area	-	0.00	639	-	-
Comilla Area	-	0.00	440	-	-
Mymensing Area	-	0.00	364	-	-
Sylhet Area	-	0.00	297	-	-
Barisal Area	-	0.00	132	-	-
Rangpur Area	-	0.00	373	-	-
Total	0		5853	0	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09) 2) Ghorasal 2(26/04/10)	1) Ghorasal 6(18/07/10) 9) WMPL #2(24/4/13) 2) Ashuganj-#1(15/1/13) 10) Ghorasal 100 MW(25/04/13) 3) Khulna-60 MW(24/1/12) 4) Shahjibazar #5 & 6(21/7/11) 5) Khulna-110 MW(21/6/12) 6) WMPL #1(1/5/12) 7) B.Pukuria #1(19/4/13) 8) Raozan #2(21/4/13)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
<p>a) Bottail 132 kV Bas was under shut down from 09:45 to 10:17 due to maintenance of T1 transformer.</p> <p>b) Faridpur 132/33 kV T3 transformer was under shut down from 09:35 to 10:31 due to maintenance of oil leakage.</p> <p>c) Jamalpur 132/33 kV T2 transformer was under shut down from 11:28 to 14:15 due to maintenance of 33 kV incoming isolator.</p> <p>d) Ashuganj-Ghorasal 132 kV Ckt-2 tripped at 13:35 from both side showing dist. Z-A relay and was switched on at 14:17. At the same time Shahjibazar 50 MW & Ashuganj TSK tripped and were synchronized at 13:52, 15:34.</p> <p>e) Bottail-Jhenidah 132 kV Ckt-1 was under shut down from 15:16 to 16:40 due to protection work.</p> <p>f) Haripur 230 kV auto TR2 tripped at 11:10 showing Bucholtz, OLTC & oil level alarm at R-phase.</p> <p>g) Hasnabad-Kamrangirchar 132kV Ckt was under shut down from 19:21 to 19:46 due to sparking at R-phase loop of reserve bus.</p> <p>h) Tongi-Aminbazar 230kV Ckt-1 was under shut down from 20:25 to 12:22(27/4/13) due to red hot maintenance Aminbazar end.</p> <p>i) Ghorasal 45 MW tripped at 13:49 due to L/A problem at S/S end.</p> <p>j) Sikalbaha 150MW was shut down at 04:20(27/4/13) due to gas booster trip.</p>	
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division
	Deputy General Manager Load Despatch Circle