

DAILY REPORT

Page -1

| | | | | | | | | | | | |
|--|--------|------------|--------------------|--------------|----------------------|-----------------------|------------|--|--------|----------------------------|--------|
| Till now the maximum generation is :- | | | | 6350 MWV at | | 21:00 | | Hrs | | Reporting Date : 25-May-13 | |
| The Summary of Yesterday's (| | | | 24-May-13 | |) Generation & Demand | | Today's Actual Min Gen. & Probable Gen. & Demand | | | |
| Day Peak Generation : | 4001.0 | MW | Hour : | 12:00 | Min. Gen. at | 6:00 | 3592 | MW | | | |
| Evening Peak Generation : | 5198.0 | MW | Hour : | 20:00 | Max Generation : | | 5882 | MW | | | |
| E.P. Demand (at gen end) : | 5198.0 | MW | Hour : | 20:00 | Max Demand : | | 5800 | MW | | | |
| Maximum Generation : | 5198.0 | MW | Hour : | 20:00 | Shortage : | | -82 | MW | | | |
| Total Gen. (MKWH) : | 100.26 | | System L/ Factor : | 89.51% | Load Shed : | | 0 | MW | | | |
| EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR | | | | | | | | | | | |
| Export from East grid to West grid :- Maximum | | | | 526 | | MW | at | 22:00 | Energy | 12.216 | MKWHR. |
| Import from West grid to East grid :- Maximum | | | | - | | MW | at | - | Energy | - | MKWHR. |
| Water Level of Kaptai Lake at 6:00 A M on | | | | 25-May-13 | | | | | | | |
| Actual : | 81.21 | Ft.(MSL) , | | Rule curve : | | 77.40 | Ft.(MSL) | | | | |
| | | | | | | | | | | | |
| Gas Consumed : | Total | 847.14 | MMCFD. | | Oil Consumed (PDB) : | | | | | | |
| | | | | | | | | HSD : | Liter | | |
| | | | | | | | | FO : | Liter | | |
| Cost of the Consumed Fuel (PDB+Pvt) : | | | | | | | | | | | |
| Gas : | | | Tk67,647,509 | | | | | | | | |
| Coal : | | | Tk16,550,724 | | Oil : | Tk130,880,259 | Total : | Tk215,078,492 | | | |

Load Shedding & Other Information

| Area | Yesterday | | Today | |
|-----------------|-----------|------|---|--|
| | MW | | Estimated Demand(s/s end) from t0/MW | Estimated Shedding (s/s end) MW Rates of Shedding (On Estimated Demand) |
| Dhaka | - | 0.00 | 2148 | - |
| Chittagong Area | - | 0.00 | 546 | - |
| Khulna Area | - | 0.00 | 594 | - |
| Rajshahi Area | - | 0.00 | 581 | - |
| Comilla Area | - | 0.00 | 401 | - |
| Mymensing Area | - | 0.00 | 336 | - |
| Sylhet Area | - | 0.00 | 273 | - |
| Barisal Area | - | 0.00 | 122 | - |
| Rangpur Area | - | 0.00 | 343 | - |
| Total | 0 | | 5344 | 0 |

Information of the Generating machines under shut down.

| Planned Shut- Down | Forced Shut- Down |
|--------------------------------|--|
| 1) Haripur SBU GT-3 (18/06/09) | 1) Ghorasal 6(18/07/10) 2) Ashuganj-#1(15/1/13) 3) Khulna-60 MW(24/1/12) 4) Shahjibazar #5 & 6(21/7/11) 5) Sikalbaha-150 MW(12/5/13) 6) WMPL #1(1/5/12) 7) WMPL #2(24/4/13) 8) Sylhet-150 MW(20/5/13) |
| | 9) Raojan #2 (19/05/13) 10) Shahjibazar #8 (22/05/13) |

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

| Description | Forced load shaded / Interrupted Areas |
|---|--|
| a) Khulna(S)-Gallamari 132 kV Ckt-1 tripped at 18:07 from both end showing main & backup protection, Diffe.,DEF, Dir O/C relay and was switched on at 18:31. | |
| b) Mongla 132/33 kV T1 & T2 transformers tripped at 19:21 due to 33 kV side sena kallyan feeder fault & showing E/F instantaneous at both end and was switched on at 19:25. | Power interruption occurred (about 4 MW) under Mongla S/S area from 19:21 to 19:25 |
| c) Ashuganj-Sirajganj 203 kV Ckt-2 was shut down at 21:10 due to charged from Serajganj end. | |
| d) Dohazari-Cox'bazar 132 kV Ckt-1 & 2 tripped at 01:35 (25/05/13) showing Dist. R.B corona, zone 2, E/F relay and was switched on at 01:40,01:58 (25/05/13) respectively. | Power interruption occurred (about 23 MW) under Dohazari S/S area from 01:35 to 01:40(25/05/13). |
| e) Ullon-Siddirganj 132 kV Ckt-1 was shut down at 05:55(25/05/13) due to project work. | |
| f) Haripur-Shyampur 132 kV Ckt was under shut down at 06:12 to 10:59 (25/05/13) due to project work. | |
| g) Maniknagar-Matuail 132 kV Ckt was under shut down at 06:45 to 10:16 due to project work . | |
| h) Kaptai # 2, 3 & 4 were shut down at 07:20, 07:05, 07:17 due to removed for waterweed. | |
| Deputy / Asstt. Manager Network Operation Division | Manager Network Operation Division |
| | Deputy General Manager Load Despatch Circle |