POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08 Page -1

Reporting Date : on 6-Jun-13 7-Jun-13 Till now the maximum generation is:-**6415 MWW**V at 19:30 The Summary of Yesterday's (6-Jun-13) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation Evening Peak Generation 5294.0 MW Hour : 12:00 Min. Gen. at 7:00 4308 MW MW 6415.0 Max Generation MW Hour: 19:30 6360 E.P. Demand (at gen end) : Max Demand 6300 Hour : Maximum Generation 6415.0 MW Hour: 19:30 Shortage -60 MW Total Gen. (MKWH) 134.19 System L/ Factor 95.62% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR MW Export from East grid to West grid :- Maximum 640 MKWHR. at 3:00 Energy 12.584 Import from West grid to East grid :- Maximum MW MKWHR. at Energy Water Level of Kaptai Lake at 6:00 A M on 7-Jun-13 Actual: 78.67 Ft.(MSL) Rule curve : 77.56 Ft.(MSL) Gas Consumed : Total Oil Consumed (PDB): 961.30 MMCFD. HSD : Liter FO: Liter Cost of the Consumed Fuel (PDB+Pvt) : Tk76,763,641 Gas Tk17,659,578 Oil : Tk419,375,529 Total : Tk513,798,748

Load Shedding & Other Information

Area	Yesterday		Today		
ľ			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Estimated Shedding (s/s en Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	-	0:00	2279	-	-
Chittagong Area	-	0:00	582	-	-
Khulna Area	-	0:00	635	-	-
Rajshahi Area	-	0:00	618	-	-
Comilla Area	-	0:00	426	-	-
Mymensing Area	-	0:00	354	-	-
Sylhet Area	-	0:00	288	-	-
Barisal Area	-	0:00	128	-	-
Rangpur Area	-	0:00	362	-	-
Total	0		5672	0	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down	
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal 6(18/07/10)	
	2) Ashuganj-#1(15/1/13)	9) Sylhet 20 MW(03/06/13)
	3) Khulna-60 MW(24/1/12)	10) Ghorasal #2 (3/6/13)
	4) Shahjibazar #5 & 6(21/7/11)	11) Baghabari-71 MW(06/06/13)
	5) Sikalbaha-150 MW(12/5/13)	
	6) WMPL #1(1/5/12)	
	7) WMPL #2(24/4/13)	
	8) Sikalbaha-60 MW(28/05/2013)	

Forced load shaded / Interrupted Areas

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description

a) Purbasadipur 132/33 kV T2 transformer tripped at 06:44 showing O/C relay and was switched on at 09:25. b) Rampura-Bashundhara 132 kV Ckt-1 was shut down at 09:53 due to red hot maintenance at B-phase CB point and was switched on at 11:07. c) Daudkandi 132/33 kV T2 transformer tripped at 11:17 showing O/C & E/F relays and was switched on at 11:27. d) Bashundhara-Tongi 132 kV Ckt-2 was shut down at 11:48 due to maintenance work and was switched on at 17:02. e) After maintenance Ghorasal #1 was synchronized at 12:20. f) Khulis-Baraulia 132 kV ckt-2 tripped at 14:28 showing E/F relay and was switched on at 14:43. g) Baraulia-A.Khayer 132 kV Ckt tripped at 14:28 showing dist.B-phase and was switched on at 14:43. h) Hathazari-Baraulia 132 kV Ckt-1 & 2 tripped at 14:32 dist.C-phase, Z2 & E/F relays and were switched on at 14:46. i) Julda-100 MW tripped at 14:32 showing E/F relay and was switched on at 15:02. j) Tongi-Aminbazar 230 kV Ckt-1 tripped at 00:44(76/13) showing main protection relay and was switched on at 01:08(7/6/13). l) B.Baria-70 MW was shut down at 06:15(7/6/13) due to project work. n) Milrpur 132/33 kV T1 transformer was shut down at 06:08(7/6/13) due to red hot maintenance and was switched on at 07:12(7/6/13). Deputy / Asstt. Manager Network Operation Division Activated to red hot maintenance and was switched on at 07:12(7/6/13). Power interruption occurred (about 15 MW) under Daudkandi S/S areas from 11:17 to 11:27. Power interruption occurred (about 15 MW) under 11:17 to 11:27. Power interruption occurred (about 25 MW) under Mirpur S/S areas from 06:08 to 07:12(7/6/13).			
at B-phase CB point and was switched on at 11:07. c) Daudkandi 132/33 kV T2 transformer tripped at 11:17 showing O/C & E/F relays and was switched on at 11:27. d) Bashundhara-Tongi 132 kV Ckt-2 was shut down at 11:48 due to maintenance work and was switched on at 17:02. e) After maintenance Ghorasal #1 was synchronized at 12:20. f) Khulis-Baraulia 132 kV ckt-2 tripped at 14:28 showing E/F relay and was switched on at 14:43. g) Baraulia-A.Khayer 132 kV Ckt tripped at 14:28 showing dist.B-phase and was switched on at 14:43. h) Hathazari-Baraulia 132 kV Ckt-1 & 2 tripped at 14:32 dist.C-phase, Z2 & E/F relays and were switched on at 14:46. i) Julda-100 MW tripped at 14:32 showing E/F relay and was switched on at 15:02. j) Tongi-Aminbazar 230 kV Ckt-1 tripped at 15:58 showing dist.prot.relay and was switched on at 16:07. k) Aminbazar 132 kV Bus tripped at 00:44(7/6/13) showing main protection relay and was switched on at 01:06(7/6/13). l) B.Baria-70 MW was shut down at 05:15(7/6/13) due to project work. m) Ullon-Siddirganj-Maniknagar 132 kV Ckt was shut down at 06:08(7/6/13) due to red hot maintenance and was switched on at 07:12(7/6/13). Deputy / Asstt. Manager Manager Manager Power interruption occurred (about 15 MW) under Daudkandi S/S areas from 11:17 to 11:27. Power interruption occurred (about 15 MW) under Daudkandi S/S areas from 11:17 to 11:27.		owing O/C relay and was	
switched on at 11:27. d) Bashundhara-Tongi 132 kV Ckt-2 was shut down at 11:48 due to maintenance work and was switched on at 17:02. e) After maintenance Ghorasal #1 was synchronized at 12:20. f) Khulsi-Baraulia 132 kV ckt-2 tripped at 14:28 showing E/F relay and was switched on at 14:43. g) Baraulia-A.Khayer 132 kV Ckt tripped at 14:28 showing dist.B-phase and was switched on at 14:43. h) Hathazari-Baraulia 132 kV Ckt-1 & 2 tripped at 14:32 dist.C-phase, Z2 & E/F relays and were switched on at 14:46. i) Julda-100 MW tripped at 14:32 showing E/F relay and was switched on at 15:02. j) Tongi-Aminbazar 230 kV Ckt-1 tripped at 15:58 showing dist.prot.relay and was switched on at 16:07. k) Aminbazar 132 kV Bus tripped at 00:44(7/6/13) showing main protection relay and was switched on at 01:08(7/6/13). l) B.Baria-70 MW was shut down at 05:15(7/6/13) due to project work. m) Ullon-Siddirganj-Maniknagar 132 kV Ckt was shut down at 06:02(7/6/13) due to red hot maintenance and was switched on at 07:12(7/6/13). o) Shahjibazar #8 was forced shut down at 05:27(7/6/13) due to cooling system problem. from 11:17 to 11:27. from 11:17 to 11:27. from 11:17 to 11:27. from 11:17 to 11:27. from 01:127. from 01:127. from 01:127. from 01:127. from 11:17 to 11:27.	, ·	53 due to red hot maintenance	
was switched on at 17:02. e) After maintenance Ghorasal #1 was synchronized at 12:20. f) Khulsi-Baraulia 132 kV ckt-2 tripped at 14:28 showing E/F relay and was switched on at 14:43. g) Baraulia-A.Khayer 132 kV Ckt tripped at 14:28 showing dist.B-phase and was switched on at 14:43. h) Hathazari-Baraulia 132 kV Ckt-1 & 2 tripped at 14:32 dist.C-phase, Z2 & E/F relays and were switched on at 14:46. i) Julda-100 MW tripped at 14:32 showing E/F relay and was switched on at 15:02. j) Tongi-Aminbazar 230 kV Ckt-1 tripped at 15:58 showing dist.prot.relay and was switched on at 16:07. k) Aminbazar 132 kV Bus tripped at 00:44(7/6/13) showing main protection relay and was switched on at 01:08(7/6/13). l) B.Baria-70 MW was shut down at 05:15(7/6/13) due to project work. m) Ullon-Siddirganj-Maniknagar 132 kV Ckt was shut down at 06:02(7/6/13) due to red hot maintenance and was switched on at 07:12(7/6/13). o) Shahjibazar #8 was forced shut down at 05:27(7/6/13) due to cooling system problem. Deputy / Asstt. Manager Manager Deputy General Manager	· · · · · · · · · · · · · · · · · · ·	. , , , ,	
1) Khulsi-Baraulia 132 kV ckt-2 tripped at 14:28 showing E/F relay and was switched on at 14:43. g) Baraulia-A.Khayer 132 kV Ckt tripped at 14:28 showing dist.B-phase and was switched on at 14:43. h) Hathazari-Baraulia 132 kV Ckt-1 & 2 tripped at 14:32 dist.C-phase, Z2 & E/F relays and were switched on at 14:46. i) Julda-100 MW tripped at 14:32 showing E/F relay and was switched on at 15:02. j) Tongi-Aminbazar 230 kV Ckt-1 tripped at 15:58 showing dist.prot.relay and was switched on at 16:07. k) Aminbazar 132 kV Bus tripped at 00:44(7/6/13) showing main protection relay and was switched on at 01:08(7/6/13). l) B.Baria-70 MW was shut down at 05:15(7/6/13) due to project work. m) Ullon-Siddirganj-Manikmagar 132 kV Ckt was shut down at 06:08(7/6/13) due to red hot maintenance and was switched on at 07:12(7/6/13). o) Shahjibazar #8 was forced shut down at 05:27(7/6/13) due to cooling system problem. Deputy / Asstt. Manager Manager Deputy General Manager	,		
g) Baraulia-A.Khayer 132 kV Ckt tripped at 14:28 showing dist.B-phase and was switched on at 14:43 h) Hathazari-Baraulia 132 kV Ckt-1 & 2 tripped at 14:32 dist.C-phase, Z2 & E/F relays and were switched on at 14:46. j) Julda-100 MW tripped at 14:32 showing E/F relay and was switched on at 15:02. j) Tongi-Aminbazar 230 kV Ckt-1 tripped at 15:58 showing dist.prot.relay and was switched on at 16:07. k) Aminbazar 132 kV Bus tripped at 00:44(7/6/13) showing main protection relay and was switched on at 01:08(7/6/13). l) B.Baria-70 MW was shut down at 05:15(7/6/13) due to project work. m) Ullion-Siddirganj-Maniknagar 132 kV Ckt was shut down at 06:08(7/6/13) due to red hot maintenance and was switched on at 07:12(7/6/13). o) Shahjibazar #8 was forced shut down at 05:27(7/6/13) due to cooling system problem. Deputy / Asstt. Manager Manager Deputy General Manager	e) After maintenance Ghorasal #1 was synchronized at 12:20		
h) Hathazari-Baraulia 132 kV Ckt-1 & 2 tripped at 14:32 dist.C-phase, Z2 & E/F relays and were switched on at 14:46. i) Julda-100 MW tripped at 14:32 showing E/F relay and was switched on at 15:02. j) Tongi-Aminbazar 230 kV Ckt-1 tripped at 15:58 showing dist.prot.relay and was switched on at 16:07. k) Aminbazar 132 kV Bus tripped at 00:44(7/6/13) showing main protection relay and was switched on at 01:08(7/6/13). l) B.Baria-70 MW was shut down at 05:15(7/6/13) due to project work. m) Ullon-Siddirganj-Maniknagar 132 kV Ckt was shut down at 06:02(7/6/13) due to project work. m) Mirpur 132/33 kV T1 transformer was shut down at 06:08(7/6/13) due to red hot maintenance and was switched on at 07:12(7/6/13). o) Shahjibazar #8 was forced shut down at 05:27(7/6/13) due to cooling system problem. Deputy / Asstt. Manager Manager Deputy General Manager	f) Khulsi-Baraulia 132 kV ckt-2 tripped at 14:28 showing E/F re		
were switched on at 14:46. i) Julda-100 MW tripped at 14:32 showing E/F relay and was switched on at 15:02. j) Tongi-Aminbazar 230 kV Ckt-1 tripped at 15:58 showing dist.prot.relay and was switched on at 16:07. k) Aminbazar 132 kV Bus tripped at 00:44(7/6/13) showing main protection relay and was switched on at 01:08(7/6/13). l) B.Baria-70 MW was shut down at 05:15(7/6/13) due to project work. m) Ullon-Siddirganj-Maniknagar 132 kV Ckt was shut down at 06:02(7/6/13) due to red hot maintenance and was switched on at 07:12(7/6/13). Power interruption occurred (about 25 MW) under Mirpur S/S areas from 06:08 to 07:12(7/6/13). Deputy / Asstt. Manager Manager Deputy General Manager	g) Baraulia-A.Khayer 132 kV Ckt tripped at 14:28 showing dis	t.B-phase and was switched on at 14:43	
j) Tongi-Aminbazar 230 kV Ckt-1 tripped at 15:58 showing dist.prot.relay and was switched on at 16:07. k) Aminbazar 132 kV Bus tripped at 00:44(7/6/13) showing main protection relay and was switched on at 01:08(7/6/13). l) B.Baria-70 MW was shut down at 05:15(7/6/13) due to project work. m) Ullion-Siddirganj-Maniknagar 132 kV Ckt was shut down at 06:02(7/6/13) due to project work. n) Mirpur 132/33 kV T1 transformer was shut down at 06:08(7/6/13) due to red hot maintenance and was switched on at 07:12(7/6/13). o) Shahjibazar #8 was forced shut down at 05:27(7/6/13) due to cooling system problem. Deputy / Asstt. Manager Manager Deputy General Manager		-phase, Z2 & E/F relays and	
k) Aminbazar 132 kV Bus tripped at 00:44(7/6/13) showing main protection relay and was switched on at 01:08(7/6/13). l) B.Baria-70 MW was shut down at 05:15(7/6/13) due to project work. m) Ullion-Siddirganj-Maniknagar 132 kV Ckt was shut down at 06:02(7/6/13) due to project work. n) Mirpur 132/33 kV T1 transformer was shut down at 06:08(7/6/13) due to red hot maintenance and was switched on at 07:12(7/6/13). Power interruption occurred (about 25 MW) under Mirpur S/S areas from 06:08 to 07:12(7/6/13). Deputy / Asstt. Manager Manager Deputy General Manager	i) Julda-100 MW tripped at 14:32 showing E/F relay and was		
switched on at 01:08(7/6/13). I) B.Baria-70 MW was shut down at 05:15(7/6/13) due to project work. m) Ullon-Siddirganj-Maniknagar 132 kV Ckt was shut down at 06:02(7/6/13) due to project work. n) Mirpur 132/33 kV T1 transformer was shut down at 06:08(7/6/13) due to red hot maintenance and was switched on at 07:12(7/6/13). Power interruption occurred (about 25 MW) under Mirpur S/S areas from 06:08 to 07:12(7/6/13). Poputy / Asstt. Manager Manager Deputy General Manager	i) Tongi-Aminbazar 230 kV Ckt-1 tripped at 15:58 showing dis	t.prot.relay and was switched on at 16:07	
m) Ullon-Siddirganj-Maniknagar 132 kV Ckt was shut down at 06:02(7/6/13) due to project work. n) Mirpur 132/33 kV T1 transformer was shut down at 06:08(7/6/13) due to red hot maintenance and was switched on at 07:12(7/6/13). o) Shahjibazar #8 was forced shut down at 05:27(7/6/13) due to cooling system problem. Deputy / Asstt. Manager Manager Deputy General Manager	, , , ,	ain protection relay and was	
n) Mirpur 132/33 kV T1 transformer was shut down at 06:08(7/6/13) due to red hot maintenance and was switched on at 07:12(7/6/13). o) Shahjibazar #8 was forced shut down at 05:27(7/6/13) due to cooling system problem. Deputy / Asstt. Manager Manager Deputy General Manager	I) B.Baria-70 MW was shut down at 05:15(7/6/13) due to proje	ect work.	
and was switched on at 07:12(7/6/13). o) Shahjibazar #8 was forced shut down at 05:27(7/6/13) due to cooling system problem. Deputy / Asstt. Manager Manager Deputy General Manager	m) Ullon-Siddirganj-Maniknagar 132 kV Ckt was shut down at		
Deputy / Asstt. Manager Deputy General Manager	, · ·		
	o) Shahjibazar #8 was forced shut down at 05:27(7/6/13) due		
	Deputy / Asstt. Manager	Manager	Deputy General Manager
	Network Operation Division	Network Operation Division	Load Despatch Circle