

QF-LDC-08
Page -1

Description		Forced load shed / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday. b) Hathazari-Raozan 230 kV Ckt-2 was shut down at 08:44 due to oil leakage maintenance of SF6 at Raozan end and was switched on at 09:45. c) Khulina-150 MW was synchronized at 10:59 and was shut down at 22:32. d) Hasnabad 132/33 kV T1 transformer was shut down at 12:38 due to temperature meter replacement and was switched on at 16:10. e) Fenchuganj GT1 was forced shut down at 19:56 due to radiator fan trouble and was synchronized at 20:46. f) Bhuita 132/33 kV T1 transformer was shut down at 16:40 due to replacing LT bushing clamp and was switched on at 17:02.		So about 227 MW (21:00) of load shed was imposed over the whole areas(except-Sylhet) of the national grid .
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division	Deputy General Manager Load Despatch Circle