POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

MW

at 8:00

Reporting Date: 15-Sep-13

Till now the maximum generation is : **6675 MW** at 21:00 Hrs on 12-Jul-13 The Summary of Yesterday's (14-Sep-13) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 4660.0 MW Hour: 12:00 Min. Gen. at 7:00 4833 MW Evening Peak Generation 6232.0 MW 21:00 6360 MW Hour : Max Generation E.P. Demand (at gen end) : 6450.0 MW Max Demand 6600 MW Maximum Generation 6240.0 MW Hour : 22:00 Shortage 240 MW Total Gen. (MKWH) 126.62 System I / Facto 81.11% Load Shed 223 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

600

Import from West grid to East grid :- Maximum MW Water Level of Kaptai Lake at 6:00 A M on 15-Sep-13

94.44 Ft.(MSL) Rule curve : 102.22 Ft.(MSL) Actual

Gas Consumed : 908.22 MMCFD. Oil Consumed (PDB):

HSD : Liter

8.579

MKWHR.

MKWHR.

FO : Liter

Energy

Energy

Cost of the Consumed Fuel (PDB+Pvt) : Tk72 524 991

Export from East grid to West grid :- Maximum

: Tk364,369,585 Total : Tk453,773,847 Tk16,879,271

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s en	Rates of Shedding
	MW		from tonw	MW	(On Estimated Demand)
Dhaka	48	(18:10-22:40)	2436	69	3%
Chittagong Area	25	(18:10-22:40)	633	26	4%
Khulna Area	31	(18:10-22:40)	692	29	4%
Rajshahi Area	24	(18:10-22:40)	672	28	4%
Comilla Area	22	(18:10-22:40)	462	19	4%
Mymensing Area	16	(18:10-22:40)	383	16	4%
Sylhet Area	10	(18:10-22:40)	312	13	4%
Barisal Area	10	(18:10-22:40)	139	6	4%
Rangpur Area	16	(18:10-22:40)	392	17	4%
Total	202	21:00	6121	223	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal #6(18/07/10) 8) Sikalbaha 60 MW (15/08/13) 2) Khulna-60 MW(24/1/12) 9) Ashuganj CC GT1 & ST(8/9/13)
	3) Shahjibazar #5 & 6(21/7/11) 4) WMPL #1(1/5/12) 5) WMPL #2(24/4/13)
	6) Raojan #2 (31/07/13) 7) Raozan #1 (15/08/13)

Additional Information of Machines Lines Interruption / Forced Load shed etc

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 202 MW (21:00) of load shed was imposed over the
b) Fenchuganj 230/132 kV AT4 was under shut down from 08:05 to 13:25 due to project work.	whole areas of the national grid .
c) Aminbazar-Savar 132 kV Ckt-2 tripped at 11:33 showing main protection (1&2) & dist.relay and was switched on at 11:57.	Power interruption occurred (about 50 MW) under Savar S/S areas from 11:33 to 11:57.
d) Jessore 132/33 kV T1, T2 & T3 transformer tripped at 09:25 showing O/C & E/F relay and were switched on at 09:40, 09:40 & 14:12 respectively.	Power interruption occurred (about 20 MW) under Jessore S/S areas from 09:25 to 09:40.
e) Jessore 33 kV bus was under shut down from 12:40 to 14:10 due to 33 kV feeder fault.	Power interruption occurred (about 60 MW) under Jessore S/S areas
f) Chowmohoni 132/33 kV 50/75 MVA T2 (New) transformer energized at 12:56.	from 12:40 to 14:10.
g) Tangail 132/33 kV T2 transformer was under shut down from 16:10 to 17:03 due to maintenance work.	Power interruption occurred (about 35 MW) under Tangail S/S areas from 16:10 to 17:03.
h) Noapara 132/33 kV T1 was under shut down from 23:07 to 23:27 due to red hot maintenance.	Power interruption occurred (about 15 MW) under Noapara S/S areas
 i) Chandpur 150 MW tripped at 16:44 due to gas pressure high and was synchronized at 19:55. 	from 23:07 to 23:27.
j) After maintenance Shah Mirpur 132/33 kV T1 transformer energized at 16:58.	
 k) Purbashadipur 132/33 kV T3 transformer was under shut down from 18:09 to 18:57 due to 33 kV bus PT burst. 	
 Purbashadipur 132/33 kV T3 transformer was under shut down from 23:12 to 23:45 due to red hot maintenance. 	Power interruption occurred (about 10 MW) under Purbashadipur S/S areas from 23:12 to 23:45.
m) After maintenance Ashuganj #3 was synchronized at 00:13 (15/09/13).	
 n) Julda 100 MW was under shut down from 05:38 (15/09/13) to 08:20 (15/09/13) due to cable replacement. 	
 o) Ghorasal Auto transformer AT2 was under shut down from 05:52 (15/09/13) to 08:36 (15/09/13). due to breaker problem. 	
p) Hathazari 132/33 kV T2 transformer tripped at 07:14 (15/09/13) showing Diff & E/F relay and	Power interruption occurred (about 12 MW) under Hathazari S/S areas

Deputy / Asstt. Manager **Network Operation Division**

was switched on at 12:10 (15/09/13).

Manager Network Operation Division Deputy General Manager Load Despatch Circle

from 07:14 to 08:40 (15/09/13).