

**POWER GRID COMPANY OF BANGLADESH LTD.**  
**NATIONAL LOAD DESPATCH CENTER**  
**DAILY REPORT**

QF-LDC-08  
Page -1

Till now the maximum generation is :- **6675 MW** at **21:00** Hrs on **12-Jul-13** Reporting Date : **5-Nov-13**

The Summary of Yesterday's (		4-Nov-13		) Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation	:	4422.0	MW	Hour :	12:00	Min. Gen. at	5:00 3315 MW
Evening Peak Generation	:	5922.0	MW	Hour :	18:30	Max Generation	: 6065 MW
E.P. Demand (at gen end)	:	5922.0	MW	Hour :	18:30	Max Demand	: 5950 MW
Maximum Generation	:	5922.0	MW	Hour :	18:30	Shortage	: -115 MW
Total Gen. (MKWH)	:	103.82		System L/ Factor	: 81.11%	Load Shed	: 0 MW

**EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR**

Export from East grid to West grid :- Maximum	220	MW	at	7:00	Energy	2.993	MKWHR.
Import from West grid to East grid :- Maximum	-	MW	at	-	Energy	-	MKWHR.
Water Level of Kaptai Lake at 6:00 A M on 5-Nov-13							
Actual :	98.52	Ft.(MSL)	Rule curve :	108.60	Ft.( MSL )		

Gas Consumed : Total 763.13 MMCFD. Oil Consumed (PDB) : HSD : Liter  
FO : Liter

Cost of the Consumed Fuel (PDB+Pvt) : Gas : Tk60,938,975  
Coal : Tk16,057,900 Oil : Tk239,159,586 Total : Tk316,156,462

**Load Shedding & Other Information**

Area	Yesterday		Today		Rates of Shedding (On Estimated Demand)
	MW		Estimated Demand(s/s end) from 10MW	Estimated Shedding (s/s end) MW	
Dhaka	-	0.00	2260	-	-
Chittagong Area	-	0.00	576	-	-
Khulna Area	-	0.00	629	-	-
Rajshahi Area	-	0.00	612	-	-
Comilla Area	-	0.00	422	-	-
Mymensing Area	-	0.00	351	-	-
Sylhet Area	-	0.00	286	-	-
Barisal Area	-	0.00	127	-	-
Rangpur Area	-	0.00	359	-	-
<b>Total</b>	<b>0</b>		<b>5622</b>	<b>0</b>	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal #6(18/07/10) 9) Sikalbaha-150(21/9/13) 2) Khulna-60 MW(24/1/12) 10) Siddirganj ST (03/10/13) 3) Shahjibazar #5 & 6(21/7/11) 11) Ghorasal #2 (02/10/13) 4) WMPL #1(1/5/12) 12) Megnaghat GT-1 MW (18/10/13) 5) WMPL #2(24/4/13) 13) Chandpur CAPP (02/11/13) 6) Raojan #2 (31/07/13) 14) Shahjibazar-8(4/11/13) 7) Raozan #1 (15/08/13) 8) Ashuganj ST(CC)(8/9/13)

**Additional Information of Machines. lines. Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
a) Feni-Hathazari 132 kV Ckt-1 was under shut down from 09:33 to 13:20 due to annual maintenance work. b) Rampura-Ghorasal 230 kV Ckt-1 was under shut down from 09:34 to 17:32 due to annual maintenance work. c) Aminbazer 230/132 kV T1 transformer was under shut down from 09:02 to 17:22 due to annual maintenance work. d) Sreemongal 132/33 kV T2 transformer was under shut down from 09:41 to 15:32 due to annual maintenance work. e) Mymensingh 132/33 kV T1 transformer was under shut down from 09:14 to 14:35 due to annual maintenance work. f) Kishoreganj 132/33 kV T1 transformer was under shut down from 08:15 to 14:35 due to annual maintenance work. g) Chandpur 132/33 kV T2 transformer was under shut down from 09:09 to 11:40 due to annual maintenance work. h) Rampura-Bashundhara 132 kV Ckt-1 was under shut down from 08:27 to 16:30 due to annual maintenance work.	
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division  Deputy General Manager Load Despatch Circle