

**POWER GRID COMPANY OF BANGLADESH LTD.**  
**NATIONAL LOAD DESPATCH CENTER**  
**DAILY REPORT**

QF-LDC-08  
Page -1

Till now the maximum generation is :-				6675 MW at		21:00		Hrs		Reporting Date : 16-Nov-13 on 12-Jul-13	
The Summary of Yesterday's (				15-Nov-13		) Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :		3600.0		MW		Hour :		12:00		Min. Gen. at 5:00 3095 MW	
Evening Peak Generation :		5271.0		MW		Hour :		18:00		Max Generation : 5960 MW	
E.P. Demand (at gen end) :		5271.0		MW		Hour :		18:00		Max Demand : 5850 MW	
Maximum Generation :		5271.0		MW		Hour :		18:00		Shortage : -110 MW	
Total Gen. (MKWH) :		89.68		System L/ Factor :		81.11%		Load Shed :		0 MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				300		MW		at 23:00		Energy 6.508 MKWHR.	
Import from West grid to East grid :- Maximum				-		MW		at -		Energy - MKWHR.	
Water Level of Kaptai Lake at 6:00 A M on				16-Nov-13							
Actual :		97.34		Ft.(MSL) ,		Rule curve :		107.50		Ft.( MSL )	
Gas Consumed :		Total		739.65		MMCFD.		Oil Consumed (PDB) :			
										HSD : Liter	
										FO : Liter	
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :		Tk59,064,004							
		Coal :		Tk16,103,059		Oil :		Tk107,963,364		Total : Tk183,130,427	

**Load Shedding & Other Information**

Area	Yesterday		Today		
	MW		Estimated Demand(s/s end) from 10:00	Estimated Shedding (s/s er) MW	Rates of Shedding (On Estimated Demand)
Dhaka	-	0:00	2174	-	-
Chittagong Area	-	0:00	553	-	-
Khulna Area	-	0:00	602	-	-
Rajshahi Area	-	0:00	588	-	-
Comilla Area	-	0:00	406	-	-
Mymensing Area	-	0:00	339	-	-
Sylhet Area	-	0:00	276	-	-
Barisal Area	-	0:00	123	-	-
Rangpur Area	-	0:00	347	-	-
<b>Total</b>	<b>0</b>		<b>5408</b>	<b>0</b>	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal #6(18/07/10) 9) Sikalbaha-150(21/9/13) 2) Khulna-60 MW(24/1/12) 10) Ghorasal #2 (02/10/13) 3) Shahjibazar #5 & 6(21/7/11) 11) Megnaghat GT-1 MW (18/10/13) 4) WMPL #1(1/5/12) 12) Fenchuganj old ST (01/11/13) 5) WMPL #2(24/4/13) 13) Khulna 110 MW (05/11/13) 6) Raojan #2 (31/07/13) 14) Ashuganj #2 (14/11/13) 7) Raozan #1 (15/08/13) 8) Ashuganj ST(CC)(8/9/13)

**Additional Information of Machines. lines. Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
<p>a) HVDC Bheramara was shut down from 08:46 to 21:51 due to maintenance work.</p> <p>b) Bheramara-Baharampur 400 kV Ckt-2 was shut down from 09:33 to 22:11 due to maintenance work.</p> <p>c) Naogaon-Joypurhat 132 kV Ckt was shut down from 09:40 to 15:05 due to A/M.</p> <p>d) Bhulta 132/33 kV T1 transformer was shut down from 08:45 to 17:52 due to A/M.</p> <p>e) Kalyanpur-Hasnabad 132 kV Ckt was shut down from 09:30 to 17:50 due to A/M.</p> <p>f) Haripur-Madanganj 132 kV Ckt was shut down from 10:40 to 18:08 due to A/M.</p> <p>g) Comilla (N) 230/132 kV T01 transformer was shut down from 11:22 to 16:55 due to A/M.</p> <p>h) Ghorashal-Ishurdi 230 kV Ckt-1 was shut down at 07:20(16/11/13) due to A/M.</p> <p>i) Siddirganj S/S-Siddirganj Desh Ckt was shut down at 06:50(16/11/13) due to project work.</p> <p>j) Haripur-Madanganj 132 kV Ckt was shut down at 08:02(16/11/13) due to A/M.</p> <p>k) Satkhira 132/33 kV T1 transformer was shut down at 07:56(16/11/13) due to A/M.</p> <p>l) Siddirganj-Ullon 132 kV Ckt-1 &amp; 2 were shut down at 07:32(16/11/13) due to EGCB work.</p> <p>m) Barisal-Madaripur 132 kV Ckt-1 was shut down at 07:23(16/11/13) due to A/M.</p> <p>n) Bhandaria 132/33 kV T1 transformer was shut down at 07:30(16/11/13) due to A/M.</p> <p>o) Siddirganj-Maniknagar 132 kV Ckt was shut down at 07:40(16/11/13) due to EGCB work.</p> <p>p) Rajshahi-Chapai Nawabganj 132 kV Ckt-1 was shut down at 08:05(16/11/13) due to A/M.</p>	
Deputy / Asstt. Manager Network Operation Division	Deputy General Manager Load Despatch Circle

Manager  
Network Operation Division