POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC.DHAKA DAILY REPORT

QF-LDC-08 Page -1

				Repor	ting Date :	26-Jun-10	
Till now the maximum generation is	:-	4606.0 MW at	22:00	Hrs on	14-Apr-10		
The Summary of Yesterday's (25-Jun-10) Generation & Demand		Today's Actual N	/lin Gen. & Pr	obable Gen. a	& Demand
Day Peak Generation :	3770.0	MW Hour :	10:00	Min Gen. at	7:00	3529	MW
Evening Peak Generation :	4046.5	MW Hour :	21:00	Max Generation	:	4076	MW
E.P. Demand (at gen end) :	4850.0	MW Hour :	21:00	Max Demand	:	4950	MW
Maximum Generation :	4136.5	MW Hour :	24:00	Shortage	:	874	MW
Total Gen. (MKWH) :	88.96	System L/ Factor :	85.41%	Load Shed	:	727	MW
	EXPO	RT/IMPORT THROUGH EAST	-WEST INTERCONNECTOR				
Export from East grid to West grid :- N	<i>M</i> aximum	420	MW at	22:00	Energy	91020	00 KWHR.
Import from West grid to East grid :- M	<i>l</i> laximum	-	MW at	-	Energy	-	KWHR.
	Water Level of Kaptai La	ke at 6:00 A M of	26-Jun-10				
Actual : 93.50	Ft.(MSL),		Rule curve : 82.65	Ft.(MSL)			
Gas Consumed : Total	795.43	MMCFt.	Oil Consume	ed (PDB):			
				· · ·	HSD :	1808358	Liter
				I	FO :	0	Liter

Cost of the Consumed Fuel (PDB): Gas

Tk58,790,231

Oil : Tk72,334,330 Total : Tk131,124,561

Load Shedding & Other Information

Area	Yesterday		Today			
			Estimated Demand(s/s end)	Estimated Shedding (s/s e Rates of Shedding		
	MW		from to/IW	MW	(On Estimated Demand)	
Dhaka	272	(18:45-00:45, gen. shortage)	1780	292	16%	
Chittagong Area	92	(18:45-01:40, gen. shortage)	507	95	19%	
Khulna Area	88	(18:45-01:00, gen. shortage)	445	83	19%	
Rajshahi Area	66	(18:45-00:45, gen. shortage)	368	68	18%	
Comilla Area	41	(18:45-00:45, gen. shortage)	289	54	19%	
Aymensing Area	38	(18:45-00:45, gen. shortage)	215	40	19%	
Sylhet Area	28	(18:45-00:47, gen. shortage)	228	42	18%	
Barisal Area	12	(18:45-01:00, gen. shortage)	89	17	19%	
Rangpur Area	32	(18:45-00:45, gen. shortage)	198	36	18%	
Total	669	21:00	4119	727		

Information of the Generating machines under shut down.

Planned Shut- Down Forced Shut-Down 8) Siddhirganj GT-1 (16/06/10) 9) Siddhirganj GT-2 (06/06/10) 1) Kaptai- 3 (19/04/08) 2) Khulna 110MW (31/03/09) 3) Haripur SBU GT-3 (18/06/09) 10) Kaptai -1 (25/06/10) 4) Ashuganj CCPP ST (05/12/09) 5) Raozan -1 (08/05/10) 6) Ghorasal 2(26/04/10) 7) Kaptai- 4 (17/01/10)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 669 MW (21:00) of load shed was imposed over the
	whole (except Sylhet) areas of the national grid.
b) Due to gas limitation, Raozan (180 MW), RPCL (210 MW), NEPC (110 MW) and HPL (360 MW)	
were limited to 100 MW, 85 MW, 33 MW, 350 MW respectively.	
c) After maintenmance, Sikalbaha 60 MW was synchronized at 19:16. But it tripped at 05:10 (26/06/10) due to boiler tube leakage.	
d) After maintenmance, Khulna 60 MW was synchronized at 19:34.	
e) After maintenance, Ghorasal unit - 4 was synchronized at 23:04.	
) Mirpur 132/33 KV T2 transformer was under shut down from 09:26 to 18:40 due to painting work.	

Manager Load Despatch Division

Deputy General Manager Load Despatch Circle