

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT										QF-LDC-08 Page -1
Reporting Date : 16-Apr-14										
Till now the maximum generation is :- 7356 MW at 20:00 Hrs on 30-Mar-14										
The Summary of Yesterday's (15-Apr-14			Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand				
Day Peak Generation :	6261.0	MW	Hou	12:00	Min. Gen. at 7:00	5677	MW			
Evening Peak Generation :	7176.0	MW	Hou	20:00	Max Generation :	7225	MW			
E.P. Demand (at gen end) :	7176.0	MW	Hou	20:00	Max Demand :	7200	MW			
Maximum Generation :	7176.0	MW	Hou	20:00	Shortage :	-25	MW			
Total Gen. (MKWH) :	150.8	System L/ Factor :		78.37%	Load Shed :	0	MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR										
Export from East grid to West grid :- Maximum				-170	MW	at 15:00	Energy	7.867	MKWHR.	
Import from West grid to East grid :- Maximum				-	MW	at -	Energy	-	MKWHR.	
Water Level of Kaptai Lake at 6:00 A M on 16-Apr-14										
Actual : 87.64		Ft.(MSL) ,		Rule curve : 85.00		Ft.(MSL)				
Gas Consumed : Total 1029.39 MMCFD. Oil Consumed (PDB) :										
HSD : Liter										
FO : Liter										
Cost of the Consumed Fuel (PDB+Pvt) : Gas : Tk87,832,853										
Coal : Tk16,523,023 Oil : Tk498,466,953 Total : Tk602,822,829										
Load Shedding & Other Information										
Area	Yesterday		Estimated Demand(s/s end)		Today		Rates of Shedding			
	MW		from toMW		Estimated Shedding (s/s end) MW		(On Estimated Demand)			
Dhaka	-	0:00	2653		-		-			
Chittagong Area	-	0:00	687		-		-			
Khulna Area	-	0:00	754		-		-			
Rajshahi Area	-	0:00	727		-		-			
Comilla Area	-	0:00	499		-		-			
Mymensingh Area	-	0:00	408		-		-			
Sylhet Area	-	0:00	332		-		-			
Barisal Area	-	0:00	147		-		-			
Rangpur Area	-	0:00	417		-		-			
	-									
Total	0		6624		0					
Information of the Generating machines under shut down.										
	Planned Shut- Down				Forced Shut- Down					
	1) Haripur SBU GT-3 (18/06/09)				1) Ghorasal #6 (18/07/10) 2) Khulna-60MW (24/1/12) 3) Shahjibazar #5 & 6 (21/7/11) 4) WMPL #1(1/5/12) 5) WMPL #2(24/4/13) 6) Ashuganj GT-1(CCPP) (06/01/14) 7) Khulna 110MW (10/04/2014)					
Additional Information of Machines. lines. Interruption / Forced Load shed etc.										
Description					Forced load shaded / Interrupted Areas					
a) Magbazar 132/33 kV T1 transformer tripped at 11:37 showing pressure relief device alarm and was switched on at 13:29.					Power interruption occurred (about 116 MW) under Magbazar S/S areas from 11:51 to 12:05.					
b) Magbazar 132/33 kV T2 & T3 transformers tripped at 11:51 showing O/C relay and were switched on at 12:05 & 12:37 respectively.										
c) Hasnabad 33 kV reserve Bus was shut down at 15:16 due to red hot maintenance and was switched on at 17:55.										
d) Rangpur-Saidpur 132 kV Ckt-2 was shut down at 19:10 due to R-phase of CT maintenance and was switched on at 20:38.										
e) Siddirganj 132/33 kV T1 & T2 transformers was shut down at 21:54 showing O/C & differential relays and were switched on at 22:01 & 23:17 respectively.										
Deputy / Asstt. Manager Network Operation Division			Manager Network Operation Division			Deputy General Manager Load Despatch Circle				