POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08 Page -1 Reporting Date: 20-Apr-14 Till now the maximum generation is: 7356 MW at 20:00 Hrs 30-Mar-14 The Summary of Yesterday's (19-Apr-14 **Generation & Demand** Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 6207.0 MW Hour: 12:00 Min. Gen. at 7:00 5852 Evening Peak Generation 6686.0 MW 20:00 Max Generation 7104 MW Hour: E.P. Demand (at gen end) 7100.0 MW Hour: 20:00 Max Demand 7100 MW Maximum Generation 6868.0 MWHour: Check Shortage MW -4 Total Gen. (MKWH) 152.7 System L/ Factor 78 37% Load Shed 0 MW EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MKWHR. 200 MW at 16:00 Energy 7.867 MKWHR. Import from West grid to East grid :- Maximum MW at Energy Water Level of Kaptai Lake at 6:00 A M on 20-Apr-14 Actual 87.64 Ft.(MSL) Rule curve 84.20 Ft.(MSL) 929.09 MMCFD Oil Consumed (PDB): Gas Consumed: Total HSD Liter FO Liter Tk83.731.613 Cost of the Consumed Fuel (PDB+Pvt): Coal Tk16.249.590 Oil : Tk625.585.638 Total: Tk725.566.842 **Load Shedding & Other Information** Area Today Yesterday Estimated Demand(s/s end) Estimated Shedding (s/s end) Rates of Shedding from MW MW MW (On Estimated Demand) Dhaka 0:00 2591 Chittagong Area 72 0:00 670 Khulna Area 80 0:00 734 Rajshahi Area 75 709 0:00 Comilla Area 54 0:00 487 Mymensingh Area 40 0.00 399 Sylhet Area 0.00 325 Barisal Area 13 0:00 144 Rangpur Area 41 0:00 408 Total 0 6467 0 Information of the Generating machines under shut down. Planned Shut- Down Forced Shut- Down 1) Haripur SBU GT-3 (18/06/09) 1) Ghorasal #6 (18/07/10) 9) Ghorasal #2 (17/04/2014) 2) Khulna-60MW (24/1/12) 3) Shahiibazar #5 & 6 (21/7/11) 4) WMPL #1(1/5/12) 5) WMPI #2(24/4/13) 6) Ashuganj GT-1(CCPP) (06/01/14) 7) Khulna-110 MW (17/04/2014) 8) Ashuganj #2(19/04/2014) Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description Forced load shaded / Interrupted Areas a) Rampura-Ghorashal 230 kV Ckt-1 was shut down from 09:10 to 17:35 due to red hot maintenance work at Ghorashal end. b) After installtion works Niamatour capacitor bank unit-3 was switched on 11:41. c) Ashugani-Ghorashal 132 kV Ckt-1 & 2 tripped at 12:44 showing distance relay from both end and were switched on 13:15, 13:16 respectively. At the same time Ashuganj united power, Agreeko, Midland,

- Ashuganj ST #2, B. Baria 70 MW, Shahjibazar 50 MW tripped and Ashuganj united power, Ashuganj Agreeko, B. Baria 70 MW, Shahjibazar 50 MW were synchronized on 13:01, 18:10, 13:15, 12:55 respectively. Ashuganj-Midland P/P 230 kV Ckt-1 trial given at 14:47 & failed and Ashuganj-Comilla (N) 230 kV Ckt-2, Ashuganj-Serajganj 230 kV Ckt-1 & 2, Ashuganj-Ghorashal 230 kV Ckt-1, Ashuganj 230/132 kV OAT 11, Ashuganj united power, Ashuganj ST #5, Ashuganj 50 MW TSK, Ashuganj 230 kV bus coupler tripped and were switched/synchronized on 15:13, 15:16, 15:22, 15:17, 15:27, 16:06, 17:39, 15:50, 15:15 respectively.
- d) Haripur-Madanganj 132 kV Ckt tripped at 15:21 showing over current relay from both end and was switched on 15:38. At the same time Madanganj 102 MW P/P tripped due to breaker problem at Madanganj S/S end and was synchronized on 16:35.
- e) Chandpur 150 MW tripped at 20:18 due to GBC pressure high and GT & ST were synchronized on 23:25, 00:43(20/04/2014).
- f) After maintenance Faridpur-Madaripur 132 kV Ckt-1 was switched on 21:09.
- g) Daudkandi-Comilla (N) 132 kV Ckt-1 & 2 tripped at 20:12 showing distance & over current relay at Daudkandi end and distance A & B, over current relay at Comilla (N) end and Ckt-1 was switched on 21:48

Deputy / Asstt. Manager Network Operation Division

Manager

Network Operation Division

About 165 MW power interruption occurred under Madanganj, Munshiganj, Sitalakhya S/S areas from 15:21 to 15:38.

> Deputy General Manager Load Despatch Circle