

Till now the maximum generation is :-									
The Summary of Yesterday's (		23-Apr-14	7356 MW		20:00	Hrs on 30-Mar-14		Reporting Date : 24-Apr-14	
Day Peak Generation :		6063.0	MW	Hou	11:00	Today's Actual Min Gen. & Probable Gen. & Demand			
Evening Peak Generation :		6776.0	MW	Hou	21:00	Min. Gen. at 7:00		5969	MW
E.P. Demand (at gen end) :		7300.0	MW	Hou	21:00	Max Generation :		6905	MW
Maximum Generation :		6776.0	MW	Hou	21:00	Max Demand :		7300	MW
Total Gen. (MKWH) :		147.3	System L/ Factor :	78.37%		Shortage :		395	MW
						Load Shed :		358	MW
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum		30	MW	at	16:00	Energy		7.867	MKWHR.
Import from West grid to East grid :- Maximum		-	MW	at	-	Energy		-	MKWHR.
Water Level of Kaptai Lake at 6:00 A M on 24-Apr-14									
Actual :		87.64	Ft.(MSL) ,		Rule curve :		83.40		Ft.( MSL )
Gas Consumed : Total		926.84		MMCFD.		Oil Consumed (PDB) :			
						HSD :		Liter	
						FO :		Liter	
Cost of the Consumed Fuel (PDB+Pvt) : Gas : Tk86,670,809									
Coal : Tk16,523,023 Oil : Tk601,771,241 Total : Tk704,965,073									
Load Shedding & Other Information									
Area									
Yesterday									
MW									
Estimated Demand(s/s end)									
MW									
Today									
Estimated Shedding (s/s end)									
MW									
Rates of Shedding (On Estimated Demand)									
Dhaka 225 (09:00-01:00) 2625 114 -									
Chittagong Area 52 (09:00-01:00) 690 43 -									
Khulna Area 53 (09:00-01:00) 755 46 -									
Rajshahi Area 47 (09:00-01:00) 731 45 -									
Comilla Area 23 (09:00-01:00) 500 29 -									
Mymensingh Area 25 (09:00-01:00) 412 25 -									
Sylhet Area 18 (09:00-01:00) 336 20 -									
Barisal Area 12 (09:00-01:00) 149 9 -									
Rangpur Area 17 (09:00-01:00) 423 27 -									
- - - - -									
Total 472 6621 358									
Information of the Generating machines under shut down.									
Planned Shut- Down									
1) Haripur SBU GT-3 (18/06/09)									
Forced Shut- Down									
1) Ghorasal #6 (18/07/10)									
2) Khulna-60MW (24/1/12)									
3) Shahjibazar #5 & 6 (21/7/11)									
4) WMPL #1(1/5/12)									
5) WMPL #2(24/4/13)									
6) Ashuganj GT-1(CCPP) (06/01/14)									
7) Meghnaghat 450MW									
Additional Information of Machines. lines. Interruption / Forced Load shed etc.									
Description									
Forced load shaded / Interrupted Areas									
a) Baghabari-100 MW tripped at 11:05 showing gas control valve problem and was sync.at 12:24.									
b) Madaripur 132/33 kV T1, T2 & T3 transformers tripped at 08:35 showing O/C relay and were sw on at 08:45.									
c) Haripur 132 kV main Bus shut down at 09:38 due to red hot maintenance and was switched on at 16:45.									
d) Maghbazar 132/33 kV T1, T2 & T3 transformers showing O/C relay and were switched on at 11:25.									
e) Ghorasal #2 tripped at 16:25 due to feed water pump trip and was synchronized at 18:47.									
f) Comilla(S) 132/33 kV T1 transformer was shut down at 17:12 due to red hot maintenance and was switched on at 17:52.									
g) Haripur 132 kV reserve Bus was shut down at 17:28 due to red hot maintenance at circuit breaker and was switched on at 21:42.									
h) Bashundhara-Rampura 132 kV Ckt-1 was shut down at 15:35 due to red hot maintenance at Y-phase connector and was switched on at 16:30.									
Deputy / Asstt. Manager									
Network Operation Division									
Manager									
Network Operation Division									
Deputy General Manager									
Load Despatch Circle									