

Till now the maximum generation is :-				7356 MW		20:00		Hrs on 30-Mar-14		Reporting Date : 25-Apr-14	
The Summary of Yesterday's (24-Apr-14		Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :		5971.0		MW		Hou 9:00		Min. Gen. at 7:00		5755 MW	
Evening Peak Generation :		6690.0		MW		Hou 20:00		Max Generation :		6900 MW	
E.P. Demand (at gen end) :		7300.0		MW		Hou 20:00		Max Demand :		7100 MW	
Maximum Generation :		6690.0		MW		Hou 20:00		Shortage :		200 MW	
Total Gen. (MKWH) :		145.8		System L/ Factor :		78.37%		Load Shed :		180 MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				60		MW at 10:00		Energy		7.867 MKWHR.	
Import from West grid to East grid :- Maximum				-		MW at -		Energy		- MKWHR.	
Water Level of Kaptai Lake at 6:00 A M on 25-Apr-14											
Actual :		87.64		Ft.(MSL) ,		Rule curve :		83.20		Ft.(MSL)	
Gas Consumed : Total		932.23		MMCFD.		Oil Consumed (PDB) :		HSD : Liter		FO : Liter	
Cost of the Consumed Fuel (PDB+Pvt) : Gas : Tk89,652,267											
Coal :				Tk16,054,286		Oil : Tk561,900,170		Total :		Tk667,606,722	
Load Shedding & Other Information											
Area	Yesterday			Estimated Demand(s/s end)		Today		Estimated Shedding (s/s end)		Rates of Shedding (On Estimated Demand)	
	MW			MW		MW		MW			
Dhaka	140	(09:00-05:42)		2532				44		-	
Chittagong Area	77	(09:00-04:00)		668				27		-	
Khulna Area	82	(09:00-03:00)		730				29		-	
Rajshahi Area	78	(09:00-05:39)		707				28		-	
Comilla Area	54	(09:00-05:37)		487				20		-	
Mymensingh Area	24	(09:00-05:36)		400				16		-	
Sylhet Area	32	(09:00-05:38)		313				-		-	
Barisal Area	14	(09:00-03:00)		139				-		-	
Rangpur Area	48	(09:00-05:39)		409				16		-	
	-										
Total	549			6385				180			
Information of the Generating machines under shut down.											
	Planned Shut- Down					Forced Shut- Down					
	1) Haripur SBU GT-3 (18/06/09)					1) Ghorasal #6 (18/07/10) 2) Khulna-60MW (24/1/12) 3) Shahjibazar #5 & 6 (21/7/11) 4) WMPL #1(1/5/12) 5) WMPL #2(24/4/13) 6) Ashuganj GT-1(CCPP) (06/01/14) 7) Meghnaghat 450MW					
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description							Forced load shaded / Interrupted Areas				
a) Shahjibazar 50 MW tripped at 12:56 due to lightning arrester break and was synchronized at 13:32.											
b) After maintenance Hasnabad 132/33 kV T2 transformer switched on at 18:26.											
c) Joydevpur-Ghorasal 132 kV Ckt-1 & 2 tripped at 05:47 (25/04/14) due to red phase main bus PT at Kabirpur S/S and were switched on at 06:05 (25/04/14).							Power interruption occurred (about 150 MW) under Joydevpur & Kabirpur S/S areas from 05:47 to 06:05.				
d) Bakulia-Sikalbaha 132 kV Ckt-1 tripped at 06:15 (25/04/14) from both end showing O/C & E/F relay at Bakulia end and was switched on at 06:47(25/04/14).											
e) Halishahar 132/33 kV T3 transformer was under shut down from 07:02 to 10:55 (25/04/14) due to painting works.											
f) Tongi-Kabirpur 132 kV Ckt-1 & 2 tripped at 06:23 (25/04/14) showing dist.relay and were switched at 06:34 (25/04/14). At the same time Tongi GT tripped showing Backup protection relay and was switched on at 06:42 (25/04/14).							Power interruption occurred (about 130 MW) under Tangail & Manikganj S/S areas from 06:23 to 06:34 (25/04/2014).				
Deputy / Asstt. Manager Network Operation Division			Manager Network Operation Division			Deputy General Manager Load Despatch Circle					