

Till now the maximum generation is :-				7356 MW		20:00		Hrs on		Reporting Date : 4-May-14	
The Summary of Yesterday's (		3-May-14		Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	5395.0	MW	Hour :	12:00	Min. Gen. at	6:00	4224	MW			
Evening Peak Generation :	6051.0	MW	Hour :	20:00	Max Generation :		6975	MW			
E.P. Demand (at gen end) :	6051.0	MW	Hour :	20:00	Max Demand :		6900	MW			
Maximum Generation :	6051.0	MW	Hour :	20:00	Shortage :		-75	MW			
Total Gen. (MKWH) :	125.5	System L/ Factor	:	78.37%	Load Shed	:	0	MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				200	MW	at	13:00	Energy	7.867	MKWHR.	
Import from West grid to East grid :- Maximum				-	MW	at	-	Energy	-	MKWHR.	
Water Level of Kaptai Lake at 6:00 A M on 4-May-14											
Actual :		87.64	Ft.(MSL) ,		Rule curve :		81.43	Ft.( MSL )			
Gas Consumed : Total		887.04	MMCFD.		Oil Consumed (PDB) :		HSD :		Liter		
							FO :		Liter		
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk74,156,952								
		Coal :	Tk15,155,868		Oil :		Tk237,568,608	Total :		Tk326,881,429	
Load Shedding & Other Information											
Area	Yesterday		Estimated Demand(s/s end)				Today		Rates of Shedding		
	MW		MW				Estimated Shedding (s/s end)		(On Estimated Demand)		
							MW				
Dhaka	-	0:00	2578				-		-		
Chittagong Area	-	0:00	666				-		-		
Khulna Area	-	0:00	730				-		-		
Rajshahi Area	-	0:00	705				-		-		
Comilla Area	-	0:00	484				-		-		
Mymensingh Area	-	0:00	397				-		-		
Sylhet Area	-	0:00	323				-		-		
Barisal Area	-	0:00	144				-		-		
Rangpur Area	-	0:00	406				-		-		
	-										
Total	0		6433				0				
Information of the Generating machines under shut down.											
Planned Shut- Down		Forced Shut- Down									
1) Haripur SBU GT-3 (18/06/09)		1) Ghorasal #6 (18/07/10)					9) Fenchuganj CCPP old #1 (30/04/2014)				
		2) Khulna-60MW (24/1/12)					10) Haripur EGCB 412MW ST(01/05/14)				
		3) Shahjibazar #5 & 6 (21/7/11)									
		4) WMPL #1(1/5/12)									
		5) WMPL #2(24/4/13)									
		6) Ashuganj GT-1(CCPP) (06/01/14)									
		7) Meghnaghat 450MW(21/04/2014)									
		8) Khulna 110 MW (29/04/2014)									
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description						Forced load shaded / Interrupted Areas					
a) Ashuganj #3 tripped at 09:35 showing PRD relay and was synchronized on 17:50.						Power interruption occurred (about 5 MW) under Patuakhali S/S areas from 16:16 to 21:15.					
b) Mymensingh-Kishoreganj 132 kV Ckt-1 was shut down from 10:35 to 12:25 due to project work.											
c) Chandpur GT 150 MW was shut down at 12:11 due to GBC tripped and was synchronized at 15:18.											
Again tripped at 16:19 and was synchronized at 17:35.											
d) Khulna @-Noapara 132 kV Ckt-2 was shut down from 10:58 to 11:59 due to for removing kites.											
e) Patuakhali-Barisal 132 kV Ckt tripped at 16:16 showing over current & earth fault relay at Barisal end and was switched on 21:15.											
f) Thakurgaon 132/33 kV T2 transformer tripped at 15:22 due to 33 kV lightning arrester burst at 33 kV end and was switched on 15:34.											
g) Comilla (N)-Chandpur 132 kV Ckt tripped at 16:12 showing distance B & C phase relay & directional over current relay from both end and was switched on 16:38.											
h) Chowmohani-Chandpur 132 kV Ckt-1 & 2 tripped at 16:19 showing over current relay at Chowmohani end and were switched on 16:30.											
i) Halishahar-Kulshi 132 kV Ckt-1 tripped at 16:30 showing over current relay at Halishahar end and was switched on at 17:03.											
k) Mymensingh-Kishoreganj 132 kV Ckt-1 tripped at 18:29 showing over current 3-phase relay at Mymensingh end and was switched on 19:27.											
l) HVDC Bheramara was shut down from 15:34 to 17:41 due to tearing of sky wire.											
N. B: Yesterday demand had low due to nor wester.											
Sub Divisional Engineer			Executive Engineer			Superintendent Engineer			Load Despatch Circle		