

Till now the maximum generation is :-										7356 MW		20:00		Hrs on 30-Mar-14		Reporting Date : 10-May-14																																	
The Summary of Yesterday's (9-May-14		Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand																																	
Day Peak Generation :										5025.0		MW		Hou		12:00		Min. Gen. at 7:00		5315 MW																													
Evening Peak Generation :										6527.0		MW		Hou		21:00		Max Generation :		6700 MW																													
E.P. Demand (at gen end) :										6700.0		MW		Hou		21:00		Max Demand :		6900 MW																													
Maximum Generation :										6527.0		MW		Hou		21:00		Shortage :		200 MW																													
Total Gen. (MKWH) :										130.9		System L/ Factor :		78.37%		Load Shed :		182		MW																													
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR																																																	
Export from East grid to West grid :-										Maximum		-220		MW		at		13:00		Energy 7.867																													
Import from West grid to East grid :-										Maximum		-		MW		at		-		Energy - MKWHR. MKWHR.																													
Water Level of Kaptai Lake at 6:00 A M on 10-May-14																																																	
Actual :										87.64		Ft.(MSL) ,		Rule curve :		80.22		Ft.(MSL)																															
Gas Consumed : Total										912.43		MMCFD.		Oil Consumed (PDB) :				HSD : Liter		FO : Liter																													
Cost of the Consumed Fuel (PDB+Pvt) :										Gas :		Tk78,064,657																																					
										Coal :		Tk6,679,520		Oil :		Tk385,333,289		Total : Tk470,077,466																															
Load Shedding & Other Information																																																	
Area										Yesterday										Today																													
										MW										Estimated Demand(s/s end)										Estimated Shedding (s/s end)										Rates of Shedding (On Estimated Demand)									
										MW										MW										MW																			
Dhaka										-										2444										-										-									
Chittagong Area										27 (19:00 to 21:00)										665										36										-									
Khulna Area										31 (19:00 to 21:00)										727										39										-									
Rajshahi Area										28 (19:00 to 21:00)										700										33										-									
Comilla Area										19 (19:00 to 21:00)										481										22										-									
Mymensingh Area										15 (19:00 to 21:00)										400										22										-									
Sylhet Area										15 (19:00 to 21:00)										308										-										-									
Barisal Area										5 (19:00 to 21:00)										145										8										-									
Rangpur Area										16 (19:00 to 21:00)										409										22										-									
Total										156										6279										182																			
Information of the Generating machines under shut down.																																																	
										Planned Shut- Down										Forced Shut- Down																													
										1) Haripur SBU GT-3 (18/06/09)										1) Ghorasal #6 (18/07/10) 9) Fenchuganj CCPP old #1 (30/04/2014) 2) Khulna-60MW (24/1/12) 10) Khulna-110(7/5/14) 3) Shahjibazar #5 & 6 (21/7/11) 11) Ghorasal # 3(8/5/14) 4) WMPL #1(1/5/12) 12) Barapukuria #1 (5/5/14) 5) WMPL #2(24/4/13) 6) Ashuganj GT-1(CCPP) (06/01/14) 7) Meghnaghat 450MW(21/04/2014) 8) Fenchuganj CCPP old #1 (30/04/2014)																													
Additional Information of Machines. lines. Interruption / Forced Load shed etc.																																																	
Description										Forced load shaded / Interrupted Areas																																							
a) Faridpur S/S-Faridpur P/S 132 kV Ckt was shut down from 08:52 to 11:56 due to project works.																																																	
b) Hasnabad-Aminbazar 230 kV Ckt-1 tripped at 10:51 from Hasnabad end showing over current & earth fault relay and was switched on at 11:12.																																																	
c) After maintenance Agargaon-Aminbazer 230 kV Ckt-1 switched on at 10:54 at the same time trip Ckt-1 & Ckt-2 showing differential & Z1 relay at Ckt-1, and Ckt-2 showing no relay. and were swit from 10:54 to 11:04 at 11:04.										About 59 MW power interruption occurred under Basantak S/S areas																																							
d) Chatak 132/33 kV T1 transformer tripped at 15:32 showing over current relay from both sides and was switched on at 15:38 .																																																	
e) After maintenance Mirpur-Tongi 132 kV Ckt was charged from Tongi end at 16:51.																																																	
f) After maintenance Mirpur-Uttara 132 kV Ckt was charged from Mirpur end at 16:58.																																																	
g) AES Haripur 360 MW tripped at 00:32(10/05/14)due to auxiliary supply failure and GT was synchronized . at 08:27																																																	
h) Jamalpur-Mymenshing 132 kV Ckt 1 & 2 were under shut down from 05:14 to 10:05(10/05/14) due to disk Isolator replacement.										About 85 MW power interruption occurred under Jamalpur S/S areas from 05:14 to 10:05(10/05/14).																																							
i) Kaptai-Madhonahat 132 kV Ckt-1 was shut down at 07:24 (10/05/14) due to disk Isolator replacement. at tower # 907.																																																	
Sub Divisional Engineer										Executive Engineer										Superintendent Engineer																													
Network Operation Division										Network Operation Division										Load Despatch Circle																													