POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date: 27-May-14 Till now the maximum generation is:

The Summary of Yesterday's (2
Day Peak Generation :
Evening Peak Generation :
E.P. Demand (at gen end) : 7356 MW 20:00 Hrs Generation & Demand
MW
MW
MW Today's Actual Min Gen. & Prot Min. Gen. at 7:00 Max Generation : Gen. & Dema 26-May-14 5894.0 6660.0 Hour : 4634 7088 21:00 21:00 6660.0 Hour Max Demand 6900 21:00 Maximum Generation 6660.0 MW Hour: Shortage -188 135.5 System L/ Factor : /8.3 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Total Gen. (MKWH) Load Shed Export from East grid to West grid :- Maximum Energy 7.867 Import from West grid to East grid :- Maximum - Water Level of Kaptai Lake at 6:00 A M on MW Energy 27-May-14 Actual : 87.64 Ft.(MSL) 77.00 Ft.(MSL) Gas Consumed : Total 902.00 Oil Consumed (PDB) : HSD FO Tk86,849,831 Cost of the Consumed Fuel (PDB+Pvt) : Gas Total : Tk487,240,292 Coal Tk8,320,104 Oil : Tk392,070,358 Load Shedding & Other Information Area Yesterday Today Estimated Demand(s/s end) Estimated Shedding (s/s end) Rates of Shedd MW (On Estimated D Dhaka Chittagong Area Khulna Area 0:00 677 Rajshahi Area 0:00 716 Comilla Area 492 0:00 403 Mymensingh Area 328 145 Sylhet Area 0:00 Barisal Area 0:00 Rangpur Area 0:00 412 Total 0 6532 Information of the Generating machines under shut down. Planned Shut- Down Forced Shut-Down 1) Ghorasal #6 (18/07/10) 2) Khulna-60MW (24/1/12) 3) Shahjibazar #5 & 6 (21/7/11) 9) Khulna 110 MW (15/05/2014) 10) B. Pukuria #1 (25/05/2014) 11) Sikalbaha 150 MW (26/05/2014) 4) WMPL #1(1/5/12) 5) WMPL #2(24/4/13) 6) Ashuganj GT-1(CCPP) (06/01/14) 7) Meghnaghat 450MW(21/04/2014) 8) Ghorasal #3 (08/05/2014) Additional Information of Machines. lines. Interruption / Forced Load shed etc. Forced load shaded / Interrupted Areas a) Demand has been reduced yesterday due to rain & storm all over the country.

b) After maintenance Haripur EGCB was synchronized at 10:41.

c) Bheramara HVDC capacitor bank at 400 kV end was shut down at 10:58 due to maintenance work of Defaultial First Capacitor bank at 400 kV end was shut down at 10.30 due to maintenance wo and was switched on at 13.05.

Comilla (N)-Daudkandi 132 kV Ckt-2 was shut down at 10.44 due to maintenance work and was switched on at 14:35. e) Gazipur RPCL tripped at 14:25 due to tripping of 33 kV feeder and was switched on at 15:12. e) Gazipur RPCL tripped at 14:25 due to tripping of 33 kV feeder and was switched on at 15:12. () Chapainawabagan (12/33 kV T4 transformer tripped at 14:37 showing E/F relay and was switched on at 16:40. g) Mymensingh 132/33 kV T2 transformer was shut down at 16:55 due to red hot maintenance at bus loop and was switched on at 17:20. h) After maintenance Ashuganj Midland was synchronized on at 20:20. h) After maintenance Ashuganj Midland was synchronized on at 20:40 due to 33 kV bus maintenance and was switched on at 20:50. About 25 MW power interruption occurred under Mymensingh S/S area from 16:55 to 17:20. About 45 MW power interruption occurred under Kamrangirchar S/S are from 20:40 to 20:50. Ashuganj-Ghorasal 132 kV Ckt-1 was shut down from 06:11(27/05/2014) to 11:07(27/05/2014) due to insulator replace.

Sub Divisional Engineer Executive Engineer Network Operation Division

Superintendent Engineer Load Despatch Circle