

Till now the maximum generation is :-			7356 MW	20:00	Hrs on 30-Mar-14		Reporting Date : 1-Jun-14		
The Summary of Yesterday's (31-May-14			Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand				
Day Peak Generation :	4565.0	MW	Hou	12:00	Min. Gen. at	6:00	4297	MW	
Evening Peak Generation :	6413.0	MW	Hou	20:00	Max Generation :		7012	MW	
E.P. Demand (at gen end) :	6413.0	MW	Hou	20:00	Max Demand :		6800	MW	
Maximum Generation :	6413.0	MW	Hou	20:00	Shortage :		-212	MW	
Total Gen. (MKWH) :	121.2	System L/ Factor		78.37%	Load Shed :		0	MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum			260	MW	at	10:00	Energy	7.867	MKWHR.
Import from West grid to East grid :- Maximum			-	MW	at	-	Energy	-	MKWHR.
Water Level of Kaptai Lake at 6:00 A M on 1-Jun-14									
Actual :	87.64	Ft.(MSL) ,	Rule curve :		76.00	Ft.(MSL)			
Gas Consumed : Total		881.29	MMCFD.		Oil Consumed (PDB) :				
					HSD :		Liter		
					FO :		Liter		
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk72,483,578						
		Coal :	Tk16,601,147		Oil :	Tk209,219,624	Total :	Tk298,304,349	
Load Shedding & Other Information									
Area	Yesterday		Estimated Demand(s/s end)		Today		Rates of Shedding		
	MW		MW		Estimated Shedding (s/s end) MW		(On Estimated Demand)		
Dhaka	-	0.00	2397		-		-		
Chittagong Area	-	0.00	615		-		-		
Khulna Area	-	0.00	673		-		-		
Rajshahi Area	-	0.00	653		-		-		
Comilla Area	-	0.00	449		-		-		
Mymensingh Area	-	0.00	371		-		-		
Sylhet Area	-	0.00	302		-		-		
Barisal Area	-	0.00	134		-		-		
Rangpur Area	-	0.00	380		-		-		
Total	0		5974		0				
Information of the Generating machines under shut down.									
Planned Shut- Down			Forced Shut- Down						
1) Haripur SBU GT-3 (18/06/09)			1) Ghorasal #6 (18/07/10)				9) Khulna 110 MW (15/05/2014)		
			2) Khulna-60MW (24/1/12)				10) Ashuganj #3(28/5/14)		
			3) Shahjibazar #5 & 6 (21/7/11)				11) Sikalbaha 150 MW (26/05/2014)		
			4) WMPL #1(1/5/12)						
			5) WMPL #2(24/4/13)						
			6) Ashuganj GT-1(CCPP) (06/01/14)						
			7) Meghnaghat 450MW (21/04/2014)						
			8) Ghorasal #3 (08/05/2014)						
Additional Information of Machines. lines. Interruption / Forced Load shed etc.									
Description					Forced load shaded / Interrupted Areas				
a) Due to rain & storm less system demand observed yesterday all over the country.					About 22 MW power interruption occurred under Satkhira S/S areas from 08:53 to 22:58.				
b) Dohazari 132/33 kV T2 transformer was shut down from 08:35 to 14:30 due to oil change.									
c) Khulna (S)-Satkhira 132 kV Ckt tripped at 08:53 showing distance relay from Khulna end and was switched on 22:58.									
d) Aminbazar 230 kV bus-1 was shut down from 09:35 to 18:30 due to busbar protection.									
e) Tongi-Aminbazar 230 kV Ckt-1 was shut down from 10:00 to 18:15 due to protection work.									
f) Bheramara-Ishurdi 132 kV Ckt-2 was shut down from 11:36 to 16:08 due to red hot maintenance work at Ishurdi end.									
g) Tongi-Ghorasal 230 Ckt-1 tripped at 14:39 showing CBFT relay from Ghorasal end and was switched on at 16:35.									
h) After maintenance Fenchuganj GT-2 was synchronized on at 16:07.									
i) Meghnaghat-Hasnabad 230 kV Ckt-2 was shut down from 06:40(01/06/2014) to due to red hot maintenance work at Meghnaghat end.									
Sub Divisional Engineer Network Operation Division		Executive Engineer Network Operation Division			Superintendent Engineer Load Despatch Circle				