

POWER GRID COMPANY OF BANGLADESH LTD.										QF-LDC-08	
NATIONAL LOAD DESPATCH CENTER										Page -1	
DAILY REPORT											
Reporting Date : 4-Jun-14											
Till now the maximum generation is :-			7356 MW		20:00		Hrs on 30-Mar-14				
The Summary of Yesterday's ( 3-Jun-14			Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand				
Day Peak Generation :	5729.0	MW	Hour :	12:00	Min. Gen. at	7:00	5238	MW			
Evening Peak Generation :	6620.0	MW	Hour :	21:00	Max Generation :		6605	MW			
E.P. Demand (at gen end) :	6900.0	MW	Hour :	21:00	Max Demand :		6950	MW			
Maximum Generation :	6620.0	MW	Hour :	21:00	Shortage :		345	MW			
Total Gen. (MKWH) :	137.1	System L/ Factor :		78.37%	Load Shed :		298	MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				40	MW	at	12:00	Energy	7.867	MKWHR.	
Import from West grid to East grid :- Maximum				-	MW	at	-	Energy	-	MKWHR.	
Water Level of Kaptai Lake at 6:00 A M on 4-Jun-14											
Actual :		87.64	Ft.(MSL) ,		Rule curve :		76.78	Ft.( MSL )			
Gas Consumed : Total 869.32 MMCFD. Oil Consumed (PDB) :											
HSD : Liter											
FO : Liter											
Cost of the Consumed Fuel (PDB+Pvt) : Gas : Tk77,925,664											
Coal : Tk14,648,071 Oil : Tk439,935,801 Total : Tk532,509,536											
Load Shedding & Other Information											
Area	Yesterday			Estimated Demand(s/s end)			Today			Rates of Shedding	
	MW			MW			Estimated Shedding (s/s end)			(On Estimated Demand)	
							MW				
Dhaka	70	(18:45-22:15)		2360			67			-	
Chittagong Area	31	(18:45-22:15)		626			40			-	
Khulna Area	32	(18:45-22:15)		684			44			-	
Rajshahi Area	31	(18:45-22:15)		665			42			-	
Comilla Area	34	(18:45-22:15)		458			29			-	
Mymensingh Area	30	(18:45-22:15)		380			24			-	
Sylhet Area	15	(18:45-22:15)		309			19			-	
Barisal Area	7	(18:45-22:15)		137			8			-	
Rangpur Area	30	(18:45-22:15)		390			25			-	
	-										
Total	280			6009			298				
Information of the Generating machines under shut down.											
	Planned Shut- Down					Forced Shut- Down					
	1) Haripur SBU GT-3 (18/06/09)					1) Ghorasal #6 (18/07/10) 9) Khulna 110 MW (15/05/2014) 2) Khulna-60MW (24/1/12) 10) Ashuganj ST #3(28/05/2014) 3) Shahjibazar #5 & 6 (21/7/11) 11) Sikalbaha 150 MW (26/05/2014) 4) WMPL #1(1/5/12) 12) Ashuganj ST #1(02/06/2014) 5) WMPL #2(24/4/13) 13) Ghorasal #5(3/6/14) 6) Ashuganj GT-1(CCPP) (06/01/14) 7) Meghnaghat 450MW (21/04/2014) 8) Ghorasal #3 (08/05/2014)					
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description						Forced load shaded / Interrupted Areas					
a) There was generation shortage in the evening peak hour yesterday. b) Jamalpur 132/33 kV T2 transformer was shut down at 08:04 due to red hot maintenance at B-phase CT loop and was switched on at 08:45. c) Ashuganj #5 tripped at 10:46 showing DCS and was synchronized at 13:37. d) After maintenance AES Haripur was synchronized at 11:15. e) Ghorasal #5 tripped at 18:05 showing furnace pressure high. f) Haripur EGCB ST tripped at 06:41(4/6/14) due to steam temperature high.						So about 254 MW (21:00) of load shed was imposed over the whole areas.					
Sub Divisional Engineer Network Operation Division						Executive Engineer Network Operation Division					
						Superintendent Engineer Load Despatch Circle					