

Till now the maximum generation is :-										7356 MW		20:00		Hrs on 30-Mar-14		Reporting Date : 5-Jun-14																																											
The Summary of Yesterday's ( 4-Jun-14										Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand																																													
Day Peak Generation :										5716.0		MW		Hour :		11:00		Min. Gen. at 6:00		5337 MW																																							
Evening Peak Generation :										6717.0		MW		Hour :		20:00		Max Generation :		6705 MW																																							
E.P. Demand (at gen end) :										6900.0		MW		Hour :		20:00		Max Demand :		6900 MW																																							
Maximum Generation :										6717.0		MW		Hour :		20:00		Shortage :		195 MW																																							
Total Gen. (MKWH) :										141.2		System L/ Factor		:		78.37%		Load Shed :		182 MW																																							
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR																																																											
Export from East grid to West grid :- Maximum										164		MW		at		10:00		Energy		7.867																																							
Import from West grid to East grid :- Maximum										-		MW		at		-		Energy		-																																							
Water Level of Kaptai Lake at 6:00 A M on 5-Jun-14																																																											
Actual :										87.64		Ft.(MSL) ,		Rule curve :		77.04		Ft.( MSL )																																									
Gas Consumed : Total										863.97		MMCFD.		Oil Consumed (PDB) :				HSD :		Liter																																							
																		FO :		Liter																																							
Cost of the Consumed Fuel (PDB+Pvt) :										Gas :		Tk86,284,828																																															
										Coal :		Tk16,210,530		Oil :		Tk512,663,717		Total :		Tk615,159,075																																							
Load Shedding & Other Information																																																											
Area										Yesterday										Today																																							
										MW										Estimated Demand(s/s end)										Estimated Shedding (s/s end)										Rates of Shedding (On Estimated Demand)																			
										MW										MW										MW																													
Dhaka										-										2511										-										-																			
Chittagong Area										31										(19:45-00:05)										682										35										-									
Khulna Area										35										(19:45-00:05)										745										36										-									
Rajshahi Area										32										(19:45-00:05)										722										36										-									
Comilla Area										24										(19:45-00:05)										494										23										-									
Mymensingh Area										18										(19:45-00:05)										410										22										-									
Sylhet Area										-										0.00										316										-										-									
Barisal Area										6										(19:45-00:05)										148										8										-									
Rangpur Area										19										(19:45-00:05)										419										22										-									
										-																																																	
Total										165										6447										182																													
Information of the Generating machines under shut down.																																																											
										Planned Shut- Down										Forced Shut- Down																																							
										1) Haripur SBU GT-3 (18/06/09)										1) Ghorasal #6 (18/07/10) 9) Khulna 110 MW (15/05/2014)																																							
																				2) Khulna-60MW (24/1/12) 10) Ashuganj ST #3(28/05/2014)																																							
																				3) Shahjibazar #5 & 6 (21/7/11) 11) Sikalbaha 150 MW (26/05/2014)																																							
																				4) WMPL #1(1/5/12) 12) Ashuganj ST #1(02/06/2014)																																							
																				5) WMPL #2(24/4/13) 13) Ghorasal #5(3/6/14)																																							
																				6) Ashuganj GT-1(CCPP) (06/01/14)																																							
																				7) Meghnaghat 450MW (21/04/2014)																																							
																				8) Ghorasal #3 (08/05/2014)																																							
Additional Information of Machines. lines. Interruption / Forced Load shed etc.																																																											
Description										Forced load shaded / Interrupted Areas																																																	
a) There was generation shortage in the evening peak hour yesterday.										So about 165 MW (20:00) of load shed was imposed over the whole areas (except Dhaka & Sylhet) of the national grid .																																																	
b) After maintenance Haripur EGCB 412 MW was switched on at 09:47.																																																											
c) After maintenance Ishurdi 132/33 kV T1 transformer was switched on at 11:57.																																																											
d) After maintenance Rampura 230/132 kV T1 transformer was switched on at 12:44.																																																											
e) Siddhirganj 132/33 kV T2 tripped at 14:48 showing winding tempertature high signal and was switched on at 15:49.																																																											
f) Siddhirganj 132/33 kV T1 tripped at 14:48 due to over load and was switched on at 14:49.																																																											
g) Patenga 50 MW RPP tripped at 16:58 and was switched on at 17:10.																																																											
Sub Divisional Engineer										Executive Engineer										Superintendent Engineer																																							
Network Operation Division										Network Operation Division										Load Despatch Circle																																							