

Reporting Date : 13-Jun-14

Till now the maximum generation is :-

7356 MW

20:00

Hrs on 30-Mar-14

The Summary of Yesterday's ( 12-Jun-14			Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation	:	5616.0	MW	Hou	11:00	Min. Gen. at 7:00	4346 MW
Evening Peak Generation	:	6788.0	MW	Hou	20:00	Max Generation	: 6990 MW
E.P. Demand (at gen end)	:	7000.0	MW	Hou	20:00	Max Demand	: 6800 MW
Maximum Generation	:	6788.0	MW	Hou	20:00	Shortage	: -190 MW
Total Gen. (MKWH)	:	140.5	System L/ Factor	:	78.37%	Load Shed	: 0 MW

## EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :-	Maximum	30	MW	at	9:00	Energy	7.867	MKWHR.
Import from West grid to East grid :-	Maximum	-	MW	at	-	Energy	-	MKWHR.

Water Level of Kaptai Lake at 6:00 A M on 13-Jun-14

Actual	:	87.64	Ft.(MSL)	Rule curve	:	79.14	Ft.(MSL)
--------	---	-------	----------	------------	---	-------	----------

Gas Consumed	:	Total	905.37	MMCFD.	Oil Consumed (PDB)	:	
					HSD	:	Liter
					FO	:	Liter

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk86,194,499			
	Coal :	Tk16,288,654	Oil :	Tk499,728,102	Total : Tk602,211,256

## Load Shedding &amp; Other Information

Area	Yesterday		Today		
	MW		Estimated Demand(s/s end) MW	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
Dhaka	72	(18:40:00:50)	2526	-	-
Chittagong Area	22	(18:40:00:50)	651	-	-
Khulna Area	22	(18:40:00:50)	713	-	-
Rajshahi Area	22	(18:40:00:50)	690	-	-
Comilla Area	14	(18:40:00:50)	474	-	-
Mymensingh Area	14	(18:40:00:50)	390	-	-
Sylhet Area	-	0:00	317	-	-
Barisal Area	8	(18:40:00:50)	141	-	-
Rangpur Area	14	(18:40:00:50)	399	-	-
	-			-	-
Total	188		6301	0	

Information of the Generating machines under shut down.

	Planned Shut- Down	Forced Shut- Down
	1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal #6 (18/07/10) 2) Khulna-60MW (24/1/12) 3) Shahjibazar #5 & 6 (21/7/11) 4) WMPL #1(1/5/12) 5) WMPL #2(24/4/13) 6) Ashuganj GT-1(CCPP) (06/01/14) 7) Meghnaghat 450MW (21/04/2014) 8) Ghorasal #3 (08/05/2014)

## Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 188 MW (20:00) of load shed was imposed over the whole areas from of the national grid.
b) Haripur EGC 412 MW was synchronized at 08:34.	
c) Ashuganj-Midland 230 kV Ckt was switched on at 10:33.	
d) Ashuganj Midland 55 MW was synchronized at 11:10.	
e) Fenchuganj GT-1 was synchronized at 10:39.	
f) Palashbari 132/33 kV T4 transformer was shut down from 11:15 to 13:15 due to replacement of T3 by new one.	
g) Barapukuria 132/33 kV T5 transformer was shut down from 13:10 to 13:30.	
h) Bheramara-Faridpur 132 kV Ckt-1 was shut down from 12:57 to 13:58 due to removed tree.	
i) Ashuganj #3 was synchronized at 18:02.	
j) Mymensingh 132/33 kV T3 transformer tripped at 04:30 (13/06/2014) from both end showing E/F O/C relays.	About 15 MW power interruption occurred under Mymensingh S/S areas from 04:30(13/06/14) to till.
k) Baghabari-Shahajadpur 132 kV Ckt-2 tripped at 04:51 from both end showing Dist. Z1, at Shahajadpur end and E/F at Baghabari end and was switched on at 05:16.	
l) Kishoreganj 33 kV Nandial feeder tripped at 01:59(13/06/14) from showing E/F & O/C and was switched on at 03:10(13/06/14).	About 16 MW power interruption occurred under Kishoreganj S/S areas from 01:59 to 03:10(13/06/14).
m) Comilla(S) 132/33 kV T-1 transformer was shut down from 05:20 to 06:45(13/06/14) due to red Maintenance.	About 60 MW power interruption occurred under Comilla S/S areas from 05:20 to 06:45(13/06/14).
n) HVDC Bheramara was shut down at 07:00 due to valve hall epoxy painting at Bheramara end and was synchronized at 09:45(13/06/14).	
o) Ashuganj-Kishoreganj 132 kV Ckt-2 tripped at 07:14 from both end showing Dist. A and was switched on at 08:29.	
p) Shylet 150 MW tripped at 07:21 due to problem at Fenchuganj S/S and was synchronized at 09:06(13/06/14)	
q) Sreemongal-Fenchuganj 132 kV Ckt 1& 2 both tripped at 07:21 from Both end showing Dist A at Sreemongal and E/F Auto recluse. At the same time Shylet 10 MW , Shylet 50 MW, Fenchuganj Prima Fenchuganj Barakatullah, Fenchuganj old & new were tripped.	

Sub Divisional Engineer  
Network Operation DivisionExecutive Engineer  
Network Operation DivisionSuperintendent Engineer  
Load Despatch Circle