

Till now the maximum generation is :-

7356 MW

20:00

Hrs on 30-Mar-14

Reporting Date : 27-Jun-14

The Summary of Yesterday's ( 26-Jun-14		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	6017.0	MW	Hou 12:00	Min. Gen. at 8:00	4703 MW
Evening Peak Generation :	6759.0	MW	Hou 19:30	Max Generation :	6554 MW
E.P. Demand (at gen end) :	6759.0	MW	Hou 19:30	Max Demand :	6500 MW
Maximum Generation :	6825.0	MW	Hou 23:00	Shortage :	-54 MW
Total Gen. (MKWH) :	149.2	System L/ Factor :	78.37%	Load Shed :	0 MW

## EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :-	Maximum	10	MW	at	15:00	Energy	7.867	MKWHR.
Import from West grid to East grid :-	Maximum	-	MW	at	-	Energy	-	MKWHR.

Water Level of Kaptai Lake at 6:00 A M on 27-Jun-14

Actual :	87.64	Ft.(MSL) ,	Rule curve :	82.92	Ft.( MSL )
----------	-------	------------	--------------	-------	------------

Gas Consumed : Total	847.75	MMCFD.	Oil Consumed (PDB) :	
			HSD :	Liter
			FO :	Liter

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk83,939,745		
	Coal :	Tk16,483,963	Oil :	Tk529,960,449
			Total :	Tk630,384,157

## Load Shedding &amp; Other Information

Area	Yesterday		Today	
	MW		Estimated Demand(s/s end)	
Dhaka	-	0.00	2390	-
Chittagong Area	-	0.00	614	-
Khulna Area	-	0.00	671	-
Rajshahi Area	-	0.00	651	-
Comilla Area	-	0.00	448	-
Mymensingh Area	-	0.00	370	-
Sylhet Area	-	0.00	302	-
Barisal Area	-	0.00	134	-
Rangpur Area	-	0.00	379	-
Total	0		5959	0

Information of the Generating machines under shut down.

	Planned Shut- Down	Forced Shut- Down
	1) Haripur SBU GT-3 (18/06/09)	1) Ghorasal #6 (18/07/10) 9) Khulna 110 MW (15/05/2014) 2) Khulna-60MW (24/1/12) 10) Ghorasal #4(16/6/2014) 3) Shahjibazar #5 & 6 (21/7/11) 4) WMPL #1(1/5/12) 5) WMPL #2(24/4/13) 6) Ashuganj GT-1(CCPP) (06/01/14) 7) Meghnaghat 450MW (21/04/2014) 8) Ghorasal #3 (08/05/2014)

## Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) Sylhet-Fenchuganj P/S 132 kV Ckt was shut down from 10:56 to 15:22 due to development work.	
b) Siddirganj-Maniknagar 230 kV Ckt 1 & 2 tripped at 11:10 from both end showing Diff.L3 at Maniknagar end and Dist. SOFT relays at Siddirganj end and was switched on at 14:07, 14:35 respectively.	
c) Siddirganj 230/132 kV T02 transformer tripped at 11:10 showing O/C, E/F relays and was switched on at 14:23	
d) Hathazari-Madunaghat 132 kV Ckt-2 was shut down from 15:10 to 15:18 due to maintenance work.	
e) Mymensingh 132/33 kV T2 transformer was shut down from 15:32 to 18:31 due to maintenance work.	
f) Rampura 33/11 kV transformer tripped at 16:35 showing master trip at 11 kV end and was switched on at 16:50	
g) Bagherhat- Goalpara 132 kv Ckt tripped at 19:55 showing O/C relay for this reason Jessore-Noa About 410 MW power interruption occurred under Bagherhat, Goalpara Ckt-1 & 2, Khulna 150 MW, KPCL-1 & 2, Faridpur P/P tripped and was Bagherhat- Goalpara 132 Jessore,Jhenidah S/S areas from 19:55 to 20:50.	
h) Haripur EGCB 412 MW was shut down at 05:03(27/06/2014) due to changing air filter.	
i) Sylhet 150 MW GT was shut down at 06:23 due to Maintenance work.	

Sub Divisional Engineer  
Network Operation DivisionExecutive Engineer  
Network Operation DivisionSuperintendent Engineer  
Load Despatch Circle