

Till now the maximum generation is :-		7356 MW	20:00	Hrs on 30-Mar-14	Reporting Date : 12-Jul-14
The Summary of Yesterday's (		11-Jul-14	Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand
Day Peak Generation :	5505.0	MW	Hou 10:00	Min. Gen. at 07:00	5685 MW
Evening Peak Generation :	7194.0	MW	Hou 20:00	Max Generation :	7095 MW
E.P. Demand (at gen end) :	7194.0	MW	Hou 20:00	Max Demand :	7350 MW
Maximum Generation :	7194.0	MW	Hou 20:00	Shortage :	255 MW
Total Gen. (MKWH) :	146.5	System L/ Factor :	78.37%	Load Shed :	231 MW
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR					
Export from East grid to West grid :- Maximum		-290	MW at 13:00	Energy	7.867 MKWHR.
Import from West grid to East grid :- Maximum		-	MW at -	Energy	- MKWHR.
Actual :		87.64	Water Level of Kaptai Lake at 6:00 A M on 12-Jul-14	Rule curve :	
Fl.(MSL) ,		85.76	Fl.( MSL )		
Gas Consumed : Total		979.27	MMCFD.	Oil Consumed (PDB) :	
				HSD :	Liter
				FO :	Liter
Cost of the Consumed Fuel (PDB+Pvt) :		Gas : Tk87,186,511			
		Coal : Tk8,163,859	Oil : Tk423,333,873	Total : Tk518,684,243	
Load Shedding & Other Information					
Area	Yesterday		Today		
	MW		Estimated Demand(s/s end) MW	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
Dhaka	-	0.00	2630	60	-
Chittagong Area	-	0.00	694	30	-
Khulna Area	-	0.00	760	32	-
Rajshahi Area	-	0.00	735	32	-
Comilla Area	-	0.00	505	22	-
Mymensingh Area	-	0.00	413	17	-
Sylhet Area	-	0.00	337	14	-
Barisal Area	-	0.00	150	7	-
Rangpur Area	-	0.00	422	17	-
Total	0		6646	231	
Information of the Generating machines under shut down.					
Planned Shut- Down			Forced Shut- Down		
1) Haripur SBU GT-3 (18/06/09)			1) Ghorasal #6 (18/07/10) 2) KhulnaST 60MW (24/1/12) 3) Shahjibazar #5 & 6 (21/7/11) 4) WMPL #1(1/5/12) 5) WMPL #2(24/4/13) 6) Meghnaghat CCPP (21/04/2014) 7) Ghorasal #3 (08/05/2014) 8) Ashuganj ST #2 (05/07/2014)		
9) Sikalbaha ST (03/07/2014) 10) Sikalbaha Peaking GT (29/06/2014) 11) Barapukuria #1 (10/07/2014) 12) Ashuganj #1 (10/07/2014) 13) Bheramara GT # 2 (08/06/2014)					
Additional Information of Machines. lines. Interruption / Forced Load shed etc.					
Description			Forced load shaded / Interrupted Areas		
a) Faridpur-Madaripur 132 kV Ckt-2 was shut down from 08:02 to 11:23 due to breaker problem at Faridpur end.			About 25 MW power interruption occurred under Faridpur S/S areas from 08:02 to 11:23.		
b) Seraiganj 132/33 kV T1 transformer was shut down from 08:26 to 11:12 due to oil leakage maintenance.					
c) Shahajadpur 132/33 kV T4 transformer was shut down at 10:56 due to red hot maintenance and was switched on at 11:46.					
d) Gulshan-Rampur 132 kV U/G cable Ckt-1 & 2 both tripped at 14:02 from both end showing diff. O/C relay and were switched on at 14:21, 18:00 respectively.			About 87 MW power interruption occurred under Gulshan S/S areas from 14:02 to 14:21.		
e) Comilla(N)-Comilla(S) 132 kV Ckt tripped at 20:58 from Comilla(N) end showing Direct. O/C, Z2 Comilla(S) showing no relay and was switched on at 21:16.			About 150 MW power interruption occurred under Comilla(S) S/S areas from 20:58 to 21:16.		
f) Hathazari-Feni 132 kV Ckt 1 & 2 tripped at 20:58 from both end showing Dist. E/F at Hathazari end and Z2 at Feni end and was switched on at 21:16.					
g) Bagherhat-Goalpara 132 kV Ckt tripped at 20:50 from Bagherhat end showing O/C relay and was switched on at 20:56.			About 88 MW power interruption occurred under Mongla,Bagherhat,Potua khali, Bhandaria S/S areas from 20:50 to 20:56.		
h) Jessore-Noapara 132 kV Ckt-1 & 2 tripped at 20:53 from Jessore end showing L1,2,3,4,5 relay and was switched on at 21:03.			About 185 MW power interruption occurred under Jessore, Jhenaidah, Magura, Chuadanga S/S areas from 20:53 to 21:03.		
i) Shahjibazar-Sreemongal Ckt-2 tripped at 01:24(12/07/14) from both end showing Dist Z1 and was switched on at 01:48(12/07/14).					
Sub Divisional Engineer Network Operation Division		Executive Engineer Network Operation Division		Superintendent Engineer Load Despatch Circle	