POWER GRID COMPANY OF BANGLADESH LTD.  NATIONAL LOAD, DESPATCH CENTER QF-LDC-1												
			C	AILY REPORT				Reporting Date :	23-Jul-14	Page -1		
Till now the ma	ximum generation is	:-	7418 MW		21:00	)	Hrs on	18-Jul-14				
The Summary o		22-Jul-14	Generation & Demar				Min Gen. & Probat					
Day Peak Genera		5746.0	MW	Hour :		11:00	Min. Gen. at	7:00	5316	MW		
Evening Peak Ger		7350.0	MW	Hour:		21:00	Max Generation	:	7402	MW		
E.P. Demand (at g		7350.0	MW	Hour :		21:00	Max Demand	:	7500	MW		
Maximum Genera		7350.0 143.6	MW System L/ Factor	Hour :		21:00 78.37%	Shortage		98 89	MW MW		
Total Gen. (MKWI	1) :			: H EAST-WEST INTERCON			Load Shed	<u> </u>	89	IVIVV		
Export from East grid to West grid :- Maximum -140					MW	at	13:00	Energy	7.867	MKWHR.		
Import from West grid to East grid :- Maximum					MW	at	-	Energy	-	MKWHR.		
	Wate	r Level of Kaptai	Lake at 6:00 A M on			3-Jul-14		- 5/				
Actual :	87.64 Ft.(I	MSL),		Rule curve	:	87.52	Ft.( MSL )					
Gas Consumed :	Total	957.23	MMCFD.		Oil C	onsumed	(PDR) ·					
Cas Consumed .	rotai	331.23	WINIOI D.		Oll O	onsumea	(1 00).	HSD :		Liter		
								FO :		Liter		
Cost of the Consu	med Fuel (PDB+Pvt) :	Gas :	Tki	81,680,503								
		Coal :	Tk	16,327,715		Oil	: Tk401,229,463	Total :	Tk499,237,68	1		
	Load	Shedding & Ot	her Information									
Area Yesterday							Today					
			Estimate	d Demand(s/s end)			Estimated Shedo	ding (s/s end)	Rates of She	dding		
	MW			MW				MW	(On Estimated			
Dhaka	-	0:00		2740				50	-			
Chittagong Area	-	0:00		709				12	-			
Khulna Area	-	0:00		780				15	_			
Rajshahi Area	_	0:00		750				12	-			
Comilla Area	_	0:00		506								
Mymensingh Area	_	0:00		413				_	_			
Sylhet Area	-	0:00		336				-	-			
Barisal Area	-			149				-	-			
	-	0:00						-	-			
Rangpur Area	-	0:00		423				-	-			
Total	0			6806				89				
Total				0000				00				
	Information of the	e Generating ma	chines under shut down.									
	Planned Shut- Down						Forced Shut-Down					
	1) Haripur GT: Unit-3 (18/06/2009)					1) Ghorasal ST: Unit-6 (18/07/2010)						
	,					2) Megnaghat CCPP (21/04/2014)						
						3) Sikalbaha Peaking GT (29/06/2014)						
						4) Sikalbaha ST (03/07/2014)						
					1		•					
					1							
										-		
	A dallela and but a second											
	Additional Informatio	n of Machines.	lines. Interruption / For	cea Load sned etc.								
Description						ed load s	haded / Interrupted	Areas				
	ara 230 kV Ckt-1 trippe	d at 08:56 from Is	shurdi end showing DTT	and was switched on								
at 12-43. b) Hasnabad-Lalbagh 132 kV Ckt tripped at 11:55 from both end showing distance Z2 and was switched on at 12:14.												
on at 12:14. On at 12:14. On Strict (Strict (S												
end.				•								
e) Mymenshing 132/33 kV T2 transformer was shut down from 14:13 to 15:43 due to 33 kV CT B phase oil leakage.  M Madannani S/S-Madannani P/S 132 kV Ckt was shut down at 07:00/23/07/2014) due to schedule shut down												

f) Madanganj S/S-Madanganj P/S 132 kV Ckt was shut down at 07:00(23/07/2014) due to schedule shut down.

Sub Divisional Engineer Executive Engineer
Network Operation Division Network Operation Division

Superintendent Engineer Load Despatch Circle