POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

Reporting Date: 29-Jul-14

The Summary of Yesterday's (the max	ximum generati	on is : -	7418 MW		21:00	Hrs on	Reporting Date : 18-Jul-14	29-Jul-14		
Evening Peak Ceneration 6448.0 MW									ble Gen. & De	emand	
E.P. Demand (all gen end)	Generati	ion :	4469.0	MW	Hou	12:00	Min. Gen. at	7:00	4356	MW	
E.P. Demand (at gen end)	eak Gen	eration :	6448.0	MW	Hou	19:30	Max Generation	:	7150	MW	
Maximum Generation S448,0 MW								:		MW	
Total Cene, (MKWH) : 120.3 System Factor The Ta.37% Load Shed : 0								:		MW	
Export from East grid to West grid - Maximum										MW	
Export from East grid to West grid 1: Maximum 280 MW at 1 3:30 Energy 7.867 MV at 1 1.30 Ene	. (101120011	·/ ·			EST INTE			•		10100	
My					ESI INIE			F	7.007	MICALLID	
Water Level of Kapital Lake at 6:00 A M on Rule curve : 88.49 FL(MSL)				-280						MKWHR.	
Actual 87.64 FL(MSL) Rule curve 88.49 FL(MSL)	m West g	grid to East grid :		-			-	Energy	-	MKWHR.	
Sas Consumed Total 922.67 MMCFD. Oil Consumed (PDB) HSD FO			Water Level of Kaptai L	ake at 6:00 A M on		29-Jul-14					
Additional Information of Machines, lines, Interruption / Forced Load shedd / Interrupted Areas	Actual:	87.64	Ft.(MSL),	Ru	ule curve :	88.49	Ft.(MSL)				
HSD FO FO FO FO FO FO FO F			,				, ,				
HSD FO FO FO FO FO FO FO F	umed .	Total	922 67	MMCFD		Oil Consumed	(PDR) ·				
FO	umou .	rotai	022.01	WINTON B.		Oil Coribanica	(1 00).	HeD .		Liter	
Cost of the Consumed Fuel (PDB+Pvt) : Gas : #VALUE! Coal : Tk16.054,286											
Coal Tk16,054,286								FO :		Liter	
Coal Tk16,054,286											
Company Comp	e Consur	med Fuel (PDB+F	Pvt): Gas :	#VALUE!							
Company Comp			Coal :	Tk16,054,286		Oil	: Tk227,672,530	Total :	#VALUE!		
Area Yesterday				-,,			,- ,				
Estimated Shedding (s/s end)			Load Shedding & Oth	er Information							
Estimated Shedding (s/s end)		Voctorde	21/	1			Today				
MW		Y esterda	1 y		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			r / /			
Daka				,	s/s end)		Estimated Shed	J (Rates of Sh		
Chittagong Area Chulna Area Comilla Are		MW		MW				MW	(On Estimate	d Demand)	
Chittagong Area Chulna Area Comilla Are		-	0:00	2383				-	-		
Chulna Area - 0.00	a Aroa	_							_		
Rajshahi Area	~	_						-	_		
Comilla Area	ea	-	0:00	668				-	-		
Comilla Area	Area	-	0:00	649				-	-		
Mymensingh Area - 0.00 369 -	rea	-	0.00	447				_	_		
Sylhet Area - 0.00 301											
Planned Shut- Down	-	-						-	-		
Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description Additional Information of Machines. lines. Interruption / Forced Load shede / Interrupted Areas a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 16:50 to 17:01 due to maintenance Sirajganj ST synchronized at 18:52.	∍a	-	0:00	301				-	-		
Information of the Generating machines under shut down. Planned Shut- Down 1) Haripur GT: Unit-3 (18/06/2009) 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CCPP (21/04/2014) 3) Sikalbaha Peaking GT (29/06/2014) 4) Sikalbaha ST (03/07/2014) 5) Sylhet 150 MW (28/07/14) 6) Ashuganj #1(27/07/14) Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description Additional Information of Machines at November 2012 (19/06/2014) 4) Sikalbaha ST (03/07/2014) 5) Sylhet 150 MW (28/07/14) 6) Ashuganj #1(27/07/14) Additional Information of Machines at November 2012 (19/06/2014) 4) Shufter maintenance Sirajganj CCPP GT was synchronized at 15:55. 2) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. 4) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance from 16:50 to 17:01. The control of the Generating machines under shut down from 12:17 to 13:05 due to red hot maintenance at November 2012 (19/06/2014) Additional Information of Machines. Interruption / Forced Load shed etc. Description Additional Information of Machines. Interruption / Forced Load shed etc. Description Additional Information of Machines. Interruption / Forced Load shed etc.	ea	-	0:00	134				-	-		
Information of the Generating machines under shut down. Planned Shut- Down 1) Haripur GT: Unit-3 (18/06/2009) 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CCPP (21/04/2014) 3) Sikalbaha Peaking GT (29/06/2014) 4) Sikalbaha ST (03/07/2014) 5) Sylhet 150 MW (28/07/14) 6) Ashuganj #1(27/07/14) Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description Additional Information of Machines at November 2012 (19/06/2014) 4) Sikalbaha ST (03/07/2014) 5) Sylhet 150 MW (28/07/14) 6) Ashuganj #1(27/07/14) Additional Information of Machines at November 2012 (19/06/2014) 4) Shufter maintenance Sirajganj CCPP GT was synchronized at 15:55. 2) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. 4) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance from 16:50 to 17:01. The control of the Generating machines under shut down from 12:17 to 13:05 due to red hot maintenance at November 2012 (19/06/2014) Additional Information of Machines. Interruption / Forced Load shed etc. Description Additional Information of Machines. Interruption / Forced Load shed etc. Description Additional Information of Machines. Interruption / Forced Load shed etc.								-	_		
Information of the Generating machines under shut down. Planned Shut- Down	"ou		0.00	0,0							
Information of the Generating machines under shut down. Planned Shut- Down											
Planned Shut- Down 1) Haripur GT: Unit-3 (18/06/2009) 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CCPP (21/04/2014) 3) Sikalbaha Peaking GT (29/06/2014) 4) Sikalbaha ST (03/07/2014) 5) Sylhet 150 MW (28/07/14) 6) Ashuganj #1(27/07/14) Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Sirajganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance from 16:50 to 17:01. e) After maintenance Sirajganj ST synchronized at 18:52.		0		5940				0			
1) Haripur GT: Unit-3 (18/06/2009) 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CCPP (21/04/2014) 3) Sikalbaha ST (03/07/2014) 4) Sikalbaha ST (03/07/2014) 5) Sylhet 150 MW (28/07/14) 6) Ashuganj #1(27/07/14) Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Sirajganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance at from 16:50 to 17:01. 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CCPP (21/04/2014) 3) Sikalbaha ST (03/07/2014) 5) Sylhet 150 MW (28/07/14) 6) Ashuganj #1(27/07/14) Forced load shaded / Interrupted Areas at Noapara end. b) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance from 16:50 to 17:01.		Information	of the Generating mac	nines under shut down.							
1) Haripur GT: Unit-3 (18/06/2009) 2) Megnaghat CCPP (21/04/2014) 3) Sikalbaha ST (03/07/2014) 4) Sikalbaha ST (03/07/2014) 5) Sylhet 150 MW (28/07/14) 6) Ashuganj #1(27/07/14) Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description 3) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Sirajganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance at Noapara Sirajganj ST synchronized at 18:52.											
Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description Althoracy Interruption Forced load shaded / Interrupted Areas Althoracy Interrupted Areas About 30 MW power interruption occurred under Ghorasal S/S are 33 kV end. Alter maintenance Sirajganj ST synchronized at 18:52.											
Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Sirajganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance from 16:50 to 17:01. 3) Sikalbaha Peaking GT (29/06/2014) 4) Sikalbaha ST (03/07/2014) 5) Sylhet 150 MW (28/07/14) 6) Ashuganj #1(27/07/14) Forced Load shaded / Interrupted Areas a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Sirajganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance from 16:50 to 17:01.											
Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Sirajganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance from 16:50 to 17:01.						- -					
Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Sirajganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance from 16:50 to 17:01.											
Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Sirajganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance from 16:50 to 17:01. Sylhet 150 MW (28/07/14) 6) Ashuganj #1(27/07/14) Forced Load shaded / Interrupted Areas at Noapara end. b) After maintenance Sirajganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance from 16:50 to 17:01.						4) Sikalbaha ST (03/07/2014) 5) Sylhet 150 MW (28/07/14)					
Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description											
Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description All Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. All All All All All All All All All Al											
Description a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Siraiganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance 3 kV end. e) After maintenance Siraiganj ST synchronized at 18:52.											
Description a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Siraiganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance 3 from 16:50 to 17:01. e) After maintenance Siraiganj ST synchronized at 18:52.											
Description a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Siraiganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance 3 from 16:50 to 17:01. e) After maintenance Siraiganj ST synchronized at 18:52.											
Description a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Siraiganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance 3 kV end. e) After maintenance Siraiganj ST synchronized at 18:52.						•					
Description a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Siraiganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance 3 from 16:50 to 17:01. e) After maintenance Siraiganj ST synchronized at 18:52.		Additional Info	mation of Machines. li	nes. Interruption / Forced	Load shed	etc.					
a) Khulna (C) - Noapara 132 kV Ckt -1 was under shut down from 12:17 to 13:05 due to red hot maintenance at Noapara end. b) After maintenance Sirajganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenance and About 30 MW power interruption occurred under Ghorasal S/S are 133 kV end. e) After maintenance Sirajganj ST synchronized at 18:52.							hadad / let	I Avene			
at Noapara end. 2) After maintenance Sirajganj CCPP GT was synchronized at 15:55. 3) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. 4) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenant About 30 MW power interruption occurred under Ghorasal S/S are 16:50 to 17:01. 5) After maintenance Sirajganj ST synchronized at 18:52.			-1 was under chut dem	n from 12:17 to 12:05 due to		·	naueu / interrupted	ı Altas			
b) After maintenance Sirajganj CCPP GT was synchronized at 15:55. c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenant About 30 MW power interruption occurred under Ghorasal S/S are 33 kV end. e) After maintenance Sirajganj ST synchronized at 18:52.		upara 132 KV CK	- i was unuel shul dow	11 11 12.17 to 13.05 tide to	reu not ma	mmenante !					
c) After maintenance Kabirpur - Tangail 132 kV Ckt -1 switched on at 16:40. d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenant About 30 MW power interruption occurred under Ghorasal S/S are 33 kV end. e) After maintenance Sirajganj ST synchronized at 18:52.											
d) Ghorasal 132/33 kV T1 Transformer was under shut down from 16:50 to 17:01 due to maintenant About 30 MW power interruption occurred under Ghorasal S/S are 33 kV end. a) After maintenance Sirajganj ST synchronized at 18:52.											
33 kV end. e) After maintenance Sirajganj ST synchronized at 18:52. from 16:50 to 17:01.											
e) After maintenance Sirajganj ST synchronized at 18:52.	al 132/33	3 kV T1 Transform	mer was under shut dow	n from 16:50 to 17:01 due to	o maintenar	About 30 MW p	oower interruption o	ccurred under Gho	rasal S/S area	S	
	end.					from 16:50 to 1	7:01.				
	aintenan	ce Sirajaani ST s	ynchronized at 18:52.								
, analysing a second second at 20112 and to stourn loanage from high probable line and was				leakage from high pressure	e line and w	as					
synchronized at 10:23 (29/07/2014)				ca.ago nom nign prossure	o mio ana w	i					
				0/C relevier division in the	ad an -+ 00	1					
g) Chatak 132/33 kV T1 transformer tripped at 22:17 showing O/C relay and was switched on at 22:31.											
h) Chandpur CCPP tripped at 23:22 showing O/C & compound voltage relay and was synchronized			snowing O/C & compo	und voltage relay and was s	synchronize	a !					
at 01:28 (29/07/2014).		,									
i) Haripur - Meghnaghat 230 kV Ckt -1 was under shut down from 01:19 to 03:22 (29/07/2014) due to red hot	- Meghna	aghat 230 kV Ckt	-1 was under shut down	n from 01:19 to 03:22 (29/07	7/2014) due	to red hot					
maintenance at Haripur end.	nance at	Haripur end.		•							
		=									
Sub Divisional Engineer Executive Engineer Superintendent Engin	ivisional	Fngineer		Executive Engineer		!		Superinten	dent Enginee	r	
		-		-	ion			•	_		
Network Operation Division	operatio	ווסופועום ווי		Network Operation Divisi	IUII	i		Load De	spatch Circle		