

Reporting Date : 7-Aug-14

Till now the maximum generation is :-

7418 MW

21:00

Hrs on 18-Jul-14

The Summary of Yesterday's (6-Aug-14		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	5747.0	MW	Hou 12:00	Min. Gen. at 7:00	5098 MW
Evening Peak Generation :	7037.0	MW	Hou 21:00	Max Generation :	7153 MW
E.P. Demand (at gen end) :	7037.0	MW	Hou 21:00	Max Demand :	7250 MW
Maximum Generation :	7037.0	MW	Hou 21:00	Shortage :	97 MW
Total Gen. (MKWH) :	140.8	System L/ Factor :	78.37%	Load Shed :	87 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :-	Maximum	-90	MW	at	12:00	Energy	7.867	MKWHR.
Import from West grid to East grid :-	Maximum	-	MW	at	-	Energy	-	MKWHR.

Water Level of Kaptai Lake at 6:00 A M on 7-Aug-14		Rule curve :		7-Aug-14	
Actual :	87.64	Ft.(MSL) ,	90.92	Ft.(MSL)	

Gas Consumed : Total	923.80	MMCFD.	Oil Consumed (PDB) :	
			HSD :	Liter
			FO :	Liter

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk77,140,581	Oil :	Tk445,330,388	Total :	Tk536,767,484
	Coal :	Tk14,296,515				

Load Shedding & Other Information

Area	Yesterday		Today	
	MW		MW	
Dhaka	-	0.00	2564	-
Chittagong Area	-	0.00	685	23
Khulna Area	-	0.00	750	24
Rajshahi Area	-	0.00	725	24
Comilla Area	-	0.00	498	16
Mymensingh Area	-	0.00	395	-
Sylhet Area	-	0.00	322	-
Barisal Area	-	0.00	143	-
Rangpur Area	-	0.00	404	-
Total	0	6486	87	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur GT: Unit-3 (18/06/2009)	1) Ghorasal ST: Unit-6 (18/07/2010)
	2) Megnaghat CCPP (21/04/2014)
	3) Sylhet 150 MW GT (28/07/14)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) Ishurdi-Bheramara 132 kV Ckt-1 was shut down from 09:13 to 16:54 due to PT change at Bheramara end. b) Faridpur-Madaripur 132 kV Ckt-1 was shut down from 10:20 to 11:24 due to maintenance work at Faridpur end. c) Tongi-Bashundhara 132 kV Ckt-1 was shut down from 12:05 to 14:30 due to red hot maintenance work at Bashundhara end. d) Megnaghat CCPP (Summit) unit-2 tripped at 14:13 due to fuel leakage and was synchronized on at 20:33. e) Faridpur 132/33 kV T2 transformer was shut down from 00:32 to 00:58 (07/08/2014) due to low gas pressure	About 30 MW power interruption occurred under Faridpur S/S areas from 00:32 to 00:58(07/08/2014)
Sub Divisional Engineer Network Operation Division	Executive Engineer Network Operation Division
	Superintendent Engineer Load Despatch Circle