

Till now the maximum generation is : - 7418 MW 21:00 Hrs on 18-Jul-14 Reporting Date : 8-Aug-14

The Summary of Yesterday's ( 7-Aug-14		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	5860.0	MW	Hour :	11:00	Min. Gen. at	7:00	4941 MW
Evening Peak Generation :	6977.0	MW	Hour :	21:00	Max Generation :		7005 MW
E.P. Demand (at gen end) :	7250.0	MW	Hour :	21:00	Max Demand :		7150 MW
Maximum Generation :	6977.0	MW	Hour :	21:00	Shortage :		145 MW
Total Gen. (MKWH) :	143.1	System L/ Factor :		78.37%	Load Shed :		128 MW

## EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :-	Maximum	-80	MW	at	15:00	Energy	7.867	MKWHR.
Import from West grid to East grid :-	Maximum	-	MW	at	-	Energy	-	MKWHR.

Actual : 87.64		Water Level of Kaptai Lake at 6:00 A M on	8-Aug-14
Ft.(MSL) ,		Rule curve :	91.24 Ft.( MSL )

Gas Consumed : Total	880.30	MMCFD.	Oil Consumed (PDB) :		HSD :		Liter
					FO :		Liter

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk80,324,856					
	Coal :	Tk14,960,171	Oil :	Tk473,416,224	Total :	Tk568,701,251	

## Load Shedding &amp; Other Information

Area	Yesterday		Estimated Demand(s/s end)	Today	
	MW			Estimated Shedding (s/s end)	Rates of Shedding
			MW	MW	(On Estimated Demand)
Dhaka	69	(20:05-23:45)	2476	-	-
Chittagong Area	32	(20:05-23:45)	638	-	-
Khulna Area	35	(20:05-23:45)	757	59	-
Rajshahi Area	31	(20:05-23:45)	676	-	-
Comilla Area	21	(20:05-23:45)	503	38	-
Mymensingh Area	17	(20:05-23:45)	414	31	-
Sylhet Area	17	(20:05-23:45)	312	-	-
Barisal Area	7	(20:05-23:45)	138	-	-
Rangpur Area	18	(20:05-23:45)	391	-	-
	-				
Total	247		6305	128	

Information of the Generating machines under shut down.

	Planned Shut- Down	Forced Shut- Down
	1) Haripur GT: Unit-3 (18/06/2009)	1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CCPP (21/04/2014) 3) Sylhet 150 MW GT (28/07/14) 4) Ashuganj #4 (07/08/14)

## Additional Information of Machines. lines. Interruption / Forced Load shed etc

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 247 MW (21:00) of load shed was imposed over the whole areas of the national grid .
b) Goalpara 132/33 kV T5 transformer was shut down from 09:12 to 10:12 due to red hot maintenance at B phase clamp.	
c) Haripur-Shaympur 132 kV Ckt tripped at 11:15 both end showing Dist. Z1, bus bar prot. Relay and was switched on at 11:38.	
d) Ashuganj #4 was force shut down at 21:27 due to auxiliary steam line leakage.	
e) Rampura-Mogbazar 132 kV Ckt1 was shut down at 05:54 (08/08/2014) due to tower shifting work.	
f) Rangpur 132/33 kV T1 transformer is under shut down since 06:30(08/08/14) due to development work.	About 30 MW power interruption occurred under Rangpur S/S areas from 06:30(08/08/2014) to till.

Sub Divisional Engineer  
Network Operation DivisionExecutive Engineer  
Network Operation DivisionSuperintendent Engineer  
Load Despatch Circle