

Till now the maximum generation is :-

7418 MW

21:00

Hrs on 18-Jul-14

Reporting Date : 11-Aug-14

The Summary of Yesterday's (10-Aug-14)				Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation	:	6058.0	MW	Hour :	12:00	Min. Gen. at	6:00	5345	MW
Evening Peak Generation	:	6981.0	MW	Hour :	20:00	Max Generation	:	7010	MW
E.P. Demand (at gen end)	:	6981.0	MW	Hour :	20:00	Max Demand	:	7100	MW
Maximum Generation	:	6981.0	MW	Hour :	20:00	Shortage	:	90	MW
Total Gen. (MKWH)	:	146.9	System L/ Factor	:	78.37%	Load Shed	:	81	MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum		36	MW	at	16:00	Energy	7.867	MKWHR.
Import from West grid to East grid :- Maximum		-	MW	at	-	Energy	-	MKWHR.
Water Level of Kaptai Lake at 6:00 A M on				11-Aug-14				
Actual	:	87.64	Ft.(MSL)	Rule curve	:	92.20	Ft.(MSL)	
Gas Consumed : Total		924.82	MMCFD.	Oil Consumed (PDB) :		HSD	:	Liter
						FO	:	Liter
Cost of the Consumed Fuel (PDB+Pvt) :		Gas	:	Tk85,576,417				
		Coal	:	Tk14,843,376	Oil	:	Tk497,002,271	Total : Tk597,422,064

Load Shedding & Other Information

Area	Yesterday		Today	
	MW		Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
			MW	
Dhaka	-	0.00	2518	-
Chittagong Area	-	0.00	665	16
Khulna Area	-	0.00	728	17
Rajshahi Area	-	0.00	705	17
Comilla Area	-	0.00	485	12
Mymensingh Area	-	0.00	397	9
Sylhet Area	-	0.00	316	-
Barisal Area	-	0.00	140	-
Rangpur Area	-	0.00	407	10
	-			-
Total	0		6361	81

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur GT: Unit-3 (18/06/2009)	1) Ghorasal ST: Unit-6 (18/07/2010)
	2) Megnaghat CCPP (21/04/2014)
	3) Sylhet 150 MW GT (28/07/14)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) Mymensingh 132/33 kV T3 transformer tripped at 09:35 showing over current relay and was switched on at 09:49. b) Haripur 230 kV reserve bus was shut down from 11:25 to 16:15 due to project work. c) Rangpur-Palashbari 132 kV Ckt-2 was shut down from 14:10 to 14:35 due to project work.	About 15 MW power interruption occurred under Mymensingh S/S areas from 09:35 to 09:49.

Sub Divisional Engineer
Network Operation DivisionExecutive Engineer
Network Operation DivisionSuperintendent Engineer
Load Despatch Circle