POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

Reporting Date: 12-Aug-14 Till now the maximum generation is: 7418 MW 21:00 The Summary of Yesterday's (11-Aug-14 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 6052.0 MW Hour 12:00 Min. Gen. at 7:00 5486 MW Evening Peak Generation MW Max Generation 6872.0 Hour: 20:00 6850 MW E.P. Demand (at gen end) : 6872.0 MW 20:00 Max Demand 7200 MW Hour: Maximum Generation 6912.0 MW Hour: 24:00 Shortage 350 MW Total Gen. (MKWH) 146.0 System L/ Factor 78.37% Load Shed 312 MW EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR MKWHR. Export from East grid to West grid :- Maximum 17:00 Energy 7.867 150 MW at Import from West grid to East grid :- Maximum MW MKWHR. at Energy Water Level of Kaptai Lake at 6:00 A M on 12-Aug-14 87.64 Ft.(MSL) Ft.(MSL) Actual: Rule curve 92.52 Gas Consumed: Total 916.99 MMCFD. Oil Consumed (PDB): HSD Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt) : Gas Tk79,723,150 Tk14,999,628 Total : Tk585,026,680 : Tk490,303,902 **Load Shedding & Other Information** Area Yesterday Today Estimated Demand(s/s end) Estimated Shedding (s/s end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka 0:00 74 2524 32 (19:15-22:10) 670 40 Chittagong Area 34 (19:15-22:10) 735 45 Khulna Area Rajshahi Area 30 (19:15-22:10) 710 42 Comilla Area 20 (19:15-22:10) 490 30 Mymensingh Area 15 (19:15-22:10) 405 26 Sylhet Area 8 330 21 (19:15-22:10) Barisal Area 8 (19:15-22:10) 146 9 Rangpur Area 14 (19:15-22:10) 413 25 Total 6423 312 161 Information of the Generating machines under shut down. Planned Shut- Down Forced Shut- Down I) Haripur GT: Unit-3 (18/06/2009) 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CCPP (21/04/2014) 3) Svihet 150 MW GT (28/07/14) 4) Ghorasal-5(12/8/14) Additional Information of Machines. lines. Interruption / Forced Load shed etc Forced load shaded / Interrupted Areas Description a) There was generation shortage in the evening peak hour yesterday. So about 161 MW (20:00) of load shed was imposed over the b) Bheramara HVDC 230 kV filter - 22 shut down at 09:13 due to AM. whole areas (Except Dhaka) of the national grid c) Meghnaghat - Haripur 230 kV Ckt - 1 was shut down from 10:07 to 16:01 due to DFDR installation. d) Gopalganj 132/33 kV T1 transformer was shut down from 10:31 to 10:56 due to red hot maintenance at 132 kV end. e) Rangpur 132 kV A-Bus was under shut down at 09:40 due to development work. f) Raozan # 1 tripped at 13:18 due to boiler feed pump problem and was switched on at 13:27. g) Tongi - Kabirpur Ckt # 2 tripped at 13:12 from both end showing O/C relay at Tongi end and distance C phase, Z2 at Kabirpur end and was switched on at 13:25. h) After maintenance Bhulta - Ghorashal and Narshingdi - Ghorashal 132 kV Ckt switched on at 11:40 & 11:43 respectively. i) Khulna ©-Noapara 132 kV Ckt - 1 was shut down from 16:42 to 17:22 due to red hot maintenance at Noapara end. j) Ghorashal unit - 5 tripped at 05:15(12/08/2014) due to water tube leakage .

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division Superintendent Engineer

Load Despatch Circle